

## SECTION 224000 - PLUMBING FIXTURES

### PART 1 - GENERAL

#### 1.1 STIPULATIONS

- A. The specifications sections “General Conditions of the Construction Contract”, “Special Conditions”, and “Division 1 – General Requirements” form a part of this Section by this reference thereto, and shall have the same force and effect as if printed herewith in full.
- B. This Section includes the following conventional plumbing fixtures and related components:
  - 1. Faucets for lavatories.
  - 2. Toilet seats.
  - 3. Protective shielding guards.
  - 4. Fixture supports.
  - 5. Water closets.
  - 6. Urinals.
  - 7. Lavatories.

#### 1.2 DEFINITIONS

- A. ABS: Acrylonitrile-butadiene-styrene plastic.
- B. Accessible Fixture: Plumbing fixture that can be approached, entered, and used by people with disabilities.
- C. Cast Polymer: Cast-filled-polymer-plastic material. This material includes cultured-marble and solid-surface materials.
- D. Cultured Marble: Cast-filled-polymer-plastic material with surface coating.
- E. Fitting: Device that controls the flow of water into or out of the plumbing fixture. Fittings specified in this Section include supplies and stops, faucets and spouts, shower heads and tub spouts, drains and tailpieces, and traps and waste pipes. Piping and general-duty valves are included where indicated.
- F. FRP: Fiberglass-reinforced plastic.
- G. PMMA: Polymethyl methacrylate (acrylic) plastic.
- H. PVC: Polyvinyl chloride plastic.
- I. Solid Surface: Nonporous, homogeneous, cast-polymer-plastic material with heat-, impact-, scratch-, and stain-resistance qualities.

### 1.3 SUBMITTALS

- A. Product Data: For each type of plumbing fixture indicated. Include selected fixture and trim, fittings, accessories, appliances, appurtenances, equipment, and supports. Indicate materials and finishes, dimensions, construction details, and flow-control rates.
- B. Operation and Maintenance Data: For plumbing fixtures to include in emergency, operation, and maintenance manuals.
- C. Warranty: Special warranty specified in this Section.

### 1.4 QUALITY ASSURANCE

- A. Source Limitations: Obtain plumbing fixtures, faucets, and other components of each category through one source from a single manufacturer.
  - 1. Exception: If fixtures, faucets, or other components are not available from a single manufacturer, obtain similar products from other manufacturers specified for that category.
- B. Regulatory Requirements: Comply with requirements in Public Law 102-486, "Energy Policy Act," about water flow and consumption rates for plumbing fixtures.
- C. Select combinations of fixtures and trim, faucets, fittings, and other components that are compatible.

### 1.5 WARRANTY

- 1. Warranty Period for Commercial Applications: One year from date of Substantial Completion.

## PART 2 - PRODUCTS

### 2.1 LAVATORY FAUCETS

- A. Lavatory Faucets (ADA):
  - 1. Product: Subject to compliance with requirements, provide product by one of the following:
    - a. Delta Faucet Company.
    - b. Kohler Co.
    - c. Moen, Inc.
    - d. Or approved equal.
  - 2. Description: Two-handle mixing valve. Include hot- and cold-water indicators; coordinate faucet inlets with supplies and fixture holes; coordinate outlet with spout and fixture receptor.

- a. Standards: ASME A112.18.1/CSA B125.1 and UL 1951.
- b. Body Material: Commercial, solid brass.
- c. Finish: Polished chrome plate.
- d. Maximum Flow Rate: 0.5 gpm.
- e. Centers: 4 inches
- f. Mounting Type: Deck.
- g. Valve Handle(s): Wrist blade, 4 inches.
- h. Inlet(s): NPS 1/2 male shank.
- i. Spout: Rigid.
- j. Spout Outlet: Vandal resistant spray head.
- k. Operation: Quarter-turn cartridges.
- l. Drain: Grid.
- m. Tempering Device: Below the deck mechanical mixing valve, ASSE 1070 approved for temperature and pressure protection.

## 2.2 FLUSHOMETERS

### A. Flushometers, P-1, P-1A:

- 1. Product: Subject to compliance with requirements, provide product by one of the following:
  - a. Delta Faucet Company.
  - b. Zurn Plumbing Products Group; Commercial Brass Operation.
  - c. TOTO USA, Inc.
  - d. Or Approved Equal.
- 2. Description: Flushometer for water-closet-type fixture. Include brass body with corrosion-resistant internal components, non-hold-open feature, control stop with check valve, vacuum breaker, copper or brass tubing, and polished chrome-plated finish on exposed parts.
  - a. Internal Design: Diaphragm operation.
  - b. Style: Exposed.
  - c. Inlet Size: NPS 1.
  - d. Trip Mechanism: Oscillating, lever-handle actuator.
  - e. Consumption: 1.6 gal./flush.
  - f. Tailpiece Size: NPS 1-1/2 and standard length to top of bowl.

### B. Flushometers:

- 1. Product: Subject to compliance with requirements, provide product by one of the following:
  - a. Delta Faucet Company.
  - b. Zurn Plumbing Products Group; Commercial Brass Operation.
  - c. TOTO USA, Inc.
  - d. Or Approved Equal.

2. Description: Flushometer for urinal-type fixture. Include brass body with corrosion-resistant internal components, non-hold-open feature, control stop with check valve, vacuum breaker, copper or brass tubing, and polished chrome-plated finish on exposed parts.
  - a. Internal Design: Diaphragm operation.
  - b. Style: Exposed.
  - c. Inlet Size: NPS 3/4.
  - d. Trip Mechanism: Oscillating, lever-handle actuator.
  - e. Consumption: 0.5 gal./flush.
  - f. Tailpiece Size: NPS 3/4 and standard length to top of bowl.

## 2.3 TOILET SEATS

### A. Toilet Seats:

1. Basis-of-Design Product: Subject to compliance with requirements, provide Beneke 523 or a comparable product by one of the following:
  - a. American Standard Companies, Inc.
  - b. Church Seats.
  - c. Olsonite Corp.
  - d. Or Approved Equal.
2. Description: Toilet seat for water-closet-type fixture.
  - a. Material: Molded, solid plastic.
  - b. Configuration: Open front without cover.
  - c. Size: Elongated.
  - d. Hinge Type: CK, check.
  - e. Class: Heavy-duty commercial.
  - f. Color: White.

## 2.4 PROTECTIVE SHIELDING GUARDS

### A. Protective Shielding Piping Enclosures:

1. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
  - a. TRUEBRO, Inc.
  - b. Or Approved Equal.
2. Description: Manufactured plastic enclosure for covering plumbing fixture hot- and cold-water supplies and trap and drain piping. Comply with ADA requirements.

## 2.5 FIXTURE SUPPORTS

1. Reuse existing supports.

## 2.6 WATER CLOSETS

### A. Water Closets:

1. Basis-of-Design Product: Subject to compliance with requirements, provide Kohler Wellcomme K-4350 or a comparable product by one of the following:
  - a. American Standard Companies, Inc.
  - b. Crane Plumbing, L.L.C./Fiat Products.
  - c. TOTO USA, Inc.
  - d. Or Approved Equal.
2. Description: Floor-mounting, bottom outlet, vitreous-china fixture designed for flushometer valve operation.
  - a. Bowl Type: Elongated with siphon-jet design. Include bolt caps matching fixture.
  - b. Height: Standard.
  - c. Water Consumption: 1.6 gal./flush
  - d. Spud Size and Location: NPS 1-1/2; top.
  - e. Color: White.
  - f. Flushometer Valve
  - g. Toilet Seat

## 2.7 URINALS

### A. Urinals

1. Basis-of-Design Product: Subject to compliance with requirements, provide Kohler Dexter K-5016-ET or a comparable product by one of the following:
  - a. American Standard Companies, Inc.
  - b. Crane Plumbing, L.L.C./Fiat Products.
  - c. TOTO USA, Inc.
  - d. Or Approved Equal.
2. Description: Accessible, wall-mounting, back-outlet, vitreous-china fixture designed for flushometer valve operation.
  - a. Type: Siphon jet.
  - b. Strainer or Trapway: Open trapway with integral trap.
  - c. Rim Height to match existing supports
  - d. Water Consumption: 0.5 gal./flush.
  - e. Spud Size and Location: NPS 3/4; top.
  - f. Color: White.
  - g. Outlet Size: NPS 2.
  - h. Flushometer: P-2, P-2A.

## 2.8 LAVATORIES

### A. Lavatories:

1. Basis-of-Design Product: Subject to compliance with requirements, provide Kohler Kingston K-2005 or a comparable product by one of the following:
  - a. American Standard Companies, Inc.
  - b. Crane Plumbing, L.L.C.
  - c. TOTO USA, Inc.
  - d. Or Approved Equal.
2. Description: Wall-mounting, vitreous-china fixture.
  - a. Type: Ledge back.
  - b. Size: 21 by 18 inches rectangular.
  - c. Faucet Hole Punching: Three holes, 4-inch.
  - d. Faucet Hole Location: Top.
  - e. Color: White.
  - f. Faucet: Lavatory
  - g. Protective Shielding Guard(s):
  - h. Fixture Support: Lavatory

## PART 3 - EXECUTION

### 3.1 EXAMINATION

- A. Examine roughing-in of water supply and sanitary drainage and vent piping systems to verify actual locations of piping connections before plumbing fixture installation.
- B. Examine cabinets, counters, floors, and walls for suitable conditions where fixtures will be installed.
- C. Proceed with installation only after unsatisfactory conditions have been corrected.

### 3.2 INSTALLATION

- A. Assemble plumbing fixtures, trim, fittings, and other components according to manufacturers' written instructions.
- B. Install off-floor supports, affixed to building substrate, for wall-mounting fixtures.
  1. Use carrier supports with waste fitting and seal for back-outlet fixtures.
  2. Use carrier supports without waste fitting for fixtures with tubular waste piping.
  3. Use chair-type carrier supports with rectangular steel uprights for accessible fixtures.
- C. Install back-outlet, wall-mounting fixtures onto waste fitting seals and attach to supports.

- D. Install floor-mounting fixtures on closet flanges or other attachments to piping or building substrate.
- E. Install wall-mounting fixtures with tubular waste piping attached to supports.
- F. Install fixtures level and plumb according to roughing-in drawings.
- G. Install water-supply piping with stop on each supply to each fixture to be connected to water distribution piping. Attach supplies to supports or substrate within pipe spaces behind fixtures. Install stops in locations where they can be easily reached for operation.
  - 1. Exception: Use ball, gate, or globe valves if supply stops are not specified with fixture. Valves are specified in Division 22 Section "General-Duty Valves for Plumbing Piping."
- H. Install trap and tubular waste piping on drain outlet of each fixture to be directly connected to sanitary drainage system.
- I. Install flushometer valves for accessible water closets and urinals with handle mounted on wide side of compartment. Install other actuators in locations that are easy for people with disabilities to reach.
- J. Install toilet seats on water closets.
- K. Install faucet-spout fittings with specified flow rates and patterns in faucet spouts if faucets are not available with required rates and patterns. Include adapters if required.
- L. Install traps on fixture outlets.
  - 1. Exception: Omit trap on fixtures with integral traps.
  - 2. Exception: Omit trap on indirect wastes, unless otherwise indicated.
- M. Install escutcheons at piping wall ceiling penetrations in exposed, finished locations and within cabinets and millwork. Use deep-pattern escutcheons if required to conceal protruding fittings.
- N. Seal joints between fixtures and walls, floors, and countertops using sanitary-type, one-part, mildew-resistant silicone sealant. Match sealant color to fixture color.

### 3.3 CONNECTIONS

- A. Piping installation requirements are specified in other Division 22 Sections. Drawings indicate general arrangement of piping, fittings, and specialties.
- B. Connect fixtures with water supplies, stops, and risers, and with traps, soil, waste, and vent piping. Use size fittings required to match fixtures.

### 3.4 FIELD QUALITY CONTROL

- A. Verify that installed plumbing fixtures are categories and types specified for locations where installed.

- B. Check that plumbing fixtures are complete with trim, faucets, fittings, and other specified components.
- C. Inspect installed plumbing fixtures for damage. Replace damaged fixtures and components.
- D. Test installed fixtures after water systems are pressurized for proper operation. Replace malfunctioning fixtures and components, then retest. Repeat procedure until units operate properly.

### 3.5 ADJUSTING

- A. Operate and adjust faucets and controls. Replace damaged and malfunctioning fixtures, fittings, and controls.
- B. Adjust water pressure at faucets and flushometer valves to produce proper flow and stream.
- C. Replace washers and seals of leaking and dripping faucets and stops.

### 3.6 CLEANING

- A. Clean fixtures, faucets, and other fittings with manufacturers' recommended cleaning methods and materials. Do the following:
  - 1. Remove faucet spouts and strainers, remove sediment and debris, and reinstall strainers and spouts.
  - 2. Remove sediment and debris from drains.
- B. After completing installation of exposed, factory-finished fixtures, faucets, and fittings, inspect exposed finishes and repair damaged finishes.

### 3.7 PROTECTION

- A. Provide protective covering for installed fixtures and fittings.
- B. Do not allow use of plumbing fixtures for temporary facilities unless approved in writing by Owner.

**END OF SECTION 224000**