

ADDENDUM NO. 3

Date: 4/17/2023

To: ALL BIDDERS

From: Buchart Horn Architects
445 West Philadelphia Street
P. O. Box 15040
York, PA 17405-7040

Subject: **York County Board of Commissioners
Alterations and Additions for the York County Central Booking Relocation**

Project: 77332-07

NOTE: This Addendum forms a part of the Contract Documents and modifies the Original Documents dated March 2023. Acknowledgement of receipt of this Addendum shall be completed by answering RFI 3.1 "I Agree" when submitting bids on the PennBid website. Failure to do so may subject the Bidder to disqualification.

General Clarification – The access control and video surveillance systems are provided by vendors who are directly contracted with the County. The scope for the electrical contractor in relation to these systems is as listed on the electrical drawings.

ITEM A - REVISIONS TO ADDENDUM NO. 2

Page 00 91 13.2-5, Item B – Revisions to the Drawings, Sheet No. E-601, One Line Diagram and Panel Schedules – DELETE Sheet No. E-601, One Line Diagram and Panel Schedules and REPLACE with revised Sheet E-601, One Line Diagram and Panel Schedules, attached to this Addendum No. 3.

ITEM B - REVISIONS TO THE SPECIFICATIONS GROUP IN THE PROJECT MANUAL

Page 10 51 14-1, Welded Duty Lockers – DELETE reference to mechanical air circulation and ADD reference to natural air circulation in paragraph 1.2.A.1.

Page 10 51 14-8, Welded Duty Lockers – DELETE reference to Lockers EQ-14 and EQ-15 at paragraphs 2.4.G.9 and 2.5.

ITEM C - REVISIONS TO THE DRAWINGS

Sheet No A-102, Partial First Floor Plans

Partial First Floor Plan – Area A: At new exterior cavity wall east of door A101 and at new exterior cavity wall at northeast corner of Property Storage A119, DELETE 1" dimension where the new addition abuts the existing building. There is no building expansion joint required here. Therefore, CHANGE overall exterior wall dimensions from 29'-8-1/4" to 29'-9-1/4" and from 39'-11" to 40'-0" respectively.

Sheet No A-401, Enlarged Plans

Locker Types: CHANGE Locker Types A and B from 90" high to 72" high.

Locker Types: CHANGE Locker Type C from 84" high 2-tier to 72" high 2-tier.

END OF ADDENDUM NO. 3