

---

**SECTION 09 21 16**  
**GYPSUM BOARD ASSEMBLIES****PART 1 GENERAL****1.1 SECTION INCLUDES**

- A. Metal stud wall framing.
- B. Metal channel ceiling framing.
- C. Gypsum wallboard.
- D. Joint treatment and accessories.

**1.2 RELATED REQUIREMENTS**

- A. Section 06 10 00 - Rough Carpentry: Wood blocking product and execution requirements.
- B. Section 07 92 00 - Joint Sealants:

**1.3 REFERENCE STANDARDS**

- A. AISI S201 - North American Standard for Cold-Formed Steel Framing - Product Data 2017.
- B. AISI S220 - North American Standard for Cold-Formed Steel Nonstructural Framing 2020.
- C. AISI S240 - North American Standard for Cold-Formed Steel Structural Framing 2015, with Errata (2020).
- D. ASCE 7 - Minimum Design Loads and Associated Criteria for Buildings and Other Structures Most Recent Edition Cited by Referring Code or Reference Standard.
- E. ASTM A1003/A1003M - Standard Specification for Steel Sheet, Carbon, Metallic- and Nonmetallic-Coated for Cold-Formed Framing Members 2015.
- F. ASTM C475/C475M - Standard Specification for Joint Compound and Joint Tape for Finishing Gypsum Board 2017 (Reapproved 2022).
- G. ASTM C754 - Standard Specification for Installation of Steel Framing Members to Receive Screw-Attached Gypsum Panel Products 2020.
- H. ASTM C840 - Standard Specification for Application and Finishing of Gypsum Board 2020.
- I. ASTM C954 - Standard Specification for Steel Drill Screws for the Application of Gypsum Panel Products or Metal Plaster Bases to Steel Studs from 0.033 in. (0.84 mm) to 0.112 in. (2.84 mm) in Thickness 2022.
- J. ASTM C1002 - Standard Specification for Steel Self-Piercing Tapping Screws for Application of Gypsum Panel Products or Metal Plaster Bases to Wood Studs or Steel Studs 2022.
- K. ASTM C1047 - Standard Specification for Accessories for Gypsum Wallboard and Gypsum Veneer Base 2019.
- L. ASTM C1629/C1629M - Standard Classification for Abuse-Resistant Nondecorated Interior Gypsum Panel Products and Fiber-Reinforced Cement Panels 2019.
- M. ASTM D3273 - Standard Test Method for Resistance to Growth of Mold on the Surface of Interior Coatings in an Environmental Chamber 2021.
- N. GA-216 - Application and Finishing of Gypsum Panel Products 2021.

**1.4 ADMINISTRATIVE REQUIREMENTS**

- A. Coordination: Coordinate the installation of gypsum board assemblies with size, location, and installation of service utilities.
  - B. Preinstallation Meeting: Conduct a preinstallation meeting one week prior to the start of the work of this section; require attendance by all affected installers.
  - C. Sequencing: Install service utilities in an orderly and expeditious manner.
-

**1.5 SUBMITTALS**

- A. See Section 01 30 00 - Administrative Requirements for submittal procedures.
- B. Product Data:
  - 1. Provide data on metal framing, gypsum board, accessories, and joint finishing system.

**1.6 QUALITY ASSURANCE**

- A. Manufacturer Qualifications: Member of Steel Stud Manufacturers Association (SSMA): [www.ssma.com/#sle](http://www.ssma.com/#sle).
- B. Installer Qualifications: Company specializing in performing work of the type specified and with at least three years of documented experience.

**1.7 DELIVERY, STORAGE, AND HANDLING**

- A. Store gypsum products and accessories indoors and keep above freezing. Elevate boards above floor, on nonwicking supports, in accordance with manufacturer's recommendations.

**PART 2 PRODUCTS****2.1 GYPSUM BOARD ASSEMBLIES**

- A. Provide completed assemblies complying with ASTM C840 and GA-216.
- B. Seismic Performance: Ceiling systems designed to withstand the effects of earthquake motions in accordance with ASCE 7 for Seismic Design Category D, E, or F and complying with the following:
  - 1. Local authorities having jurisdiction.

**2.2 METAL FRAMING MATERIALS**

- A. Material and Product Requirements Criteria: AISI S201.
- B. Steel Sheet: ASTM A1003/A1003M, subject to the ductility limitations indicated in AISI S240.
  - 1. Structural Grade: As required to meet design criteria.
  - 2. Corrosion Protection Coating Designation: G40 in accordance with AISI S220.
- C. Manufacturers - Metal Framing, Connectors, and Accessories:
  - 1. ClarkDietrich: [www.clarkdietrich.com/#sle](http://www.clarkdietrich.com/#sle).
  - 2. Jaimes Industries: [www.jaimesind.com/#sle](http://www.jaimesind.com/#sle).
  - 3. MarinoWARE: [www.marinoware.com/#sle](http://www.marinoware.com/#sle).
  - 4. Phillips Manufacturing Co: [www.phillipsmfg.com/#sle](http://www.phillipsmfg.com/#sle).
- D. Nonstructural Framing System Components: AISI S220; galvanized sheet steel, of size and properties necessary to comply with ASTM C754 for the spacing indicated, with maximum deflection of wall framing of L/120 at 5 psf.
  - 1. Studs: C-shaped with knurled or embossed faces.
  - 2. Runners: U shaped, sized to match studs.
  - 3. Ceiling Channels: C-shaped.

**2.3 BOARD MATERIALS**

- A. Manufacturers - Gypsum-Based Board:
  - 1. Continental Building Products: [www.continental-bp.com/#sle](http://www.continental-bp.com/#sle).
  - 2. Georgia-Pacific Gypsum: [www.gpgypsum.com/#sle](http://www.gpgypsum.com/#sle).
  - 3. National Gypsum Company: [www.nationalgypsum.com/#sle](http://www.nationalgypsum.com/#sle).

4. USG Corporation: [www.usg.com/#sle](http://www.usg.com/#sle).
- B. Abuse Resistant Wallboard:
  1. Application: Security ceilings where indicated on drawings.
  2. Surface Abrasion: Level 3, minimum, when tested in accordance with ASTM C1629/C1629M.
  3. Indentation: Level 1, minimum, when tested in accordance with ASTM C1629/C1629M.
  4. Soft Body Impact: Level 2, minimum, when tested in accordance with ASTM C1629/C1629M.
  5. Mold Resistance: Score of 10, when tested in accordance with ASTM D3273.
  6. Paper-Faced Type: Gypsum wallboard, as defined in ASTM C1396/C1396M.
  7. Type: Fire-resistance-rated Type X, UL or WH listed.
  8. Thickness: 5/8 inch.
  9. Edges: Tapered.
  10. Paper-Faced Products:
    - a. Continental Building Products: [www.continental-bp.com/#sle](http://www.continental-bp.com/#sle).
    - b. Georgia-Pacific Gypsum: [www.gpgypsum.com/#sle](http://www.gpgypsum.com/#sle).
    - c. National Gypsum Company: [www.nationalgypsum.com/#sle](http://www.nationalgypsum.com/#sle).
    - d. USG Corporation: [www.usg.com/#sle](http://www.usg.com/#sle).

## **2.4 GYPSUM BOARD ACCESSORIES**

- A. Finishing Accessories: ASTM C1047, extruded aluminum alloy (6063 T5) or galvanized steel sheet ASTM A924/A924M G90, unless noted otherwise.
  1. Types: As detailed or required for finished appearance.
  2. Products:
    - a. Same manufacturer as framing materials.
- B. Joint Materials: ASTM C475/C475M and as recommended by gypsum board manufacturer for project conditions.
  1. Fiberglass Tape: 2 inch wide, coated glass fiber tape for joints and corners.
  2. Joint Compound: Setting type, field-mixed.
- C. Screws for Fastening of Gypsum Panel Products to Cold-Formed Steel Studs Less than 0.033 inches in Thickness and Wood Members: ASTM C1002; self-piercing tapping screws, corrosion-resistant.
- D. Screws for Fastening of Gypsum Panel Products to Steel Members from 0.033 to 0.112 inch in Thickness: ASTM C954; steel drill screws, corrosion-resistant.

## **PART 3 EXECUTION**

### **3.1 EXAMINATION**

- A. Verify that project conditions are appropriate for work of this section to commence.

### **3.2 FRAMING INSTALLATION**

- A. Metal Framing: Install in accordance with AISI S220 and manufacturer's instructions.
- B. Ceilings and Soffits: Space framing and furring members as required for spans and applicable load.
  1. Level ceiling system to a tolerance of 1/1200.
  2. Laterally brace entire suspension system.
- C. Openings: Reinforce openings as required.

### **3.3 BOARD INSTALLATION**

---

- A. Comply with ASTM C840, GA-216, and manufacturer's instructions. Install to minimize butt end joints, especially in highly visible locations.
- B. Installation on Metal Framing: Use screws for attachment of gypsum board.

### **3.4 INSTALLATION OF TRIM AND ACCESSORIES**

- A. Control Joints: Place control joints consistent with lines of building spaces and as indicated.
  - 1. Not more than 30 feet apart on walls and ceilings over 50 feet long.
- B. Edge Trim: Install at locations where gypsum board abuts dissimilar materials.

### **3.5 JOINT TREATMENT**

- A. Finish gypsum board in accordance with levels defined in ASTM C840, as follows:
  - 1. Level 4: Walls and ceilings to receive paint finish or wall coverings, unless otherwise indicated.
- B. Tape, fill, and sand exposed joints, edges, and corners to produce smooth surface ready to receive finishes.
  - 1. Feather coats of joint compound so that camber is maximum 1/32 inch.

### **3.6 TOLERANCES**

- A. Maximum Variation of Finished Gypsum Board Surface from True Flatness: 1/8 inch in 10 feet in any direction.

**END OF SECTION 09 21 16**