

---

**SECTION 09 67 23**  
**– RESINOUS FLOORING****PART 1 GENERAL****1.1 SUMMARY**

- A. This Section includes:
  - 1. High-performance resinous flooring systems.

**1.2 SUBMITTALS**

- A. Product Data: For each type of product indicated.
- B. Installer Certificates for Qualification: Signed by manufacturer stating that installers comply with specified requirements.
- C. Material Certificates: For each resinous flooring component, from manufacturer.
- D. Maintenance Data: For maintenance manuals.
- E. Samples: Submit two 6" X 6" samples of each resinous flooring system applied to a rigid backing. Provide sample which is a true representation of proposed field applied finish. Provide sample color and texture for approval from Owner in writing or approved by General Contractor prior to installation.
- F. Product Schedule: For resinous flooring.

**1.3 QUALITY ASSURANCE**

- A. Installer Qualifications: Manufacturer's authorized representative who is trained and approved for installation of flooring systems required for this Project.
  - 1. Engage an installer who is approved in writing by resinous flooring manufacturer as qualified to apply resinous flooring systems indicated.
  - 2. Installer Letter of Qualification: Installer to provide letter stating that they have been in business for at least 5 years and listing 5 projects in the last 2 years of similar scope. For each project provide: project name, location, date of installation, contact information, size of project, and manufacturer of materials with system information.
- B. Source Limitations: Obtain primary resinous flooring materials, including primers, resins, hardening agents, grouting coats, and topcoats, from single source from single manufacturer. Provide secondary materials, including patching and fill material, joint sealant, and repair materials, of type and from source recommended by manufacturer of primary materials.
- C. Pre-installation Conference: Conduct conference at Project site before work and mockups begin.
- D. Mock-ups: Apply mockups to verify selections made under sample submittals and to demonstrate aesthetic effects and set quality standards for materials and execution. Do not cover up mockup area.
  - 1. Apply full-thickness mockups on 16 square foot floor area selected by Architect.
  - 2. Finish surfaces for verification of products, color, texture, and sheen.
  - 3. Simulate finished lighting conditions for Architect's review of mock-ups.
  - 4. Approved mock-ups may become part of the completed Work if undisturbed at time of Substantial Completion.
  - 5. Mock-up shall demonstrate desired slip resistance for review and approval by Owner's representative in writing.

**1.4 DELIVERY, STORAGE, AND HANDLING**

- A. Deliver materials in original packages and containers, with seals unbroken, bearing manufacturer's labels indicating brand name and directions for storage and mixing with other components.
  - 1. Maintain containers in clean condition, free of foreign materials and residue.
  - 2. Remove rags and waste from storage areas daily.

### **1.5 PROJECT CONDITIONS**

- A. Environmental Limitations: Comply with resinous flooring manufacturer's written instructions for substrate temperature, ambient temperature, moisture, ventilation, and other conditions affecting resinous flooring application.
- B. Lighting: Provide permanent lighting or, if permanent lighting is not in place, simulate permanent lighting conditions during resinous flooring application.
- C. Close spaces to traffic during resinous flooring application and for not less than 24 hours after application unless manufacturer recommends a longer period.

## **PART 2 PRODUCTS**

### **2.1 MANUFACTURERS**

- A. Manufacturers: Subject to compliance with requirements, provide products by:
  - 1. The Sherwin Williams Company, Cleveland, OH. swflooring@sherwin.com
- B. Resuflor Deco Quartz BC23, 1/8" nominal thickness.
  - 1. Primer: Resuprime 3579 at 250 sq. ft. per gallon.
  - 2. 1st Receiver Coat: Resuflor 3561 at 140-145 sq. ft. per gallon
  - 3. 1st Broadcast: GP5900F to excess at 0.4 lbs. per sq. ft.
  - 4. 2nd Receiver Coat: Resuflor 3561 at 65-70 sq. ft. per gallon
  - 5. 2nd Broadcast: GP5900F to excess at 0.4 lbs. per sq. ft.
  - 6. Grout Coat: Resuflor 3746 at 100 sq. ft. per gallon.
  - 7. Topcoat: Resuflor 3746 at 200 sq. ft. per gallon.

### **2.2 MATERIALS**

- A. VOC Content of Resinous Flooring: Provide resinous flooring systems, for use inside the weatherproofing system, that comply with the following limits for VOC content when calculated according to 40 CFR 59, Subpart D (EPA Method 24)].
  - 1. Resinous Flooring: 100 g/L.

### **2.3 HIGH-PERFORMANCE RESINOUS FLOORING**

- A. Resinous Flooring: Abrasion-, impact- and chemical-resistant, high-performance, resin-based, monolithic floor surfacing designed to produce a seamless floor.
- B. System Characteristics:
  - 1. Color and Pattern: As selected by Architect from manufacturer's full standard color line.
  - 2. Sheen: As selected by Architect from manufacturer's standard sheen levels.
  - 3. Slip Resistance: Provide slip resistant finish.

## **PART 3 EXECUTION**

### **3.1 PREPARATION**

- A. Inspection: Prior to commencing Work, thoroughly examine all underlying and adjoining work, surfaces and conditions upon which Work is in any way dependent for perfect results. Report all conditions

which affect Work. No "waiver of responsibility" for incomplete, inadequate or defective underlaying and adjoining work, surfaces and conditions will be considered, unless notice of such unsatisfactory conditions has been filed and agreed to in writing before Work begins. Commencement of Work constitutes acceptance of surfaces.

- B. Surface Preparation: Remove all surface contamination, loose or weakly adherent particles, laitance, grease, oil, curing compounds, paint, dust and debris by blast track method or approved mechanical means (acid etch not allowed). If surface is questionable, try a test patch. Create a minimum surface profile for the system specified in accordance with the methods described in ICRI No. 03732 to achieve profile numbers as follows:
  - 1. CSP-4 to CSP-6
- C. Verify that concrete substrates are dry and moisture-vapor emissions are within acceptable levels according to manufacturer's written instructions.
  - 1. Moisture Testing: Perform tests indicated below.
    - a. Calcium Chloride Test: Perform anhydrous calcium chloride test per ASTM F 1869. Proceed with installation only after substrates have maximum moisture-vapor-emission rate of 3 lbs. of water/1000 sq. ft. in 24 hours. Perform tests so that each test area does not exceed 1000 sq. ft. and perform 3 tests for the first 1000 sq. ft. and one additional test for every additional 1000 sq ft.
    - b. In-Situ Probe Test: Perform relative-humidity test using in-situ probes per ASTM F 2170. Proceed with installation only after substrates have a maximum 75 percent relative-humidity-level measurement.
  - 2. Resil flooring contractor shall provide products and methods recommended by resilient flooring manufacturer and adhesive materials manufacturer if moisture and alkalinity test results are not within limits recommended by resilient flooring manufacturer and adhesive materials manufacturer.

### **3.2 ENVIRONMENTAL CONDITIONS**

- A. All applicators and all other personnel in the area of the RF installation shall take all required and necessary safety precautions. All manufacturers' installation instructions shall be implicitly followed.
- B. Repair damaged and deteriorated concrete according to resinous flooring manufacturer's written instructions.
- C. Alkalinity and Adhesion Testing: Verify that concrete substrates have pH within acceptable range. Perform tests recommended by manufacturer. Proceed with application only after substrates pass testing.
- D. Resinous Materials: Mix components and prepare materials according to resinous flooring manufacturer's written instructions.
- E. Use patching and fill material to fill holes and depressions in substrates according to manufacturer's written instructions.
- F. Treat control joints and other nonmoving substrate cracks to prevent cracks from reflecting through resinous flooring according to manufacturer's written instructions.

### **3.3 APPLICATIONS**

- A. Install resinous floor over properly prepared concrete surface in strict accordance with the manufacturer's directions.

- 
1. Install the primer and/or base coats over thoroughly cleaned and prepared concrete.
  2. Install topcoat over flooring after excess aggregate has been removed.
  3. Maintain a slab temperature of 60°F to 80°F for 24 hours minimum before applying floor topping, or as instructed by manufacturer.
- B. Apply components of resinous flooring system according to manufacturer's written instructions to produce a uniform, monolithic wearing surface of thickness indicated.
1. Coordinate application of components to provide optimum adhesion of resinous flooring system to substrate, and optimum intercoat adhesion.
  2. Cure resinous flooring components according to manufacturer's written instructions. Prevent contamination during application and curing processes.
  3. At substrate expansion and isolation joints, comply with resinous flooring manufacturer's written instructions.
- C. Sealant: Saw cut resinous floor topping at expansion joints in concrete slab. Fill sawcuts with sealant prior to final seal coat application. Follow manufacturer's written recommendations.
- D. Apply primer over prepared substrate at manufacturer's recommended spreading rate.
- E. Slip Resistant Finish: Provide grit for slip resistance.
- F. Apply topcoats in number indicated for flooring system and at spreading rates recommended in writing by manufacturer.

### **3.4 COMPLETED WORK**

- A. Cleaning: Upon completion of the Work, clean up and remove from the premises surplus materials, tools, appliances, empty cans, cartons and rubbish resulting from the Work. Clean off all spattering and drippings, and all resulting stains.
- B. Protection: Protect Work in accordance with manufacturer's directions from damage and wear during the remainder of the construction period. Use protective methods and materials, including temporary covering, recommended in writing by resinous flooring manufacturer.
- C. Contractor shall insure that coating is protected from any traffic until it is fully cured to the satisfaction of the coating manufacturer.

**END OF SECTION 09 67 23**