

---

**SECTION 10 44 00**  
**FIRE PROTECTION SPECIALTIES**

**PART 1 GENERAL**

**1.1 SECTION INCLUDES**

- A. Fire extinguishers.
- B. Fire extinguisher cabinets.
- C. Accessories.

**1.2 RELATED REQUIREMENTS**

- A. Section 04 20 00 - Unit Masonry: Roughed-in wall openings.

**1.3 REFERENCE STANDARDS**

- A. ASTM E814 - Standard Test Method for Fire Tests of Penetration Firestop Systems 2013a (Reapproved 2017).
- B. FM (AG) - FM Approval Guide Current Edition.
- C. NFPA 10 - Standard for Portable Fire Extinguishers 2022.
- D. UL (DIR) - Online Certifications Directory Current Edition.

**1.4 SUBMITTALS**

- A. See Section 01 30 00 - Administrative Requirements, for submittal procedures.
- B. Product Data: Provide extinguisher operational features.
- C. Shop Drawings: Indicate locations of cabinets and cabinet physical dimensions.
- D. Manufacturer's Installation Instructions: Indicate special criteria and wall opening coordination requirements.
- E. Manufacturer's Certificate: Certify that products meet or exceed specified requirements.
- F. Maintenance Data: Include test, refill or recharge schedules and re-certification requirements.

**1.5 FIELD CONDITIONS**

- A. Do not install extinguishers when ambient temperature may cause freezing of extinguisher ingredients.

**PART 2 PRODUCTS**

**2.1 MANUFACTURERS**

- A. Fire Extinguishers:
  - 1. Kidde, a unit of United Technologies Corp: [www.kidde.com](http://www.kidde.com).
  - 2. Larsen's Manufacturing Co: [www.larsensmfg.com](http://www.larsensmfg.com).
  - 3. Potter-Roemer: [www.potterroemer.com/#sle](http://www.potterroemer.com/#sle).

**2.2 FIRE EXTINGUISHERS**

- A. Fire Extinguishers - General: Comply with product requirements of NFPA 10 and applicable codes, whichever is more stringent.
- B. Multipurpose Dry Chemical Type Fire Extinguishers: Carbon steel tank, with pressure gauge.
  - 1. Cartridge Operated: Spun shell.
  - 2. Class: A:B:C type.
  - 3. Size: 5 pound.

4. Finish: Baked polyester powder coat, red color.
5. Temperature range: Minus 65 degrees F to 120 degrees F.

### **2.3 FIRE EXTINGUISHER CABINETS**

- A. Fire Rating: Listed and labeled in accordance with ASTM E814 requirements for fire resistance rating of walls where being installed.
- B. Cabinet Construction: Non-fire rated.
- C. Fire Rated Cabinet Construction: One-hour fire rated.
  1. Steel; double wall or outer and inner boxes with 5/8 inch thick fire barrier material.
- D. Cabinet Configuration: Recessed type.
  1. Size to accommodate accessories.
  2. Trim: Flat square edge, with 1-1/2 inch wide face.
- E. Door: 0.036 inch metal thickness, reinforced for flatness and rigidity with nylon catch. Hinge doors for 180 degree opening with two butt hinge.
- F. Door Glazing: Acrylic plastic, clear, 1/8 inch thick, flat shape and set in resilient channel glazing gasket.
- G. Cabinet Mounting Hardware: Appropriate to cabinet, with pre-drilled holes for placement of anchors.
- H. Weld, fill, and grind components smooth.
- I. Finish of Cabinet Exterior Trim and Door: No. 4 - Brushed stainless steel.
- J. Finish of Cabinet Interior: White colored enamel.

### **2.4 ACCESSORIES**

- A. Extinguisher Brackets: Formed steel, chrome-plated.
- B. Cabinet Signage: Provide signage as required by applicable codes.
- C. Lettering: "FIRE EXTINGUISHER" decal, or vinyl self-adhering, pre-spaced black lettering as required by and in accordance with authorities having jurisdiction (AHJ).

## **PART 3 EXECUTION**

### **3.1 EXAMINATION**

- A. Verify existing conditions before starting work.
- B. Verify rough openings for cabinet are correctly sized and located.

### **3.2 INSTALLATION**

- A. Install in accordance with manufacturer's instructions.

### **3.3 MAINTENANCE**

- A. See Section 01 70 00 - Execution and Closeout Requirements, for additional requirements relating to maintenance service.

**END OF SECTION 10 44 00**