

---

**SECTION 08 33 26**  
**OVERHEAD COILING GRILLES**

**PART 1 GENERAL**

**1.1 SECTION INCLUDES**

- A. Overhead coiling metal grilles and operating hardware; electrically or manually operated.
- B. Wiring from electric circuit disconnect to operator and to control station.

**1.2 RELATED REQUIREMENTS**

- A. Section 05 12 00 - Structural Steel Framing: Support framing.
- B. Section 26 05 33.13 - Conduit for Electrical Systems: Conduit from electric circuit to operator and from operator to control station.
- C. Section 26 05 83 - Wiring Connections: Power to disconnect.
- D. Section 28 10 00 - Access Control: Electronic access.

**1.3 REFERENCE STANDARDS**

- A. ASTM A653/A653M - Standard Specification for Steel Sheet, Zinc-Coated (Galvanized) or Zinc-Iron Alloy-Coated (Galvannealed) by the Hot-Dip Process 2022.
- B. ASTM A 924 - Standard Specification for General Requirements for Steel Sheet, Metallic-Coated by the Hot-Dip Process.
- C. ASTM A666 - Standard Specification for Annealed or Cold-Worked Austenitic Stainless Steel Sheet, Strip, Plate, and Flat Bar 2015.
- D. ASTM B221 - Standard Specification for Aluminum and Aluminum-Alloy Extruded Bars, Rods, Wire, Profiles, and Tubes 2021.
- E. ITS (DIR) - Directory of Listed Products Current Edition.
- F. NEMA 250 - Enclosures for Electrical Equipment (1000 Volts Maximum) 2020.
- G. NEMA ICS 2 - Industrial Control and Systems Controllers, Contactors and Overload Relays Rated 600 Volts 2008 (Reaffirmed 2020).
- H. NEMA MG 1 - Motors and Generators 2021.
- I. NFPA 70 - National Electrical Code Most Recent Edition Adopted by Authority Having Jurisdiction, Including All Applicable Amendments and Supplements.

**1.4 SUBMITTALS**

- A. See Section 01 30 00 - Administrative Requirements, for submittal procedures.
- B. Product Data: Provide general construction component connections and details, and electrical equipment.
- C. Shop Drawings: Indicate pertinent dimensioning, anchorage methods, hardware locations, and installation details.
- D. Manufacturer's Installation Instructions: Indicate installation sequences and procedures, adjustment and alignment procedures.
- E. Manufacturer's Qualification Statement.
- F. Maintenance Data: Indicate lubrication requirements and frequency and periodic adjustments required.

**1.5 QUALITY ASSURANCE**

- 
- A. Manufacturer Qualifications: Company specializing in manufacturing the products specified in this section with minimum five years of documented experience.
  - B. Installer Qualifications: Company specializing in performing work of type specified and with at least five years documented experience.
  - C. Products Requiring Electrical Connection: Listed and classified by ITS (DIR), UL (DIR), or testing firm acceptable to authorities having jurisdiction as suitable for purpose specified.

#### **1.6 WARRANTY**

- A. See Section 01 78 00 - Closeout Submittals for warranty requirements.
- B. Correct defective Work within a one year period after Date of Substantial Completion.
- C. Warranty: Include coverage for electric motor and transmission.
- D. Provide five year manufacturer warranty for electric operating equipment.

### **PART 2 PRODUCTS**

#### **2.1 MANUFACTURERS**

- A. Basis of Design Overhead Coiling Grilles: Overhead Door Corporation Model No. 671; [www.overhaddoor.com](http://www.overhaddoor.com) or comparable products meeting project requirements by one of the following:
  - 1. Cornell Iron Works, Inc: [www.cornelliron.com/#sle](http://www.cornelliron.com/#sle).
  - 2. The Cookson Company: [www.cooksondoor.com/#sle](http://www.cooksondoor.com/#sle).

#### **2.2 GRILLES AND COMPONENTS**

- A. Grille: Galvanized steel; horizontal bar curtain, coiling on overhead counterbalanced shaft.
  - 1. Finish: Galvanized.
  - 2. Electric operation.
  - 3. Mounting: Face of wall mounted.
- B. Curtain: Round horizontal bars connected with vertical links.
  - 1. Horizontal bars: 5/16 inch diameter.
  - 2. Bar spacing: 1-1/2 inch on center.
  - 3. Grille pattern: Brick pattern.
  - 4. Horizontal link spacing: 4-1/2 inch on center.
  - 5. Bar Ends: Provide with nylon runners for quiet operation.
  - 6. Bottom Bar: Back-to-back angles with tubular resilient cushion.
- C. Steel Tube Jamb: Galvanized, 3 inch x 3 inch x 3/16 inch HHS.
- D. Guides: Extruded aluminum angles, of profile to retain grille in place with snap-on trim, mounting brackets of same metal.
- E. Hood Enclosure and Trim: Sheet metal; completely covering operating mechanisms; internally reinforced to maintain rigidity and shape.
  - 1. Material: Same metal as grille.
  - 2. Sheet Metal Thickness: 24 gauge, 0.0276 inch.
  - 3. Finish: Galvanized.
- F. Roller Shaft Counterbalance: Steel pipe and helical steel spring system, capable of producing torque sufficient to ensure smooth operation of curtain from any position and capable of holding position at mid-travel; with adjustable spring tension; requiring 25 lb nominal force to operate.

---

**2.3 MATERIALS**

- A. Aluminum: ASTM B221 (ASTM B221M).
- B. Galvanized Steel Bars: Galvanized to minimum coating thickness grade in accordance with ASTM A123/A123M.
- C. Galvanized Steel Sheet: ASTM A653/A653M, galvanized to minimum G90/Z275 coating.
- D. Stainless Steel: ASTM A666 Type 304, with rollable temper.

**2.4 ELECTRIC OPERATION**

- A. Operator, Controls, Actuators, and Safeties: Comply with UL 325; provide products listed by ITS (DIR), UL (DIR), or testing agency acceptable to authorities having jurisdiction.
  - 1. Provide interlock switches on motor operated units.
- B. Electric Operators:
  - 1. Operator: To be supplied by door manufacturer, Basis of Design Model J (jackshaft) RHX Commercial Heavy Duty Door Operator by LiftMaster.
  - 2. Mounting: Side mounted, front of hood. Location of motor shall be coordinated with all contractors. Contractor to field verify clearance required for mounting specified prior to ordering.
  - 3. Motor Enclosure:
    - a. Interior Coiling Grilles: NEMA MG 1, Type 1; open drip proof.
  - 4. Motor Rating: 1/2 hp; continuous duty.
  - 5. Motor Voltage: 208 volts, three phase, 60 Hz.
  - 6. Motor Controller: NEMA ICS 2, full voltage, reversing magnetic motor starter.
  - 7. Controller Enclosure: NEMA 250 Type 1.
  - 8. Opening Speed: 12 inches per second.
  - 9. Brake: Adjustable friction clutch type, activated by motor controller.
  - 10. Manual override in case of power failure.
  - 11. Emergency Egress: Provide code compliant emergency egress system that automatically unlocks and manually releases grille part way to permit passage, even if power is not available.
  - 12. Refer to Section 26 05 83 for electrical connections.
- C. Wiring Terminations: Provide terminal lugs to match branch circuit conductor quantities, sizes, and materials indicated; enclose terminal lugs in terminal box sized to comply with NFPA 70.
- D. Control Station: Provide standard three button (Open-Close-Stop) momentary-contact control device for each operator complying with UL 325.
  - 1. 24 volt circuit.
  - 2. Surface mounted, at interior door jamb.
  - 3. Entrapment Protection Devices: Provide sensing devices and safety mechanisms complying with UL 325.
    - a. Primary Device: Provide electric sensing edge as required with momentary-contact control device.
- E. Safety Edge: Located at bottom of coiling grill, full width, electro-mechanical sensitized type, wired to stop and reverse grill direction upon striking object, hollow neoprene covered.
- F. Provide interconnection to security system.
- G. Coordination: Provide materials required for and coordination with respective contractors for electronic access control of coiling grille.

---

**PART 3 EXECUTION**

**3.1 EXAMINATION**

- A. Verify that opening sizes, tolerances and conditions are acceptable.

**3.2 INSTALLATION**

- A. Install grille unit assembly in accordance with manufacturer's instructions.
- B. Use anchorage devices to securely fasten assembly to wall construction and building framing without distortion or stress.
- C. Securely and rigidly brace components suspended from structure. Secure guides to structural members only.
- D. Fit and align assembly including hardware; level and plumb, to provide smooth operation.
- E. Coordinate installation of electrical service with Section 26 05 83.
- F. Complete wiring from disconnect to unit components.
- G. Install enclosure and perimeter trim.

**3.3 TOLERANCES**

- A. Maintain dimensional tolerances and alignment with adjacent work.
- B. Maximum Variation From Plumb: 1/16 inch.
- C. Maximum Variation From Level: 1/16 inch.
- D. Longitudinal or Diagonal Warp: Plus or minus 1/8 inch per 10 ft straight edge.

**3.4 ADJUSTING**

- A. Adjust grille, hardware and operating assemblies for smooth and noiseless operation.

**3.5 CLEANING**

- A. Clean grille and components.
- B. Remove labels and visible markings.

**END OF SECTION 08 33 26**