

ELECTRICAL LEGEND

(REFER TO SPECIFICATIONS FOR MORE INFORMATION)
NOTE: DIMENSIONS ARE TO CENTER OF DEVICE, UNO.

LIGHTING FIXTURES

(REFER TO LIGHTING FIXTURE SCHEDULE FOR DESCRIPTION AND TYPE)

SYMBOL	DESCRIPTION
	- LED LIGHTING FIXTURE.
	- LIGHTING FIXTURE - NORMAL AND EMERGENCY POWER.
	- LIGHTING FIXTURE - EMERGENCY POWER ONLY.
	- INCANDESCENT, FLUORESCENT, H.I.D. OR LED LIGHTING FIXTURE.
	- WALL MOUNTED LIGHTING FIXTURE.
	- EXIT LIGHTING FIXTURE - NORMAL AND EMERGENCY POWER - ARROW(S) INDICATE DIRECTIONAL MARKERS.
	- LIGHTING FIXTURE - WALL WASH.
	- EMERGENCY BATTERY UNIT WITH 2 LAMPS.
	- TRACK LIGHTING - LENGTH OF TRACK AND NUMBER OF HEADS AS INDICATED ON DRAWINGS.
	- FLOOD LIGHT. AIM LIGHT AT NIGHT. COORDINATE TIME WITH ARCHITECT/OWNER/ENGINEER.
	- POLE MOUNTED LIGHT FIXTURE.
	- BOLLARD TYPE LIGHT FIXTURE.

SWITCHES

SYMBOL	DESCRIPTION
S	- SINGLE POLE SWITCH - 20 AMP - MOUNT 46" AFF.
S2	- 2 POLE SINGLE THROW SWITCH - 20 AMP - MOUNT 46" AFF.
S3	- THREE WAY LIGHT SWITCH - 20 AMP - MOUNT 46" AFF.
S4	- FOUR WAY LIGHT SWITCH - 20 AMP - MOUNT 46" AFF.
Sk	- KEY OPERATED LIGHT SWITCH - 20 AMP - SIMILAR TO LEVITON MODEL #1221-2KL - MOUNT 46" AFF.
Sk3	- THREE WAY KEY OPERATED LIGHT SWITCH - 20 AMP - SIMILAR TO LEVITON MODEL #1223-2KL - MOUNT 46" AFF.
SLs,SLs	- SUB-LETTER DESIGNATION INDICATES THE LIGHTING TO BE CONTROLLED BY EACH SWITCH WITHIN THE ROOM/AREA.
Sw	- MOTION SENSING LIGHT SWITCH - MOUNT 46" AFF.
Sp	- LIGHT SWITCH WITH PILOT LIGHT - 20 AMP - SIMILAR TO P&S PS20AC2-RPL SERIES - MOUNT 46" AFF.
Sw	- TIMER SWITCH - SIMILAR TO TORK MODEL #SSA100, UNO - MOUNT 46" AFF.
SLH	- LIGHTED HANDLE LIGHT SWITCH - 20 AMP - MOUNT 46" AFF.
SLs	- RAISE/LOWER SWITCH - U.N.O. FURNISHED BY OTHERS. INSTALL AND PROVIDE FINAL CONNECTIONS PER MANUFACTURER REQUIREMENTS.
SLv	- LOW VOLTAGE SWITCH STATION CONNECTED TO LIGHTING CONTROL SYSTEM. PROVIDE SINGLE BUTTON STATION, UNO - MOUNT 46" AFF.
SLw	- WEATHERPROOF LIGHT SWITCH - PROVIDE PASS & SEYMOUR CAT. #CATLG CAST WEATHERPROOF COVER OVER THREE-WAY TOGGLE SWITCH. MOUNT 46" AFF.
SLD	- TIME DELAY SWITCH - FURNISHED BY OTHERS. INSTALL AND PROVIDE FINAL CONNECTIONS PER MANUFACTURER REQUIREMENTS - MOUNT 46" AFF.
SLs,SLs	- DIMMER LIGHT SWITCH - TYPE & SIZED FOR LOAD SERVED - PROVIDE COMPATIBLE 0-10V DIMMER SWITCH WITH POWER PACK. ARCHITECT TO SELECT FINISH FROM FULL LIST OF MANUFACTURER STANDARD COLORS - MOUNT 46" AFF.
SLs	- LOW VOLTAGE DIMMER STATION CONNECTED TO LIGHTING CONTROL SYSTEM. PROVIDE 3-BUTTON STATION WITH ON/OFF AND RAISE/LOWER BUTTONS. - MOUNT 46" AFF.
SLx	- LOW VOLTAGE ON/OFF OVERRIDE SWITCH CONNECTED TO LIGHTING CONTROL SYSTEM TO CONTROL CORRIDOR LIGHTS. PROVIDE KEY OPERATED LIGHT SWITCH UNO - MOUNT 46" AFF.
SLoss	- OCCUPANCY SENSING SINGLE POLE DIMMER LIGHT SWITCH - SIMILAR TO LUTRON MAESTRO MODEL #MSCL-OP153M-XX. ARCHITECT TO SELECT FINISH FROM FULL LIST OF MANUFACTURER STANDARD COLORS - MOUNT 46" AFF.
SLos	- OCCUPANCY SENSING WALL SWITCH - SEE SPECIFICATIONS - MOUNT 46" AFF.
SLS,H	- LOW VOLTAGE CEILING/WALL MOUNTED OCCUPANCY SENSING UNIT POWERED FROM LIGHTING CONTROL SYSTEM - SEE SPECIFICATIONS. VERIFY LOCATION OF SENSOR WITH MANUFACTURER PRIOR TO INSTALLATION.
SLA	- LIGHTING CONTROL SYSTEM DAYLIGHT SENSOR TO BE WIRED INTO LIGHTING CONTROL SYSTEM PER MANUFACTURER'S REQUIREMENTS. ATTACH TO CEILING OR WALL WITH THE USE OF A THREADED NUT. SENSOR MAY BE INSTALLED TO PENDANT AS REQUIRED FOR PROPER OPERATION. VERIFY LOCATION OF SENSOR WITH MANUFACTURER PRIOR TO INSTALLATION.

RECEPTACLES

SYMBOL	DESCRIPTION
	- DUPLEX RECEPTACLE - 20 AMP, 120 VOLT, 18" AFF.
EW	- ELECTRIC WATER COOLER RECEPTACLE - TYPE PER MANUFACTURER'S RECOMMENDATIONS - COORDINATE HEIGHT WITH EWC.
GF	- GROUND FAULT RECEPTACLE - INDIVIDUAL TYPE - 18" ABOVE FINISHED FLOOR.
W	- DUPLEX RECEPTACLE (WITH "W" LABEL) WITH WEATHERPROOF "WHILE-IN-USE" COVER - FLUSH IN NEW WALL CONSTRUCTION, SURFACE ON EXISTING WALL CONSTRUCTION - 18" AFF UNO.
U	- TAMPER-RESISTANT DUPLEX RECEPTACLE WITH (2) 5-VOLT DC USB PORTS - 20 AMP, 120 VOLT, 18" AFF UNO. PROVIDE SIMILAR TO P&S TR5362USB SERIES.
SH	- SHUTTERED DUPLEX RECEPTACLE - 20 AMP, 120 VOLT, 18" AFF UNO. PROVIDE SIMILAR TO P&S TR63H SERIES.
	- QUAD OUTLET - 120V - 20 AMP EACH - TWO DUPLEX TOGETHER WITH ONE COVER PLATE - 18" AFF.
	- DUPLEX RECEPTACLE WITH CAST OUTLET BOX ON STAND PIPE 3" AFF.
	- SPECIAL OUTLET - SIZE AND TYPE INDICATED - 18" AFF UNO.
	- PLUGMOLD WITH RECEPTACLES 12" OC IVORY (VERIFY MOUNTING HEIGHT) WIREMOLD V24GBA SERIES OR EQUAL BY HUBBELL (2-CIRCUIT).
	- PLUGMOLD WITH RECEPTACLES 18"OC IVORY (VERIFY MOUNTING HEIGHT) WIREMOLD V24GBA SERIES OR EQUAL BY HUBBELL (2-CIRCUIT).
C	- DUPLEX RECEPTACLE - 20 AMP, 120 VOLT - ("C" INDICATES MOUNTED ABOVE COUNTER OR HEIGHT ABOVE BACKSPLASH. COORDINATE EXACT LOCATION WITH ARCHITECT AND CASEWORK DRAWINGS.)
	- NORMAL/EMERGENCY DUPLEX RECEPTACLE - 20 AMP, 120 VOLT, 18" AFF UNO. PROVIDE RED COLOR WIRING DEVICE AND COVER PLATE.
	- EXISTING FLUSH FLOOR OUTLET, THOMAS & BETTS 665 SERIES UNLESS NOTED OTHERWISE.
	- DUAL-CHANNEL SURFACE RACEWAY SYSTEM WITH DEVICES AS SHOWN ON PLANS. PROVIDE FINISH COLOR AS SELECTED BY ARCHITECT.
	- FLOOR OUTLET RECESSED FLUSH STYLE POKE-THRU DEVICE - DATA CABLING FED FROM FLOOR BELOW. PROVIDE SPARE 1 1/4" CONDUIT FROM POKE-THRU DEVICE UP WALL TO ACCESSIBLE CEILING PLENUM. PROVIDE (2) DUPLEX RECEPTACLES AND (4) DATA JACKS IN FLOOR OUTLET. POKE-THRU SHALL BE WIREMOLD CAT. REVOLUTION BAT SERIES WITH DEVICE BRACKETS AS REQUIRED. PROVIDE ACTIVATION COVER ASSEMBLY WITH FINISH AS SELECTED BY ARCHITECT. PROVIDE 3/4" CONDUIT FOR POWER WIRING. FLOOR SHALL BE CORE DRILLED WITH FINAL LOCATION MARKED BY ARCHITECT/OWNER. CONCRETE POUR SLEEVE SHALL NOT BE USED. WIRE BOTH RECEPTACLES ON SAME CIRCUIT.
	- STEEL TELE-POWER POLE, WIREMOLD 250TP SERIES WITH HEIGHT AS REQUIRED AND FINISH COLOR AS SELECTED BY ARCHITECT. PROVIDE (3) DUPLEX RECEPTACLES IN POWER POLE. PROVIDE ALL ACCESSORIES INCLUDING, BUT NOT LIMITED TO, CEILING TRIM PLATES, POLE CLAMP, FOOT PAD, DEVICE COVER PLATES, ADD-ON POWER COVER, ETC. FOR A COMPLETE INSTALLATION.
	- STEEL TELE-POWER POLE, WIREMOLD 250TP SERIES WITH HEIGHT AS REQUIRED AND FINISH COLOR AS SELECTED BY ARCHITECT. PROVIDE (2) DUPLEX RECEPTACLES AND (2) DATA JACKS IN POWER POLE. PROVIDE ALL ACCESSORIES INCLUDING, BUT NOT LIMITED TO, CEILING TRIM PLATES, POLE CLAMP, FOOT PAD, DEVICE COVER PLATES, ADD-ON COVERS, ETC. FOR A COMPLETE INSTALLATION.

WIRING

SYMBOL	DESCRIPTION
	- HOMERUN TO APPLICABLE PANEL - WIRING SHALL BE 2 #12 AWG WITH SEPARATE GROUND WIRE IN 3/4" CONDUIT UNLESS NOTED OTHERWISE.
	- WIRING - CONCEALED AS SPECIFIED OR AS OTHERWISE NOTED.
	- EQUIPMENT CONNECTED TO SAME CIRCUIT EXCEPT SEPARATELY CONTROLLED.
	- EMERGENCY ONLY CIRCUIT.
	- NE-NORMAL/EMERGENCY LIGHTING CIRCUIT.
	- SR-SURFACE RACEWAY - WIREMOLD 700 SERIES (IVORY).
	- INDICATES VERTICAL RUN OF SURFACE RACEWAY UP TO ACCESSIBLE CEILING PLENUM.
	- INDICATES DRAWING NOTE NUMBER.
	- INDICATES KITCHEN EQUIPMENT NUMBER.

EQUIPMENT

SYMBOL	DESCRIPTION
	- JUNCTION BOX - PROVIDE FINAL CONNECTION TO EQUIPMENT.
	- MOTOR - SIZE AND TYPE AS INDICATED - BY OTHERS. PROVIDE FINAL CONNECTIONS.
	- MOTOR CONTROLLER - BY OTHERS. PROVIDE FINAL CONNECTIONS.
	- NEW PANELBOARD.
	- EXISTING PANELBOARD.
	- TIME CLOCK - 24 HR. ASTRONOMIC WITH SPRING RESERVE POWER - TORK MODEL #7000 SERIES (120V).
	- PHOTOCELL - TORK MODEL #3010 (MOUNT AS HIGH ON WALL AS POSSIBLE).
	- CONTRACTOR - MECHANICALLY HELD - SIZE AND TYPE REQUIRED OR NOTED ON DRAWINGS.
	- THERMAL SWITCH - MANUAL STARTER WITH THERMAL PROTECTION AND HAND/AUTO SWITCH TO ALLOW STARTER CONTROL FROM REMOTE SOURCE. SQUARE D CLASS 2510 SERIES OR EQUAL WITH HANDLE GUARD/LOCK-OFF ATTACHMENT. MOUNT ON OR ADJACENT TO EQUIPMENT.
	- DRY TYPE TRANSFORMER - SIZE AND TYPE INDICATED.
	- NON-FUSED DISCONNECT SWITCH - SIZE AND TYPE INDICATED.
	- FUSED DISCONNECT SWITCH - SIZE AND TYPE INDICATED (PROVIDE FUSES AS PER EQUIPMENT MANUFACTURERS REQUIREMENTS).
	- COMBINATION STARTER/DISCONNECT SWITCH - SIZE 1 U.N.O. - PROVIDED BY E.C. - 60" TO HANDLE.
	- VARIABLE FREQUENCY DRIVE - FURNISHED BY OTHERS. INSTALL DRIVE AND PROVIDE FINAL CONNECTIONS.
	- ENCLOSED CIRCUIT BREAKER - SIZE AS INDICATED.
	- CABLE REEL DROP - SEE SPECIFICATIONS. PROVIDE WEATHER-RATED TYPE WHERE INSTALLED OUTSIDE.

COMMUNICATION SYSTEMS

SYMBOL	DESCRIPTION
2	- DATA OUTLET - FLUSH MOUNTED SINGLE GANG BOX 18" AFF UNO WITH 1" CONDUIT TO ACCESSIBLE CEILING PLENUM. NUMBER BESIDE SYMBOL DESIGNATES QUANTITY OF DATA CABLES AND JACKS AT THIS LOCATION. PROVIDE CABLENG AND JACKS PER SPECIFICATIONS. RUN CABLENG TO DATA CLOSET INDICATED AND TERMINATE.
W	- DATA OUTLET FOR TELEPHONE HANDSET - FLUSH MOUNTED SINGLE GANG BOX 42" AFF WITH 3/4" CONDUIT TO ACCESSIBLE CEILING PLENUM. PROVIDE CABLENG AND JACK PER SPECIFICATIONS. RUN CABLENG TO DATA CLOSET INDICATED AND TERMINATE.
	- TELEVISION OUTLET.
2	- DATA OUTLET TERMINATED ABOVE ACCESSIBLE CEILING. CONTRACTOR IS RESPONSIBLE FOR PROVIDING PLENUM RATED BOX AND TERMINATIONS. NUMBER BESIDE SYMBOL DESIGNATES QUANTITY OF DATA CABLES AND JACKS AT THIS LOCATION. PROVIDE CABLENG AND JACKS PER SPECIFICATIONS. RUN CABLENG TO DATA CLOSET INDICATED AND TERMINATE.
2A	- WIRELESS ACCESS POINT - DATA OUTLET TERMINATED ABOVE ACCESSIBLE CEILING. CONTRACTOR IS RESPONSIBLE FOR PROVIDING PLENUM RATED BOX AND TERMINATIONS. NUMBER BESIDE SYMBOL DESIGNATES QUANTITY OF DATA CABLES AND JACKS AT THIS LOCATION. PROVIDE CABLENG AND JACKS PER SPECIFICATIONS. RUN CABLENG TO DATA CLOSET INDICATED AND TERMINATE. E.C. TO INSTALL ACCESS POINT FURNISHED BY OWNER.
	- WIRELESS CLOCK SYSTEM ANALOG CLOCK, WALL MOUNTED (VERIFY HEIGHT) 12" ROUND UNO. PROVIDE DUPLEX RECEPTACLE AND CONNECT RECEPTACLE TO NEAREST NORMAL 120V RECEPTACLE CIRCUIT. PROVIDE (D) DOUBLE FACE CLOCK WHERE INDICATED.
	- MICROPHONE OUTLET WALL MOUNTED FLUSH - SINGLE GANG BOX - MOUNT 18" AFF UNO. NUMBER BESIDE SYMBOL DESIGNATES QUANTITY OF OUTLETS AT THIS LOCATION.
	- SOUND SYSTEM SPEAKER - CEILING MOUNTED (PAGING SYSTEM). SEE SPECIFICATIONS FOR ANALOG OR NETWORK TYPE.
	- LOCAL SOUND SYSTEM SPEAKER - FLUSH CEILING MOUNTED (LOCAL SYSTEM).
	- SOUND SYSTEM SPEAKER - SURFACE WALL MOUNTED (PAGING SYSTEM).
W	- SOUND SYSTEM SPEAKER - EXTERIOR BUILDING SURFACE WALL MOUNTED - WEATHERPROOF - COORDINATE COLOR OF BACKBOX AND BAFFLE COVER WITH ARCHITECT. (PAGING SYSTEM)
	- SOUND SYSTEM SPEAKER - HORN TYPE MOUNTED TO STRUCTURE (PAGING SYSTEM).
	- LOCAL SOUND SYSTEM SPEAKER - MOUNTED ON WALL OR TO BUILDING STRUCTURE (LOCAL SYSTEM).
	- DOOR INTERCOM SYSTEM REMOTE STATION. REFER TO DOOR ENTRY SYSTEM WIRING DETAIL ON DRAWING E-9.
	- DOOR INTERCOM SYSTEM MASTER STATION. REFER TO DOOR ENTRY SYSTEM WIRING DETAIL ON DRAWING E-9.
	- COMBINATION CLOCK/SPEAKER UNIT
	- SOUND SYSTEM NORMAL/EMERGENCY CALL-IN STATION (PAGING SYSTEM).
	- BLANK OUTLET - FLUSH MOUNTED SINGLE GANG 3 1/2" DEEP BOX 18" AFF UNO WITH 1" SPARE CONDUIT AND PULL STRING TO ACCESSIBLE CEILING PLENUM. PROVIDE BLANK COVER PLATE FOR BOX.
	- MULTI-PURPOSE ROOM PROJECTOR INPUT. SEE SPECIFICATIONS.
	- MULTI-PURPOSE ROOM PROJECTOR CONNECTIONS. SEE SPECIFICATIONS.
	- TV DISPLAY HDMI INPUT - FLUSH MOUNTED SINGLE GANG 3 1/2" DEEP BOX, 18" AFF UNO WITH 1" CONDUIT TO ACCESSIBLE CEILING PLENUM. PROVIDE PLENUM RATED HDMI CABLE FROM TV/LED MONITOR TO INDICATED LOCATION. PROVIDE CABLE LENGTH AS REQUIRED, BUT MINIMUM 35' IN LENGTH, AND SUPPORT 4K30 4:4:4 (4K60 4:2:0). AT THE WALL BOX, PROVIDE KEYSTONE PLATE, HDMI KEYSTONE JACK RATED TO SUPPORT HDMI 2.2 AND HDMI 1.1 ADAPTER RATED TO SUPPORT HDMI 2.2. TEST SYSTEM TO ENSURE FULL COMPATIBILITY AND FUNCTIONALITY.

FIRE ALARM SYSTEM

SYMBOL	DESCRIPTION
	- FIRE ALARM AUDIO UNIT - WALL MOUNTED 18" BELOW FINISHED CEILING (6" ABOVE FINISHED FLOOR MAX.)
30	- COMBINATION FIRE ALARM AUDIO/VISUAL UNIT - WALL MOUNTED 80" AFF. NUMBER BESIDE UNIT INDICATES CANDELA RATING OTHER THAN 15.
	- FIRE ALARM PULL STATION - 42" ABOVE FINISHED FLOOR TO THE HANDLE.
30	- FIRE ALARM VISUAL UNIT - WALL MOUNTED 80" AFF. NUMBER BESIDE UNIT INDICATES CANDELA RATING OTHER THAN 15.
	- FIRE ALARM AUDIO UNIT - FLUSH CEILING
30	- FIRE ALARM VISUAL UNIT - FLUSH CEILING. NUMBER BESIDE UNIT INDICATES CANDELA RATING OTHER THAN 15.
30	- COMBINATION FIRE ALARM AUDIO/VISUAL UNIT - FLUSH CEILING. NUMBER BESIDE UNIT INDICATES CANDELA RATING OTHER THAN 15.
	- HEAT DETECTOR.
	- SMOKE DETECTOR.
	- DUCT MOUNTED SMOKE DETECTOR WITH REMOTE TEST SWITCH/LED INDICATOR - DETECTOR FURNISHED AND WIRED BY E.C. - DETECTOR INSTALLED BY H.C. REMOTE TEST SWITCH/INDICATOR INSTALLED ON WALL BY E.C. AS PER MANUF. REQUIREMENTS.
	- MAGNETIC DOOR HOLDER - PROVIDED AND WIRED BY EC.
	- SPRINKLER FLOW SWITCH - SUPPLIED AND INSTALLED BY F.P.C., WIRED BY E.C.
	- SPRINKLER TAMPER SWITCH - SUPPLIED AND INSTALLED BY F.P.C., WIRED BY E.C.
	- KNOB BOX - CONNECT TO FIRE ALARM SYSTEM.
	- ELECTRIC SPRINKLER GONG - FURNISHED AND INSTALLED BY FIRE PROTECTION CONTRACTOR, WIRED BY E.C.

SECURITY/ACCESS CONTROL SYSTEMS

SYMBOL	DESCRIPTION
	- CCTV SYSTEM CAMERA - E.C. SHALL PROVIDE CAT. 6 DATA WIRING, PER SPECIFICATIONS, CONCEALED BACK TO RESPECTIVE DATA CLOSET INDICATED. VERIFY EXACT CAMERA LOCATION WITH OWNER PRIOR TO ROUGH-IN OF CABLENG. CAMERA FURNISHED BY OWNER AND INSTALLED BY E.C. FOR ALL NEW AND EXISTING REINSTALLED CAMERAS. E.C. SHALL PROVIDE MANUFACTURER STANDARD CEILING TILE BRACKET SUPPORT FOR MOUNTING OF CAMERAS.
	- CARD READER - PROXIMITY TYPE - 46" AFF. CONTRACTOR SHALL PROVIDE A BOX AND 3/4" CONDUIT TO ABOVE ACCESSIBLE CEILING. CARD READER AND ASSOCIATED WIRING BY CONTRACTOR PER SPECIFICATIONS.
	- ELECTRIC DOOR STRIKE OR LATCH RETRACTION - FURNISHED AND INSTALLED BY OTHERS, WIRED BY E.C.
	- KEY PAD FOR SECURITY SYSTEM BY E.C. - 46" AFF.
	- CEILING MOUNTED LONG RANGE PASSIVE INFRARED MOTION DETECTOR BY E.C.
	- CEILING MOUNTED 360° PASSIVE INFRARED MOTION DETECTOR BY E.C.
	- DOOR CONTACT - AT ENTRANCE DOORS, FURNISHED AND INSTALLED BY OTHERS, WIRED BY E.C. AT EXISTING OVERHEAD DOOR AND ROOF HATCHES, CONTACTS SHALL BE PROVIDED AND WIRED BY E.C.
	- DOOR HARDWARE POWER SUPPLY. FURNISHED AND INSTALLED BY OTHERS, WIRED BY E.C. CONNECT POWER SUPPLY TO NEAREST NON-CRITICAL 120/208V NORMAL/EMERGENCY POWER PANEL VIA 2 #12 & #120-3/4". CONNECT A MAXIMUM OF (6) POWER SUPPLIES ON EACH CIRCUIT. EACH POWER SUPPLY CIRCUIT SHALL CONNECT TO A 20A/1P CIRCUIT BREAKER IN THE PANEL.
	- PUSHBUTTON AND TOGGLE SWITCH TO CONTROL ELECTRIC DOOR STRIKE OR LATCH RETRACTION SO DOOR UNLOCKS WHEN BUTTON IS DEPRESSED. PROVIDE STAINLESS STEEL COVER PLATE. REFER TO DOOR ENTRY SELECTOR STATION WIRING DETAIL ON DRAWING E-9.
	- SECURITY SYSTEM AUDIBLE ALARM

ABBREVIATIONS

SYMBOL	DESCRIPTION
AFF	- ABOVE FINISHED FLOOR
AFG	- ABOVE FINISHED GRADE
ATS	- AUTOMATIC TRANSFER SWITCH - SEE SPECIFICATIONS
EN	- EXISTING LOCATION - NEW DEVICE AND COVERPLATE
EP	- EXPLOSION PROOF
ER	- EXISTING ITEM TO BE REMOVED
ERL	- EXISTING ITEM TO BE RELOCATED
EX	- EXISTING ITEM TO REMAIN
TL	- TWIST-LOCK
UNO	- UNLESS NOTED OTHERWISE
WP	- WEATHER PROOF
AC	- AIR CONDITIONING UNIT - BY OTHERS. PROVIDE FINAL CONNECTIONS.
AHU	- AIR HANDLING UNIT - BY OTHERS. PROVIDE FINAL CONNECTIONS.
CH	- CABINET HEATER - BY OTHERS. PROVIDE FINAL CONNECTIONS.
CU	- CONDENSING UNIT - BY OTHERS. PROVIDE FINAL CONNECTIONS.
DH	- ELECTRIC DUCT HEATER - BY OTHERS. PROVIDE FINAL CONNECTIONS.
EF	- EXHAUST FAN - BY OTHERS. PROVIDE FINAL CONNECTIONS.
FC	- FAN COIL UNIT - BY OTHERS. PROVIDE FINAL CONNECTIONS.
HP	- HEAT PUMP UNIT - BY OTHERS. PROVIDE FINAL CONNECTIONS.
UH	- UNIT HEATER - BY OTHERS. PROVIDE FINAL CONNECTIONS.
UV	- UNIT VENTILATOR - BY OTHERS. PROVIDE FINAL CONNECTIONS.
WH	- WALL HEATER - BY OTHERS. PROVIDE FINAL CONNECTIONS.
RTU	- ROOFTOP UNIT - BY OTHERS. PROVIDE FINAL CONNECTIONS.

NOTE: THE ABOVE ELECTRICAL LEGEND IS STANDARD. SOME ITEMS LISTED ARE NOT NECESSARILY USED ON THIS PROJECT. ALL ITEMS LISTED SHALL BE PROVIDED BY THIS CONTRACTOR UNLESS NOTED OTHERWISE.