

## SECTION 10 14 16 - PLAQUES

### PART 1 - GENERAL

#### 1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General Conditions and Division 01 Specification Sections, apply to this Section.

#### 1.2 SUMMARY

- A. Section includes metal plaques.
- B. Related Requirements:
  - 1. Division 10 Section "Panel Signage" for plaques or signs similar to metal plaques, with or without frames, except that they are made of materials other than solid metal.
  - 2. Division 22 Section "Identification for Plumbing Piping and Equipment" for labels, tags, and nameplates for plumbing systems and equipment.
  - 3. Division 23 Section "Identification for HVAC Piping and Equipment" for labels, tags, and nameplates for HVAC systems and equipment.
  - 4. Division 26 Section "Identification for Electrical Systems" for labels, tags, and nameplates for electrical equipment.

#### 1.3 ACTION SUBMITTALS

- A. Product Data: For each type of product.
- B. Shop Drawings: For plaques.
  - 1. Include fabrication and installation details and attachments to other work.
  - 2. Show plaque mounting heights, locations of supplementary supports to be provided by other installers, and accessories.
  - 3. Show typestyles, graphic elements and layout for each plaque at least half size.
- C. Samples for Initial Selection: For each type of plaque, exposed component, and exposed finish.
  - 1. Include representative Samples of available typestyles and graphic symbols.

#### 1.4 INFORMATIONAL SUBMITTALS

- A. Sample Warranty: For special warranty.

#### 1.5 CLOSEOUT SUBMITTALS

- A. Maintenance Data: For plaques to include in maintenance manuals.

## 1.6 WARRANTY

- A. Special Warranty: Manufacturer agrees to repair or replace components of plaques that fail in materials or workmanship within specified warranty period.
  - 1. Failures include, but are not limited to, the following:
    - a. Deterioration of finishes beyond normal weathering.
    - b. Deterioration of embedded graphic image.
  - 2. Warranty Period: Five years from date of Substantial Completion.

## PART 2 - PRODUCTS

### 2.1 PLAQUES

- A. Cast Plaque: Cast-metal plaque with background texture, border, and characters having uniform faces, sharp corners, and precisely formed lines and profiles; and as follows:
  - 1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
    - a. A.R.K. Ramos.
    - b. Gemini Signage; Gemini, Inc.
    - c. Matthews International Corporation: Bronze Division.
    - d. Metallic Arts.
    - e. Southwell Company (The).
  - 2. Plaque Material: Cast aluminum.
  - 3. Plaque Thickness: 0.25 inch, minimum.
  - 4. Size: 30"x42".
  - 5. Finishes:
    - a. Integral Aluminum Finish: Clear anodized.
    - b. Overcoat: Manufacturer's standard baked-on clear coating.
  - 6. Background Texture: Pebble.
  - 7. Integrally Cast Border Style: Double-raised line border.
  - 8. Mounting: Concealed studs.
  - 9. Text and Typeface: Typeface as selected by Architect from manufacturer's full range and variable content.

### 2.2 MATERIALS

- A. Aluminum Castings: ASTM B 26/B 26M, alloy and temper recommended by plaque manufacturer for casting process used and for type of use and finish indicated.
- B. Aluminum Sheet and Plate: ASTM B 209, alloy and temper recommended by aluminum producer and finisher for type of use and finish indicated.

## 2.3 ACCESSORIES

- A. Fasteners and Anchors: Manufacturer's standard as required for secure anchorage of plaques, noncorrosive and compatible with each material joined, and complying with the following:
  - 1. Use concealed fasteners and anchors unless indicated to be exposed.
  - 2. For exterior exposure, furnish nonferrous-metal or hot-dip galvanized devices unless otherwise indicated.
  - 3. Plaque Mounting Fasteners:
    - a. Concealed Studs: Concealed (blind), threaded studs welded or brazed to back of plaque, screwed into back of plaque, or screwed into tapped lugs cast integrally into back of plaque unless otherwise indicated.

## 2.4 FABRICATION

- A. General: Provide manufacturer's standard plaques according to requirements indicated.
  - 1. Preassemble plaques in the shop to greatest extent possible. Disassemble plaques only as necessary for shipping and handling limitations. Clearly mark units for reassembly and installation; apply markings in locations concealed from view after final assembly.
  - 2. Mill joints to a tight, hairline fit. Form assemblies and joints exposed to weather to resist water penetration and retention.
  - 3. Comply with AWS for recommended practices in welding and brazing. Provide welds and brazes behind finished surfaces without distorting or discoloring exposed side. Clean exposed welded and brazed connections of flux, and dress exposed and contact surfaces.
  - 4. Conceal connections if possible; otherwise, locate connections where they are inconspicuous.
  - 5. Provide rabbets, lugs, and tabs necessary to assemble components and to attach to existing work. Drill and tap for required fasteners. Use concealed fasteners where possible; use exposed fasteners that match plaque finish.
  - 6. Castings: Fabricate castings free of warp, cracks, blowholes, pits, scale, sand holes, and other defects that impair appearance or strength. Grind, wire brush, sandblast, and buff castings to remove seams, gate marks, casting flash, and other casting marks before finishing.

## 2.5 GENERAL FINISH REQUIREMENTS

- A. Protect mechanical finishes on exposed surfaces from damage by applying a strippable, temporary protective covering before shipping.
- B. Appearance of Finished Work: Noticeable variations in same piece are not acceptable. Variations in appearance of adjoining components are acceptable if they are within the range of approved Samples and are assembled or installed to minimize contrast.
- C. Organic, Anodic, and Chemically Produced Finishes: Apply to formed metal after fabrication but before applying contrasting polished finishes on raised features unless otherwise indicated.

## 2.6 ALUMINUM FINISHES

- A. Clear Anodic Finish: AAMA 611, Class I, 0.018 mm or thicker.

## PART 3 - EXECUTION

### 3.1 EXAMINATION

- A. Examine substrates, areas, and conditions, with Installer present, for compliance with requirements for installation tolerances and other conditions affecting performance.
- B. Verify that plaque-support surfaces are within tolerances to accommodate plaques without gaps or irregularities between backs of plaques and support surfaces unless otherwise indicated.
- C. Proceed with installation only after unsatisfactory conditions have been corrected.

### 3.2 INSTALLATION

- A. General: Install plaques using mounting methods indicated and according to manufacturer's written instructions.
  - 1. Install plaques level, plumb, true to line, and at locations and heights indicated, with plaque surfaces free of distortion and other defects in appearance.
  - 2. Install plaques so they do not protrude or obstruct according to the accessibility standard.
  - 3. Before installation, verify that plaque surfaces are clean and free of materials or debris that would impair installation.
- B. Mounting Methods:
  - 1. Concealed Studs: Using a template, drill holes in substrate aligning with studs on back of plaque. Remove loose debris from hole and substrate surface.
    - a. Masonry Substrates: Fill holes with adhesive. Leave recess space in hole for displaced adhesive. Place plaque in position and push until flush to surface, embedding studs in holes. Temporarily support plaque in position until adhesive fully sets.
    - b. Thin or Hollow Surfaces: Install wood blocking inside wall sufficient for supporting full weight of plaque.

### 3.3 ADJUSTING AND CLEANING

- A. Remove and replace damaged or deformed plaques and plaques that do not comply with specified requirements. Replace plaques with damaged or deteriorated finishes or components that cannot be successfully repaired by finish touchup or similar minor repair procedures.
- B. Remove temporary protective coverings and strippable films as plaques are installed.
- C. On completion of installation, clean exposed surfaces of plaques according to manufacturer's written instructions, and touch up minor nicks and abrasions in finish. Maintain plaques in a clean condition during construction and protect from damage until acceptance by Owner.

END OF SECTION 10 14 16