

## SECTION 074113

### METAL PANELS & ACCESSORIES

#### PART 1 - GENERAL

##### 1.1 STIPULATIONS

- A. The General Conditions, Drawings and any other attached Contract Documents form a part of this Section by reference thereto and shall have the same force and effect as if printed herewith in full. The Contractor shall be strictly accountable for the cognizance of carrying out the provisions thereof.

##### 1.2 SUMMARY

- A. This Section includes the following:
  - 1. Factory-formed and field-assembled, metal roof panels

##### 1.3 DEFINITIONS

- A. Metal Roof Panel Assembly: Metal roof panels, attachment system components, miscellaneous metal framing, thermal insulation, and accessories necessary for a complete weathertight roofing system.
- B. Steel Sheet Thickness: Minimum thickness of base metal without metallic coatings or painted finishes.

##### 1.4 PERFORMANCE REQUIREMENTS

- A. General: Provide metal roof panel assemblies that comply with performance requirements specified as determined by testing manufacturers' standard assemblies similar to those indicated for this Project, by a qualified testing and inspecting agency.
- B. Water Penetration: No water penetration when tested according to ASTM E 1646 at the following test-pressure difference:
  - 1. Test-Pressure Difference: 2.86 lbf/sq. ft.
  - 2. Test-Pressure Difference: 20 percent of positive design wind pressure, but not less than 6.24 lbf/sq. ft. and not more than 12.0 lbf/sq. ft.
  - 3. Positive Preload Test-Pressure Difference: Greater than or equal to 15.0 lbf/sq. ft. and the greater of 75 percent of building live load or 50 percent of building design positive wind-pressure difference.
  - 4. Negative Preload Test-Pressure Difference: 50 percent of design wind-uplift-pressure difference.

- C. Water Absorption: Maximum 1.0 percent absorption rate by volume when tested according to ASTM C 209.
- D. Thermal Movements: Provide metal roof panel assemblies that allow for thermal movements resulting from the following maximum change (range) in ambient and surface temperatures by preventing buckling, opening of joints, overstressing of components, failure of joint sealants, failure of connections, and other detrimental effects. Base engineering calculation on surface temperatures of materials due to both solar heat gain and nighttime-sky heat loss.
  - 1. Temperature Change (Range): 120 deg F, ambient; 180 deg F, material surfaces.

## 1.5 SUBMITTALS

- A. Product Data: Include construction details, material descriptions, dimensions of individual components and profiles, and finishes for each type of metal roof panel and accessory.
- B. Maintenance Data: For metal roof panels to include in maintenance manuals.
- C. Warranties: Warranties as specified in this Section.

## 1.6 QUALITY ASSURANCE

- A. Installer Qualifications: An employer of workers trained and approved by manufacturer.
  - 1. Installer's responsibilities include fabricating and installing metal roof panel assemblies and providing professional engineering services needed to assume engineering responsibility.
  - 2. Engineering Responsibility: Preparation of data for metal roof panels, including Shop Drawings, based on testing and engineering analysis of manufacturer's standard units in assemblies similar to those indicated for this Project.
- B. Source Limitations: Obtain each type of metal roof panels through one source from a single manufacturer.

## 1.7 DELIVERY, STORAGE, AND HANDLING

- A. Deliver components, sheets, metal roof panels, and other manufactured items so as not to be damaged or deformed. Package metal roof panels for protection during transportation and handling.
- B. Unload, store, and erect metal roof panels in a manner to prevent bending, warping, twisting, and surface damage.

- C. Stack metal roof panels on platforms or pallets, covered with suitable weathertight and ventilated covering. Store metal roof panels to ensure dryness. Do not store metal roof panels in contact with other materials that might cause staining, denting, or other surface damage.
- D. Protect strippable protective covering on metal roof panels from exposure to sunlight and high humidity, except to extent necessary for period of metal roof panel installation.

## 1.8 PROJECT CONDITIONS

- A. Weather Limitations: Proceed with installation only when existing and forecasted weather conditions permit assembly of metal roof panels to be performed according to manufacturers' written instructions and warranty requirements.
- B. Field Measurements: Verify locations of roof framing and roof opening dimensions by field measurements before metal roof panel fabrication and indicate measurements on Shop Drawings.
  - 1. Established Dimensions: Where field measurements cannot be made without delaying the Work, either establish framing and opening dimensions and proceed with fabricating metal roof panels without field measurements, or allow for field-trimming of panels. Coordinate roof construction to ensure that actual building dimensions, locations of structural members, and openings correspond to established dimensions.

## 1.9 WARRANTY

- A. Warranty: Manufacturer's standard form in which manufacturer agrees to repair or replace components of metal roof panel assemblies that fail in materials or workmanship within specified warranty period.
  - 1. Failures include, but are not limited to, the following:
    - a. Structural failures, including rupturing, cracking, or puncturing.
    - b. Deterioration of metals, metal finishes, and other materials beyond normal weathering.
  - 2. Warranty Period: Two (2) years from date of Substantial Completion.
- B. Warranty on Panel Finishes: Manufacturer's standard form in which manufacturer agrees to repair finish or replace metal roof panels that show evidence of deterioration of factory-applied finishes within specified warranty period.
  - 1. Fluoropolymer Finish: Deterioration includes, but is not limited to, the following:
    - a. Color fading more than 5 Hunter units when tested according to ASTM D 2244.
    - b. Chalking in excess of a No. 8 rating when tested according to ASTM D 4214.
    - c. Cracking, checking, peeling, or failure of paint to adhere to bare metal.
  - 2. Finish Warranty Period: Twenty (20) years from date of Substantial Completion.

## PART 2 - PRODUCTS

### 2.1 MANUFACTURERS

- A. In this Part where titles below introduce lists, the following requirements apply for product selection:
  - 1. Available Products: Subject to compliance with requirements, products that may be incorporated into the Work include, but are not limited to, the products specified.
  - 2. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the manufacturers specified.

### 2.2 METAL ROOF PANELS

- A. General: Provide factory-formed metal roof panels designed to be field assembled by over on high ridge of adjacent panels; exposed fastener system attaching panels to supports. Include all accessories necessary to provide a complete system.
  - 1. Steel Panel Systems: Unless more stringent requirements are indicated, comply with ASTM E 1514.
- B. Metal Roof Panels: Formed with vertical ribs at panel edges and intermediate stiffening ribs symmetrically spaced between ribs; designed for sequential installation by mechanically attaching panels to supports. fasten to accommodate thermal movement.
  - 1. Manufacturers:
    - a. Everlast Roofing, Inc.
    - b. "Or Approved Equal"
  - 2. Panel Profile: Everlast II Corrugated
  - 3. Material: Zinc-coated (galvanized) steel sheet, 0.0159 inch thick.
    - a. Exterior Finish: Fluoropolymer or Kynar.
    - b. Color: As selected by Government Design Professional from manufacturer's full range.
  - 4. Surface: Smooth
    - a. Material: 26-27 gauge, zinc-coated (galvanized) or aluminum-zinc alloy-coated steel sheet.
  - 5. Panel Coverage: 36"
  - 6. Raised Panel Height: ¾"
  - 7. Uplift Rating: UL 90.

### 2.3 ACCESSORIES

- A. ROOF PANEL ACCESSORIES: Provide components required for a complete metal roof panel assembly including trim, copings, fasciae, corner units, ridge closures, clips, flashings, sealants, gaskets, fillers, closure strips, and similar items. Match material and finish of metal roof panels, unless otherwise indicated.

1. Closures: Provide closures at eaves and ridges, fabricated of same metal as metal roof panels.
2. Clips: Minimum 0.0625-inch- thick, stainless-steel panel clips designed to withstand negative-load requirements.
3. Cleats: Mechanically seamed cleats formed from minimum 0.0250-inch- thick, stainless-steel or nylon-coated aluminum sheet.
4. Backing Plates: Provide metal backing plates at panel end splices, fabricated from material recommended by manufacturer.
5. Closure Strips: Closed-cell, expanded, cellular, rubber or crosslinked, polyolefin-foam or closed-cell laminated polyethylene; minimum 1-inch- thick, flexible closure strips; cut or premolded to match metal roof panel profile. Provide closure strips where indicated or necessary to ensure weathertight construction.

B. SNOW GUARD

1. Snow Guard shall be 6" x 3" h x 1/8" thick pad type, as shown on drawings.
2. Material: extruded aluminum
3. Color: to match roof panel color
4. Manufacturer:

## 2.4 FABRICATION

- A. General: Fabricate and finish metal roof panels and accessories at the factory to greatest extent possible, by manufacturer's standard procedures and processes, as necessary to fulfill indicated performance requirements demonstrated by laboratory testing. Comply with indicated profiles and with dimensional and structural requirements.
- B. Provide panel profile, including major ribs and intermediate stiffening ribs, if any, for full length of panel.
- C. Fabricate metal roof panel joints with factory-installed captive gaskets or separator strips that provide a tight seal and prevent metal-to-metal contact, in a manner that will minimize noise from movements within panel assembly.
- D. Sheet Metal Accessories: Fabricate flashing and trim to comply with recommendations in SMACNA's "Architectural Sheet Metal Manual" that apply to the design, dimensions, metal, and other characteristics of item indicated.
  1. Form exposed sheet metal accessories that are without excessive oil canning, buckling, and tool marks and that are true to line and levels indicated, with exposed edges folded back to form hems.
  2. Seams for Aluminum: Fabricate nonmoving seams with flat-lock seams. Form seams and seal with epoxy seam sealer. Rivet joints for additional strength.
  3. Seams for Other Than Aluminum: Fabricate nonmoving seams in accessories with flat-lock seams. Tin edges to be seamed, form seams, and solder.
  4. Sealed Joints: Form nonexpansion but movable joints in metal to accommodate elastomeric sealant to comply with SMACNA standards.

5. Conceal fasteners and expansion provisions where possible. Exposed fasteners are not allowed on faces of accessories exposed to view.
6. Fabricate cleats and attachment devices from same material as accessory being anchored or from compatible, noncorrosive metal recommended by metal roof panel manufacturer.
  - a. Size: As recommended by SMACNA's "Architectural Sheet Metal Manual" or metal roof panel manufacturer for application but not less than thickness of metal being secured.

## 2.5 FINISHES, GENERAL

- A. Comply with NAAMM's "Metal Finishes Manual for Architectural and Metal Products" for recommendations for applying and designating finishes.
- B. Protect mechanical and painted finishes on exposed surfaces from damage by applying a strippable, temporary protective covering before shipping.
- C. Appearance of Finished Work: Variations in appearance of abutting or adjacent pieces are acceptable if they are within one-half of the range of approved Samples. Noticeable variations in the same piece are not acceptable. Variations in appearance of other components are acceptable if they are within the range of approved Samples and are assembled or installed to minimize contrast.

## PART 3 - EXECUTION

### 3.1 EXAMINATION

- A. Examine substrates, areas, and conditions, with Installer present, for compliance with requirements for installation tolerances, metal roof panel supports, and other conditions affecting performance of work.
  1. Examine primary and secondary roof framing to verify that rafters, purlins, angles, channels, and other structural panel support members and anchorages have been installed within alignment tolerances required by metal roof panel manufacturer.
  2. Examine solid roof sheathing to verify that sheathing joints are supported by framing or blocking and that installation is within flatness tolerances required by metal roof panel manufacturer.
  3. For the record, prepare written report, endorsed by Installer, listing conditions detrimental to performance of work.
- B. Examine items penetrating metal roof panels to verify actual locations of penetrations relative to seam locations of metal roof panels before metal roof panel installation.
- C. Proceed with installation only after unsatisfactory conditions have been corrected.

### 3.2 PREPARATION

- A. Clean substrates of substances harmful to insulation, including removing projections capable of interfering with roof/wall panel attachment.

### 3.3 METAL ROOF PANEL INSTALLATION, GENERAL

- A. General: Provide metal roof panels of full length from eave to ridge, unless otherwise indicated or restricted by shipping limitations. Anchor panels and other components of the Work securely in place, with provisions for thermal and structural movement.
  - 1. Field cutting of metal roof panels by torch is not permitted.
  - 2. Install panels perpendicular to purlins.
  - 3. Rigidly fasten eave end of metal roof panels and allow ridge end free movement due to thermal expansion and contraction. Predrill panels.
  - 4. Provide metal closures at peaks, rake edges rake walls and each side of ridge and hip caps.
  - 5. Flash and seal metal roof panels with weather closures at eaves, rakes, and at perimeter of all openings. Fasten with self-tapping screws.
  - 6. Locate and space fastenings in uniform vertical and horizontal alignment.
  - 7. Install ridge and hip caps as metal roof panel work proceeds.
  - 8. Locate panel splices over, but not attached to, structural supports. Stagger panel splices and end laps to avoid a four-panel lap splice condition.
  - 9. Lap metal flashing over metal roof panels to allow moisture to run over and off the material.
- B. Field cutting of metal roof panels by torch is not permitted.
- C. Rigidly fasten panels but allow free movement for thermal expansion and contraction.
- D. Provide metal closures, where required.
- E. Locate and space fastenings in uniform vertical and horizontal alignment.
- F. Install end caps, ridge cap and all other trim pieces as required
- G. Fasteners:
  - 1. Steel Roof Panels: Use stainless-steel fasteners for surfaces exposed to the exterior and galvanized steel fasteners for surfaces exposed to the interior.
  - 2. Aluminum Roof Panels: Use aluminum or stainless-steel fasteners for surfaces exposed to the exterior and aluminum or galvanized steel fasteners for surfaces exposed to the interior.
- H. Metal Protection: Where dissimilar metals will contact each other or corrosive substrates, protect against galvanic action by painting contact surfaces with bituminous coating, by applying rubberized-asphalt underlayment to each contact surface, or by other permanent separation as recommended by metal roof panel manufacturer.

1. Coat back side of stainless-steel roof panels with bituminous coating where roof panels will contact wood, ferrous metal, or cementitious construction.
- I. Joint Sealers: Install gaskets, joint fillers, and sealants where indicated and where required for weatherproof performance of metal roof panel assemblies. Provide types of gaskets, fillers, and sealants indicated or, if not indicated, types recommended by metal roof panel manufacturer.
  1. Seal metal roof panel end laps with double beads of tape or sealant, full width of panel. Seal side joints where recommended by metal roof panel manufacturer.
  2. Prepare joints and apply sealants to comply with requirements in Division 7 Section "Joint Sealants."

### 3.4 PANEL INSTALLATION

- A. Panels: Fasten panels to supports with fasteners following manufacturer's recommended locations.

### 3.5 ACCESSORY INSTALLATION

- A. General: Install accessories with positive anchorage to building and weathertight mounting and provide for thermal expansion. Coordinate installation with flashings and other components.
  1. Install components required for a complete metal roof panel assembly including trim, copings, ridge closures, seam covers, flashings, sealants, gaskets, fillers, closure strips, and similar items.
- B. Snow Guards: Attach snow guards as recommended by manufacturer.

### 3.6 CLEANING AND PROTECTION

- A. Remove temporary protective coverings and strippable films, if any, as panels are installed, unless otherwise indicated in manufacturer's written installation instructions. On completion of metal roof panel installation, clean finished surfaces as recommended by panel manufacturer. Maintain in a clean condition during construction.
- B. Replace panels that have been damaged or have deteriorated beyond successful repair by finish touchup or similar minor repair procedures.

END OF SECTION