

## SECTION 233710

### AIR INLETS AND OUTLETS

#### PART 1 GENERAL

##### 1.1 STIPULATIONS

- A. The General Conditions, drawings and all other attached documents form a part of this Section and all other Sections by reference thereto and have the same force and effect as if printed herewith in full. The Contractor shall be strictly accountable for the cognizance of carrying out the provisions thereof.

#### PART 2 PRODUCTS

##### 2.1 AIR CONTROL DEVICES

- A. This Contractor shall furnish and install air control devices and accessories, as shown on plans and as specified herein.
- B. Interior grilles, registers diffusers, and louvers shall have white enamel finish ready for field painting.
- C. All security air control devices shall be installed with vandal proof screws. Fasteners shall be one-way vandal proof #8 - 3/4 S/M screws. Through bolts shall be one-way vandal proof heads.
- D. Air control devices shall be as manufactured by Anemostat, Titus Corporation, Price or approved equal.
- E. Shop drawings showing room schedule, style, catalog numbers, finish, size, details, CFM, NC ratings, and accessories shall be submitted for review.
- F. For the purpose of setting a minimum standard, Model numbers listed below shall be referenced to Price or Anemostat, unless otherwise noted. Other manufacturers submitted shall be in all ways equal with NC ratings limited to a maximum of NC 30, as accepted by the Professional.

##### 1. Ceiling Diffusers (CD)

##### a. Square Ceiling Diffusers:

- (1). Basis-of-Design Product: Subject to compliance with requirements, provide product indicated on Drawings or comparable product by one of the following:

- (a). Tuttle & Bailey.
- (b). Carnes.
- (c). Hart & Cooley Inc.
- (d). METALAIRE, Inc.

- (2). Devices shall be specifically designed for variable-air-volume flows.

- (3). Material: Aluminum.

- (4). Finish: Baked enamel, white

- (5). Face Style: Three cone.

- (6). Mounting: Lay-In, Surface Mounted and Duct-Mounted (See Drawings).
- (7). Pattern: Fixed

#### 1. Ceiling Mounted Return Grille (RG)

- a. Panels shall be steel with square/rectangular necks. ½" x ½' x ½" deep egg crate face return with mounting frame to match ceiling type.
- b. Panel face shall be finished in white finish shade as selected by the Professional to match the ceiling tile.
- c. The unit shall be similar to Price 80.

### 2.2 LOUVERS

- A. All louvers performance shall equal or surpass the minimum free area, maximum static pressure, and airflow requirements for the specified application.
- B. 4" Louvers.
  - 1. Furnish and install where indicated on drawings for air handling units and other intakes or exhausts 4" deep thick louvers with 1/4" x 1/4" aluminum bird screen.
  - 2. Frames and blades shall be 6063-T5 alloy, extruded aluminum sections of a minimum 12 gauge (0.081 inch) thickness with 2 reinforcing bosses, heads, sills, jambs to be one piece structural members. Maximum blade span shall be 96 inches; greater spans shall employ a rigid vertical mullion.
  - 3. Louvers shall be Model XB-4 as manufactured by Airline Products Co., Airstream Model SA, Ruskin Model ELF 375, or Arrow United Industries, Inc., Model SPA-11. Louvers shall be color as selected by the Professional.

## PART 3 EXECUTION

### 3.1 GENERAL

- A. Coordinate all devices with ceiling grid, construction and type, and work of other trades.
- B. See also "ACCESS PANELS".
- C. Spin Collars: For each flexible duct connection off of a main or branch duct to a ceiling diffuser and for each outlet off of the ventilation ductwork to the plenum air furnish and install a spin collar with a positive locking balancing damper.
- D. Backdraft Dampers
  - 1. Furnish and install for all gravity relief louvers and ventilators, back-draft design.
  - 2. Where multiple sections are required, this Contractor shall provide additional mullions and bearings to support total assembly. Seal all joints weathertight.

END OF SECTION

## SECTION 235400 - FURNACES

### PART 1 - GENERAL

#### 1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

#### 1.2 SUMMARY

- A. This Section includes the following:
  - 1. Gas-fired, condensing furnaces and accessories complete with controls.
  - 2. Air filters.
  - 3. Air cleaners.
  - 4. Ultraviolet germicidal lights.
  - 5. Refrigeration components.

#### 1.3 ACTION SUBMITTALS

- A. Product Data: Include rated capacities, operating characteristics, furnished specialties, and accessories for each of the following:
  - 1. Furnace.
  - 2. Thermostat.
  - 3. Air filter.
  - 4. Ultraviolet germicidal light.
  - 5. Refrigeration components.
- B. Shop Drawings: Detail equipment assemblies and indicate dimensions, weights, loads, required clearances, method of field assembly, components, and location and size of each field connection.
  - 1. Wiring Diagrams: Power, signal, and control wiring.

#### 1.4 INFORMATIONAL SUBMITTALS

- A. Warranty: Special warranty specified in this Section.

#### 1.5 CLOSEOUT SUBMITTALS

- A. Operation and Maintenance Data: For each furnace to include in emergency, operation, and maintenance manuals for each of the following:

1. Furnace and accessories complete with controls.
2. Air filter.
3. Ultraviolet germicidal light.
4. Refrigeration components.

#### 1.6 MAINTENANCE MATERIAL SUBMITTALS

- A. Furnish extra materials described below that match products installed and that are packaged with protective covering for storage and identified with labels describing contents.
  1. Disposable Air Filters: Furnish two complete sets.
  2. Fan Belts: Furnish one set for each furnace fan.

#### 1.7 QUALITY ASSURANCE

- A. Electrical Components, Devices, and Accessories: Listed and labeled as defined in NFPA 70, Article 100, by a testing agency acceptable to authorities having jurisdiction, and marked for intended use.
- B. ASHRAE Compliance: Applicable requirements in ASHRAE 62.1, Section 5 - "Systems and Equipment" and Section 7 - "Construction and Startup."
- C. ASHRAE/IESNA 90.1 Compliance: Applicable requirements in ASHRAE/IESNA 90.1, Section 6 - "Heating, Ventilating, and Air-Conditioning."
- D. Comply with NFPA 70.

#### 1.8 COORDINATION

- A. Coordinate size and location of concrete bases. Cast anchor-bolt inserts into bases. Concrete, reinforcement, and formwork requirements are specified with concrete.

#### 1.9 WARRANTY

- A. Special Warranty: Manufacturer's standard form in which manufacturer agrees to repair or replace the following components of furnaces that fail in materials or workmanship within specified warranty period:
  1. Warranty Period, Commencing on Date of Substantial Completion:
    - a. Furnace Heat Exchanger: 10 years.
    - b. Integrated Ignition and Blower Control Circuit Board: Five years.
    - c. Draft-Inducer Motor: Five years.
    - d. Refrigeration Compressors: 10 years.
    - e. Evaporator and Condenser Coils: Five years.

## PART 2 - PRODUCTS

### 2.1 GAS-FIRED FURNACES, CONDENSING

- A. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
- B. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
- C. Basis-of-Design Product: Subject to compliance with requirements, provide [the product indicated on Drawings] <Insert manufacturer's name; product name or designation> or a comparable product by one of the following:
  - 1. Carrier Corporation; Div. of United Technologies Corp.
  - 2. Trane.
  - 3. York International Corp.; a division of Unitary Products Group.
- D. General Requirements for Gas-Fired, Condensing Furnaces: Factory assembled, piped, wired, and tested; complying with ANSI Z21.47/CSA 2.3, "Gas-Fired Central Furnaces," and with NFPA 54.
- E. Cabinet: Steel.
  - 1. Cabinet interior around heat exchanger shall be factory-installed insulation.
  - 2. Lift-out panels shall expose burners and all other items requiring access for maintenance.
  - 3. Factory paint external cabinets in manufacturer's standard color.
  - 4. Airstream Surfaces: Surfaces in contact with the airstream shall comply with requirements in ASHRAE 62.1.
- F. Fan: Centrifugal, factory balanced, resilient mounted, direct drive.
  - 1. Fan Motors: Comply with requirements in Section 230513 "Common Motor Requirements for HVAC Equipment."
  - 2. Special Motor Features: Single speed, Premium (TM) efficiency, as defined in Section 230513 "Common Motor Requirements for HVAC Equipment," and with internal thermal protection and permanent lubrication.
  - 3. Special Motor Features: Multitapped, multispeed with internal thermal protection and permanent lubrication.
  - 4. Special Motor Features: Electronically controlled motor (ECM) controlled by integrated furnace/blower control.
- G. Type of Gas: [Natural] [Propane].
- H. Heat Exchanger:
  - 1. Primary: Stainless steel.
  - 2. Secondary: Stainless steel.
- I. Burner:

1. Gas Valve: 100 percent safety modulating main gas valve, main shutoff valve, pressure regulator, safety pilot with electronic flame sensor, limit control, transformer, and combination ignition/fan timer control board.
  2. Ignition: Electric pilot ignition, with hot-surface igniter or electric spark ignition.
- J. Gas-Burner Safety Controls:
1. Electronic Flame Sensor: Prevents gas valve from opening until pilot flame is proven; stops gas flow on ignition failure.
  2. Flame Rollout Switch: Installed on burner box; prevents burner operation.
  3. Limit Control: Fixed stop at maximum permissible setting; de-energizes burner on excessive bonnet temperature; automatic reset.
- K. Combustion-Air Inducer: Centrifugal fan with thermally protected motor and sleeve bearings prepurges heat exchanger and vents combustion products; pressure switch prevents furnace operation if combustion-air inlet or flue outlet is blocked.
- L. Furnace Controls: Solid-state board integrates ignition, heat, cooling, and fan speeds; adjustable fan-on and fan-off timing; terminals for connection to accessories diagnostic light with viewport.
- M. Accessories:
1. Combination Combustion-Air Intake and Vent: PVC plastic fitting to combine combustion-air inlet and vent through outside wall.
  2. CPVC Plastic Vent Materials.
    - a. CPVC Plastic Pipe: Schedule 40, complying with ASTM F 441/F 441M.
    - b. CPVC Plastic Fittings: Schedule 40, complying with ASTM F 438, socket type.
    - c. CPVC Solvent Cement: ASTM F 493.
      - 1) CPVC solvent cement shall have a VOC content of 490 g/L or less when calculated according to 40 CFR 59, Subpart D (EPA Method 24).
      - 2) Adhesive primer shall have a VOC content of 550 g/L or less when calculated according to 40 CFR 59, Subpart D (EPA Method 24).
      - 3) Solvent cement and adhesive primer shall comply with the testing and product requirements of the California Department of Health Services' "Standard Practice for the Testing of Volatile Organic Emissions from Various Sources Using Small-Scale Environmental Chambers."
  3. PVC Plastic Vent Materials:
    - a. PVC Plastic Pipe: Schedule 40, complying with ASTM D 1785.
    - b. PVC Plastic Fittings: Schedule 40, complying with ASTM D 2466, socket type.
    - c. PVC Solvent Cement: ASTM D 2564.
      - 1) PVC solvent cement shall have a VOC content of 510 g/L or less when calculated according to 40 CFR 59, Subpart D (EPA Method 24).
      - 2) Adhesive primer shall have a VOC content of 550 g/L or less when calculated according to 40 CFR 59, Subpart D (EPA Method 24).

- 3) Solvent cement and adhesive primer shall comply with the testing and product requirements of the California Department of Health Services' "Standard Practice for the Testing of Volatile Organic Emissions from Various Sources Using Small-Scale Environmental Chambers."

## 2.2 THERMOSTATS

- A. Controls shall comply with requirements in ASHRAE/IESNA 90.1, "Controls."
- B. Solid-State Thermostat: Wall-mounting programmable, microprocessor-based unit with automatic switching from heating to cooling, preferential rate control, seven-day programmability with minimum of four temperature presets per day, and battery backup protection against power failure for program settings.
- C. Two-Stage, Heating-Cooling Thermostat: Adjustable, heating-cooling, wall-mounting unit with fan on-automatic selector.
- D. Control Wiring: Unshielded twisted-pair cabling.
  1. No. 24 AWG, 100 ohm, four pair.
  2. Cable Jacket Color: Blue.

## 2.3 AIR FILTERS

- A. Disposable Filters: 1-inch-thick fiberglass media with ASHRAE 52.2 MERV rating of 6 or higher, in sheet metal frame.

## 2.4 ULTRAVIOLET GERMICIDAL LIGHTS

- A. Description: Lighting unit in metal housing arranged for installation in supply-air duct and controlled to cycle on and off with furnace fan, with one 75-W ultraviolet-light bulb(s).

## 2.5 REFRIGERATION COMPONENTS

- A. General Refrigeration Component Requirements:
  1. Refrigeration compressor, coils, and specialties shall be designed to operate with CFC-free refrigerants.
  2. Energy Efficiency: Equal to or greater than prescribed by ASHRAE/IESNA 90.1, "Energy Standard for Buildings except Low-Rise Residential Buildings."
- B. Refrigerant Coil: Copper tubes mechanically expanded into aluminum fins. Comply with ARI 210/240, "Unitary Air-Conditioning and Air-Source Heat Pump Equipment." Match size with furnace. Include condensate drain pan with accessible drain outlet complying with ASHRAE 62.1.

1. Refrigerant Coil Enclosure: Steel, matching furnace and evaporator coil, with access panel and flanges for integral mounting at or on furnace cabinet and galvanized sheet metal drain pan coated with black asphaltic base paint.
- C. Refrigerant Line Kits: Annealed-copper suction and liquid lines factory cleaned, dried, pressurized with nitrogen, sealed, and with suction line insulated. Provide in standard lengths for installation without joints, except at equipment connections.
1. Flexible Elastomeric: Closed-cell, sponge- or expanded-rubber materials. Comply with ASTM C 534, Type I, 1 inch thick.
- D. Refrigerant Piping: Comply with requirements in Section 232300 "Refrigerant Piping."
- E. Air-Cooled, Compressor-Condenser Unit:
1. Casing: Steel, finished with baked enamel, with removable panels for access to controls, weep holes for water drainage, and mounting holes in base. Provide brass service valves, fittings, and gage ports on exterior of casing.
  2. Compressor: Hermetically sealed reciprocating type.
    - a. Crankcase heater.
    - b. Vibration isolation mounts for compressor.
    - c. Compressor motor shall have thermal- and current-sensitive overload devices, start capacitor, relay, and contactor.
    - d. Variable-speed compressor motors shall have manual-reset high-pressure switch and automatic-reset low-pressure switch.
    - e. Refrigerant: R-407C or R-410A.
  3. Refrigerant Coil: Copper tube, with mechanically bonded aluminum fins, complying with ARI 210/240, and with liquid subcooler.
  4. Heat-Pump Components: Reversing valve and low-temperature air cut-off thermostat.
  5. Fan: Aluminum-propeller type, directly connected to motor.
  6. Motor: Permanently lubricated, with integral thermal-overload protection.
  7. Low Ambient Kit: Permits operation down to 45 deg F (7 deg C).
  8. Mounting Base: Polyethylene.

## PART 3 - EXECUTION

### 3.1 EXAMINATION

- A. Examine areas and conditions, with Installer present, for compliance with requirements for installation tolerances and other conditions affecting performance of the Work.
- B. Examine factory-installed insulation before furnace installation. Reject units that are wet, moisture damaged, or mold damaged.
- C. Examine roughing-in for gas and refrigerant piping systems to verify actual locations of piping connections before equipment installation.



- D. Proceed with installation only after unsatisfactory conditions have been corrected.

### 3.2 INSTALLATION

- A. Install gas-fired furnaces and associated fuel and vent features and systems according to NFPA 54.
- B. Install oil-fired furnaces and associated fuel and vent piping according to NFPA 31.
- C. Suspended Units: Suspend from structure using threaded rods, spring hangers, and building attachments. Secure rods to unit hanger attachments. Adjust hangers so unit is level and plumb.
  - 1. Install seismic restraints to limit movement of furnace by resisting code-required seismic acceleration.
- D. Base-Mounted Units: Secure units to substrate. Provide optional bottom closure base if required by installation conditions.
  - 1. Anchor furnace to substrate to resist code-required seismic acceleration.
- E. Controls: Install thermostats and humidistats at mounting height of 60 inches above floor.
- F. Wiring Method: Install control wiring in accessible ceiling spaces and in gypsum board partitions where unenclosed wiring method may be used. Conceal control wiring except in unfinished spaces.
- G. Install ground-mounted, compressor-condenser components on 6-inch-thick, reinforced concrete base; as indicated on the drawings.

### 3.3 CONNECTIONS

- A. Gas piping installation requirements are specified in Section 231126 "Facility Liquefied-Petroleum Gas Piping." Drawings indicate general arrangement of piping, fittings, and specialties. Connect gas piping with union or flange and appliance connector valve.
- B. Install piping adjacent to equipment to allow service and maintenance.
- C. Vent and Outside-Air Connection, Condensing, Gas-Fired Furnaces: Connect plastic piping vent material to furnace connections and extend outdoors. Terminate vent outdoors with a cap and in an arrangement that will protect against entry of birds, insects, and dirt.
  - 1. Ream ends of pipes and tubes and remove burrs. Bevel plain ends of steel pipe.
  - 2. Remove scale, slag, dirt, and debris from inside and outside of pipe and fittings before assembly.
  - 3. Plastic Piping Solvent-Cement Joints: Clean and dry joining surfaces. Join pipe and fittings according to the following:
    - a. Comply with ASTM F 402 for safe-handling practice of cleaners, primers, and solvent cements.
    - b. CPVC Piping: Join according to ASTM D 2846/D 2846M Appendix.

- c. PVC Pressure Piping: Join schedule number ASTM D 1785, PVC pipe and PVC socket fittings according to ASTM D 2672. Join other-than-schedule-number PVC pipe and socket fittings according to ASTM D 2855.
- d. Requirements for Low-Emitting Materials:
  - 1) CPVC solvent cement shall have a VOC content of 490 g/L or less when calculated according to 40 CFR 59, Subpart D (EPA Method 24).
  - 2) PVC solvent cement shall have a VOC content of 510 g/L or less when calculated according to 40 CFR 59, Subpart D (EPA Method 24).
  - 3) Adhesive primer shall have a VOC content of 550 g/L or less when calculated according to 40 CFR 59, Subpart D (EPA Method 24).
  - 4) Solvent cement and adhesive primer shall comply with the testing and product requirements of the California Department of Health Services' "Standard Practice for the Testing of Volatile Organic Emissions from Various Sources Using Small-Scale Environmental Chambers."
- 4. Slope pipe vent back to furnace or to outside terminal.
- D. Connect ducts to furnace with flexible connector. Comply with requirements in Section 233300 "Air Duct Accessories."
- E. Connect refrigerant tubing kits to refrigerant coil in furnace and to air-cooled, compressor-condenser unit.
  - 1. Flared Joints: Use ASME B16.26 fitting and flared ends, following procedures in CDA's "Copper Tube Handbook."
  - 2. Soldered Joints: Apply ASTM B 813, water-flushable flux, unless otherwise indicated, to tube end. Construct joints according to ASTM B 828 or CDA's "Copper Tube Handbook," using lead-free solder alloy complying with ASTM B 32.
  - 3. Brazed Joints: Construct joints according to AWS's "Brazing Handbook," "Pipe and Tube" Chapter, using copper-phosphorus brazing filler metal complying with AWS A5.8.
- F. Comply with requirements in Section 232300 "Refrigerant Piping" for installation and joint construction of refrigerant piping.

### 3.4 FIELD QUALITY CONTROL

- A. Perform the following field tests and inspections and prepare test reports:
  - 1. Perform electrical test and visual and mechanical inspection.
  - 2. Leak Test: After installation, charge systems with refrigerant and oil and test for leaks. Repair leaks, replace lost refrigerant and oil, and retest until no leaks exist.
  - 3. Operational Test: After electrical circuitry has been energized, start units to confirm proper operation, product capability, and compliance with requirements.
  - 4. Verify that fan wheel is rotating in the correct direction and is not vibrating or binding.
  - 5. Test and adjust controls and safeties. Replace damaged and malfunctioning controls and equipment.
- B. Verify that vibration isolation and flexible connections properly dampen vibration transmission to structure.

### 3.5 STARTUP SERVICE

- A. Complete installation and startup checks according to manufacturer's written instructions and perform the following:
  - 1. Inspect for physical damage to unit casings.
  - 2. Verify that access doors move freely and are weathertight.
  - 3. Clean units and inspect for construction debris.
  - 4. Verify that all bolts and screws are tight.
  - 5. Adjust vibration isolation and flexible connections.
  - 6. Verify that controls are connected and operational.
- B. Adjust fan belts to proper alignment and tension.
- C. Start unit according to manufacturer's written instructions and complete manufacturer's operational checklist.
- D. Measure and record airflows.
- E. Verify proper operation of capacity control device.
- F. After startup and performance test, lubricate bearings and adjust belt tension.

### 3.6 ADJUSTING

- A. Adjust initial temperature and humidity set points.
- B. Set controls, burner, and other adjustments for optimum heating performance and efficiency. Adjust heat-distribution features, including shutters, dampers, and relays, to provide optimum heating performance and system efficiency.

### 3.7 CLEANING

- A. After completing installation, clean furnaces internally according to manufacturer's written instructions.
- B. Install new filters in each furnace within 14 days after Substantial Completion.

### 3.8 DEMONSTRATION

- A. Train Owner's maintenance personnel to adjust, operate, and maintain condensing units. Refer to Section 017900 "Demonstration and Training."

END OF SECTION 235400