

WATER CLOSETS AND URINALS					
FIXTURE IDENTIFICATION	DESCRIPTION	MOUNTING REQUIREMENTS	FIXTURE MANUFACTURER AND MODEL NUMBER (OR APPROVED EQUAL)	FIXTURE ACCESSORIES MAKE AND MODEL NUMBER (OR APPROVED EQUAL)	FOOTNOTES
W-1	WATER CLOSET 1.28 GALLON PER FLUSH SIPHON JET ELONGATED BOWL - VITREOUS CHINA (RESIDENT / STAFF TOILET FACILITY)	FLOOR MOUNTED BACK OUTLET STANDARD ACCESSIBLE	(AMERICAN STD. KOHLER & ZURN) 1.28 GALLON PER FLUSH ELONGATED BOWL VITREOUS CHINA ZURN - ECO VANTAGE HET MODEL #Z5637-BWL	(AMERICAN STD. SLOAN & ZURN) CONCEALED DIAPHRAGM TYPE HARD-WIRED CONCEALED ELECTRIC SENSOR OPERATED FLUSH VALVE ZURN - AQUASENSE AV MODEL #ZEM6S152AV-HET	1, 2, 5
W-2	WATER CLOSET 1.28 GALLON PER FLUSH SIPHON JET - ELONGATED BOWL - VITREOUS CHINA (RESIDENT /STAFF TOILET FACILITY)	FLOOR MOUNTED BACK OUTLET ADA ACCESSIBLE	(AMERICAN STD. KOHLER & ZURN) 1.28 GALLON PER FLUSH ELONGATED BOWL VITREOUS CHINA ZURN - ECO VANTAGE HET MODEL # Z5647-BWL	(AMERICAN STD. SLOAN & ZURN) CONCEALED DIAPHRAGM TYPE HARD-WIRED CONCEALED ELECTRIC SENSOR OPERATED FLUSH VALVE ZURN - AQUASENSE AV MODEL # ZEM6S152AV-HET	1, 2, 5
W-3	WATER CLOSET 1.28 GALLON PER FLUSH SIPHON JET ELONGATED BOWL (RESIDENT / STAFF TOILET)	FLOOR MOUNTED ADA HANDICAP ACCESSIBLE	(AMERICAN STD. KOHLER & ZURN) 1.28 GALLON PER FLUSH ELONGATED BOWL - VITREOUS CHINA ZURN -ECO VANTAGE - HET MODEL #Z5665-BWL1	(AMERICAN STD. SLOAN & ZURN) CONCEALED DIAPHRAGM TYPE HARD-WIRED CONCEALED ELECTRIC SENSOR OPERATED FLUSH VALVE ZURN - AQUASENSE AV MODEL # ZEM6S152AV-HET	1, 3, 5
W-4	WATER CLOSET 1.28 GALLON PER FLUSH SIPHON JET ELONGATED BOWL (OR REST ROOM)	FLOOR MOUNTED ADA HANDICAP ACCESSIBLE	(AMERICAN STD. KOHLER & ZURN) 1.28 GALLON PER FLUSH ELONGATED BOWL - VITREOUS CHINA ZURN -ECO VANTAGE - HET MODEL #Z5665-BWL1	(AMERICAN STD. SLOAN & ZURN) CONCEALED DIAPHRAGM TYPE HARD-WIRED CONCEALED ELECTRIC SENSOR OPERATED FLUSH VALVE ZURN - AQUASENSE AV MODEL # ZEM6S152AV-HET	1, 3, 5
U-1	URINAL 0.125 GALLON PER FLUSH WASHOUT TYPE VITREOUS CHINA (RESIDENT / STAFF TOILET)	WALL MOUNTED ADA HANDICAP ACCESSIBLE	(AMERICAN STD. KOHLER & ZURN) HIGH EFFICIENCY- ULTRA LOW 0.125 CONSUMPTION "PINT" URINAL ZURN - ECO VANTAGE MODEL #Z5758-U	(DELANY, SLOAN & ZURN) CONCEALED DIAPHRAGM TYPE HARD-WIRED CONCEALED ELECTRIC SENSOR OPERATED FLUSH VALVE ZURN - AQUASENSE AV MODEL #ZEM6S195AV-ULF	1, 4, 5

WATER CLOSET AND URINAL FOOTNOTES:

1. REFER TO SPECIFICATIONS FOR REQUIREMENTS OF MATERIALS, COLOR, FINISHES, INSTALLATION, APPROVED EQUAL MANUFACTURERS, ETC..
2. PROVIDE COMPLETE WITH PERMANENTLY ATTACHED SPLIT NOSE SEAT, WALL WASTE CARRIER, SUPPLY AND WASTE ROUGH-IN ASSEMBLIES IN ACCORDANCE WITH SPECIFICATIONS.
3. PROVIDE COMPLETE WITH PERMANENTLY ATTACHED SPLIT NOSE SEAT, FLOOR MOUNTED FLANGE, SUPPLY AND WASTE ROUGH-IN ASSEMBLIES IN ACCORDANCE WITH SPECIFICATIONS.
4. PROVIDE COMPLETE WITH WALL CHAIR CARRIER, SUPPLY AND WASTE ROUGH-IN ASSEMBLIES IN ACCORDANCE WITH SPECIFICATIONS.
5. THE 3 CONTRACTOR SHALL PROVIDE AND INSTALL THE REQUIRED CONCEALED VALVE ASSEMBLY WITH ALL ELECTRIC COMPONENTS (120V / LOW VOLTAGE) FOR THE SPECIFIED AND SELECTED MANUFACTURER TO OPERATE THE INDIVIDUAL OR MULTIPLE HARDWARE SENSOR OPERATED FLUSH VALVE ASSEMBLY. REFER TO THE PIPING PLANS FOR PROPOSED TRANSFORMER LOCATIONS. THE 3 CONTRACTOR SHALL COORDINATE THE TRANSFORMER LOCATION AND ELECTRICAL POWER SUPPLY REQUIREMENTS WITH THE 4 CONTRACTOR. THE LOW VOLTAGE SYSTEM SHALL BE COMPLETE WITH APPROVED REDUCED VOLTAGE TRANSFORMERS (ZURN MODEL #HW6-MJ), WIRING, JUNCTION BOXES AND CONDUIT FOR WIRING EXPOSED OR CONCEALED IN WALLS OR CEILINGS AS REQUIRED. THE 3 CONTRACTOR SHALL EXTEND AND CONNECT THE REQUIRED LOW VOLTAGE WIRING TO THE FLUSH VALVES AS PER THE MANUFACTURER RECOMMENDATIONS AND INSTALLATION INSTRUCTIONS. THE CONTRACTOR SHALL PROVIDE VANDAL RESISTANT ACCESS TO CONCEALED FLUSH VALVE ASSEMBLY FOR MAINTENANCE AND REPAIR. (TYPICAL)

WATER COOLERS					
FIXTURE IDENTIFICATION	DESCRIPTION	MOUNTING REQUIREMENTS	FIXTURE MANUFACTURER AND MODEL NUMBER (OR APPROVED EQUAL)	FIXTURE ACCESSORIES MAKE AND MODEL NUMBER (OR APPROVED EQUAL)	FOOTNOTES
D-1	WATER COOLER TWO STATION - BI-LEVEL BARRIER-FREE W/ BOTTLE FILL HANDS-FREE ACTIVATION (RESIDENT AREA)	WALL MOUNTED STANDARD & ADA HANDICAP ACCESSIBLE	ELKAY EZH2O TWO STATION BI-LEVEL W/ BOTTLE FILL STATION & FILTER MODEL #LZOOTL8WSLK	ELKAY WATER SENTRY VII FILTER KIT MODEL #EWF172	1, 2, 3, 4

WATER COOLER FOOTNOTES:

1. REFER TO SPECIFICATIONS FOR REQUIREMENTS OF MATERIALS, COLOR, FINISHES, INSTALLATION, APPROVED EQUAL MANUFACTURERS, ETC.
2. PROVIDE COMPLETE WITH WALL MOUNTING FRAME/ CHAIR CARRIER, SUPPLY AND WASTE ROUGH-IN ASSEMBLIES IN ACCORDANCE WITH SPECIFICATIONS.
3. THE 3 CONTRACTOR SHALL FURNISH AND INSTALL POINT OF USE - SEDIMENT -TASTE/ODOR WATER FILTER CARTRIDGE KIT ASSEMBLY (ELKAY MODEL# F20 OR APPROVE EQUAL) ON WATER SUPPLY TO WATER CLOSER. FILTER CAPACITY IS APPROXIMATELY 500 GALLONS
4. PROVIDE COMPLETE WITH LIGATURE RESISTANT COMPONENTS, WATER SUPPLY AND WASTE ROUGH-IN ASSEMBLIES. THE 3 CONTRACTOR SHALL FURNISH AND SET THE SPECIFIED FIXTURE AND MAKE ALL ROUGH-IN AND WASTE CONNECTIONS WITH ASSOCIATED FIXTURE ASSEMBLY REQUIRED FOR PROPER OPERATION AND FUNCTION. COORDINATE THE INSTALLATION OF A QUAD 120V GFI ELECTRICAL RECEPTACLES OUTLET BOX WITH 4 CONTRACTOR.

WALL HYDRANTS AND HOSE BIBBS SCHEDULE					
FIXTURE IDENTIFICATION	DESCRIPTION	MOUNTING REQUIREMENTS	FIXTURE MANUFACTURER AND MODEL NUMBER (OR APPROVED EQUAL)	FIXTURE ACCESSORIES MAKE AND MODEL NUMBER (OR APPROVED EQUAL)	FOOTNOTES
WH-1	EXTERIOR WALL HYDRANT POLISHED BRONZE OR STAINLESS STEEL WALL BOX AND COVER (BUILDING PERIMETER)	24" ABOVE FINISH GRADE RECESSED WALL MOUNTED	(JR SMITH, WOODFORD & ZURN) NON-FREEZE, ANTI-SIPHON I/W BACKFLOW PREVENTION AND ALL BRONZE PARTS ZURN MODEL #Z-1300-3 / #Z-1300-13	REMOVABLE KEY FOR LOCKING COVER AND HYDRANT OPERATION WITH "WATER" STAMPED IN COVER	1, 2
WH-2	INTERIOR WALL HYDRANT CHROME PLATED RECESSED WALL BOX AND COVER (TOILET FACILITIES)	18" ABOVE FINISH FLOOR RECESSED WALL MOUNTED	(JR SMITH, WOODFORD & ZURN) NICKEL BRONZE STAINLESS STEEL, MODERATE CLIMATE, ANTI-SIPHON WITH BACKFLOW PREVENTION SHALLOW WALL BOX AND COVER ZURN MODEL #Z-1300-3	REMOVABLE KEY FOR LOCKING COVER AND HYDRANT OPERATION WITH "WATER" STAMPED IN COVER	1, 3
HB-1	GENERAL BUILDING AND MECHANICAL/UTILITY SERVICE AREAS	42" ABOVE FINISH FLOOR WALL MOUNTED	(CHICAGO FAUCET, T & S & ZURN) CHROME PLATED LEVER HANDLE WITH HOSE END OUTLET ZURN #Z-80501 OR #Z80701	-----	1, 4

HYDRANTS AND HOSE BIBB FOOTNOTES:

1. REFER TO SPECIFICATIONS FOR REQUIREMENTS OF MATERIALS, COLOR, FINISHES, INSTALLATION, APPROVED EQUAL MANUFACTURERS, ETC..
2. INSTALL WALL HYDRANT WALL BOX AND COVER FLUSH WITH EXTERIOR WALL FINISH. THE DEPTH OF THE VALVE STEM SHALL BE COORDINATED WITH THE THICKNESS OF THE EXTERIOR WALL AND THE DEPTH TO VALVE STOP WITHIN THE INTERIOR SPACE BEYOND THE INSULATION ENVELOPE. EXTEND 3/4" COLD WATER SUPPLY WITH ISOLATION SHUT-OFF VALVE TO THE WALL HYDRANT.
3. INSTALL THE INTERIOR WALL HYDRANT SHALLOW WALL BOX AND COVER FLUSH WITH INTERIOR WALL FINISH. EXTEND AND CONNECT 1/2" OR 3/4" HOT OR COLD WATER SUPPLY AS DESIGNATED TO INTERIOR WALL HYDRANT.
4. EXTEND 1/2" OR 3/4" HOT OR COLD WATER SUPPLY AS DESIGNATED WITH CONCEALED OR EXPOSED PIPING TO THE HOSE BIBB AS NOTED ON DRAWING.

LAVATORIES, SINKS, AND SERVICE RECEPTORS					
FIXTURE IDENTIFICATION	DESCRIPTION	MOUNTING REQUIREMENTS	FIXTURE MANUFACTURER AND MODEL NUMBER (OR APPROVED EQUAL)	FIXTURE ACCESSORIES MAKE AND MODEL NUMBER (OR APPROVED EQUAL)	FOOTNOTES
L-1	LAVATORY 20" x 22" - 4" OC - SOLID SURFACE / STAINLESS STEEL LIGATURE-RESISTANT (SECOND FLOOR TLT FACILITY)	ADA ACCESSIBLE WALL MOUNTED	(ACORN, BRADLEY OR WILLOUGHBY) 20" x 22" LAVATORY - 4" OC SOLID SURFACE / STAINLESS STEEL BOD: WILLOUGHBY - MODEL #LRHL-2220-LRFC-IR-TMC	(ACORN, BRADLEY OR WILLOUGHBY) 4" OC HARD WIRE ELECTRIC IR SENSOR OPERATED LIGATURE-RESISTANT FAUCET (BOD: WILLOUGHBY)	1, 3, 4, 5, 10
L-2	LAVATORY 20" x 22" - 4" OC - SOLID SURFACE / STAINLESS STEEL LIGATURE-RESISTANT RESIDENT/ STAFF TLT FACILITY	ADA ACCESSIBLE WALL MOUNTED	(ACORN, BRADLEY OR WILLOUGHBY) 20" x 22" LAVATORY - 4" OC SOLID SURFACE / STAINLESS STEEL BOD: WILLOUGHBY - MODEL #LRHL-2220-LRFC-IR-TMC	(ACORN, BRADLEY OR WILLOUGHBY) 4" OC HARD WIRE ELECTRIC IR SENSOR OPERATED LIGATURE-RESISTANT FAUCET (BOD: WILLOUGHBY)	1, 3, 4, 5, 10
L-3	LAVATORY 20" x 22" - 4" OC - SOLID SURFACE / STAINLESS STEEL LIGATURE-RESISTANT RESIDENT/ STAFF TLT FACILITY	ADA ACCESSIBLE WALL MOUNTED	(ACORN, BRADLEY OR WILLOUGHBY) 20" x 22" LAVATORY - 4" OC SOLID SURFACE / STAINLESS STEEL BOD: WILLOUGHBY - MODEL #LRHL-2220-LRFC-IR-TMC	(ACORN, BRADLEY OR WILLOUGHBY) 4" OC HARD WIRE ELECTRIC IR SENSOR OPERATED LIGATURE-RESISTANT FAUCET (BOD: WILLOUGHBY)	1, 3, 4, 5, 10
L-4	LAVATORY 30" x 22" - 4" OC W/ CW FAUCET SOLID SURFACE (ICR REST ROOM)	ADA ACCESSIBLE WALL MOUNTED	(ACORN, BRADLEY OR WILLOUGHBY) 22" x 30" LAVATORY - 4" OC SOLID SURFACE / STAINLESS STEEL BOD: WILLOUGHBY - MODEL #WELS-2230-WALL-4C-SP	(ACORN, BRADLEY OR WILLOUGHBY) 4" OC HARD WIRE ELECTRIC IR SENSOR OPERATED LIGATURE-RESISTANT FAUCET (BOD: WILLOUGHBY)	1, 3, 4, 5, 10
S-1	BREAK ROOM SINK CASEWORK DROP-IN SINK STAINLESS STEEL 8"OC (STAFF BREAK ROOM)	CASEWORK COUNTERTOP MOUNTED	(ADVANCED TABCO, ELKAY OR JUST) 25" x 22" x 8" DROP-IN SINGLE BASIN STAINLESS STEEL KITCHEN SINK ELKAY MODEL #LR2522 -4	(CHICAGO FAUCET, T & S OR ZURN) CLASSIC SERIES SINGLE LEVER FAUCET W/ SPRAY ZURN MODEL #Z7872C-XL-LA	1, 2, 6, 7, 9
SS-1	SERVICE RECEPTOR BASIN 24" x 24" X 10" HIGH HIGH DENSITY MOLDED COMPOSITE PLASTIC	FLOOR MOUNTED	(CRANE-FIAT, STERN WILLIAMS & ZURN) MOP SERVICE RECEPTOR BASIN ZURN LIGHT COMMERCIAL MODEL #Z1996-24-BH-HH-SDL-WG	(CHICAGO FAUCET, MOEN & ZURN) 8" OC SERVICE SINK FAUCET VACUUM BREAKER HOSE-END SPOUT ZURN - MODEL #Z843M1-XL-CS-SH	1, 2, 7, 8, 9

LAVATORIES, SINKS, AND SERVICE SINKS FOOTNOTES:

1. REFER TO SPECIFICATIONS FOR REQUIREMENTS OF MATERIALS, COLOR, FINISHES, INSTALLATION, APPROVED EQUAL MANUFACTURERS, ETC..
2. PROVIDE COMPLETE WITH SUPPLY AND WASTE ROUGH-IN ASSEMBLIES IN ACCORDANCE WITH SPECIFICATIONS.
3. THE .3 CONTRACTOR WILL FURNISH AND INSTALL AN ASSE 1070 APPROVED THERMOSTATIC MIXING VALVE FOR MULTIPLE FAUCETS OR INDIVIDUAL FAUCET AS THE APPLICATION WARRANTS.
4. THE .3 CONTRACTOR SHALL FURNISH AND INSTALL SECURITY ENCLOSURE ASSEMBLY TO CONCEAL WATER , WASTE, VALVES AND FAUCET COMPONENTS BENEATH THE FIXTURE AS PER MANUFACTURER'S REQUIREMENTS.
5. PROVIDE COMPLETE WITH CHAIR CARRIER, SUPPLY AND WASTE ROUGH-IN ASSEMBLIES IN ACCORDANCE WITH SPECIFICATIONS.
6. CASEWORK, COUNTERTOP, AND COUNTERTOP SINK CUT-OUT BY THE .1 CONTRACTOR . THE SINK, FAUCET, ACCESSORIES, ROUGH-IN, AND FINAL CONNECTIONS BY THE .3 CONTRACTOR.
7. PROVIDE TAMPER-RESISTANT COVER TO CONCEAL ALL EXPOSED SUPPLY, DRAIN AND SENSOR HARDWARE ASSEMBLIES BELOW THE DESIGNATED LAVATORIES AS SCHEDULED AND SPECIFIED.
8. PROVIDE SERVICE RECEPTOR COMPLETE WITH THE FOLLOWING ACCESSORIES: E-77-AA VINYL BUMPER GUARD, 1453 BB FIAT STAINLESS STEEL STRAINER, STAINLESS STEEL WALL GUARDS (TWO WALL PANELS), AND 832AA HOSE BRACKET.
9. PROVIDE CHECK VALVES ON WATER SUPPLY LINES TO SINKS AND SERVICE RECEPTOR MIXING FAUCETS TO PREVENT POTENTIAL TEMPERATURE BLEED THROUGH. (TYPICAL)
10. THE .3 CONTRACTOR SHALL PROVIDE AND INSTALL THE REQUIRED ELECTRIC COMPONENTS (120V / LOW VOLTAGE) FOR THE SPECIFIED AND SELECTED MANUFACTURER TO OPERATE THE INDIVIDUAL OR MULTIPLE HARDWARE SENSOR OPERATED FAUCET ASSEMBLIES. REFER TO THE WATER PIPING PLANS FOR PROPOSED TRANSFORMER LOCATIONS. THE .3 CONTRACTOR SHALL COORDINATE THE TRANSFORMER LOCATIONS AND ELECTRICAL POWER SUPPLY REQUIREMENTS WITH THE .4 CONTRACTOR. THE LOW VOLTAGE SYSTEM SHALL BE COMPLETE WITH APPROVED REDUCED VOLTAGE TRANSFORMERS, WIRING, JUNCTION BOXES AND CONDUIT FOR WIRING EXPOSED OR CONCEALED IN WALLS OR CEILINGS AS REQUIRED. THE .3 CONTRACTOR SHALL EXTEND AND CONNECT THE REQUIRED LOW VOLTAGE WIRING TO THE FAUCETS AS PER THE MANUFACTURER RECOMMENDATIONS AND INSTALLATION INSTRUCTIONS.

FIXTURE IDENTIFICATION	APPLICATION AND LOCATION	DESCRIPTION	FIXTURE MANUFACTURER AND MODEL NUMBER (OR APPROVED EQUAL)	FOOTNOTES
FD-1	GENERAL AREA FLOOR DRAIN (TOILET & SHOWER FACILITIES)	COATED CAST IRON BODY WITH ADJUSTABLE POLISHED NICKEL- BRONZE STRAINER W/ SEDIMENT BUCKET AND CLAMPING COLLAR	ZURN MODEL #ZN-415-6B-Y W/ TYPE 'B' STRAINER	1, 2, 3, 4
FD-2	MECHANICAL EQUIPMENT / UTILITY ROOM AREAS (FLOOR DRAIN W/ FUNNEL) SLAB ON GRADE	MEDIUM DUTY COATED CAST IRON BODY WITH 9"DIAMETER FLAT SLOTTED GRATE TOP. REMOVABLE SEDIMENT BUCKET AND 4" ROUND FUNNEL CONVERTING ASSEMBLY	ZURN MODEL #Z-551-Y W/ Z-328-4 JR SMITH #2270-B, 3580	1, 2
FD-3	MECHANICAL EQUIPMENT / UTILITY ROOM AREAS (FLOOR DRAIN W/ FUNNEL) ABOVE FINISH SPACES	MEDIUM DUTY COATED CAST IRON BODY WITH 9" DIAMETER FLAT SLOTTED GRATE TOP. FRAME, REMOVABLE SEDIMENT BUCKET AND 4" ROUND CONVERTING ASSEMBLY	ZURN MODEL #Z-550-Y W/ Z-384-4 JR SMITH #2111-B-3580	1, 2
FD-4	MECHANICAL EQUIPMENT / UTILITY ROOM AREAS (AREA FLOOR DRAIN) SLAB ON GRADE	MEDIUM DUTY COATED CAST IRON BODY WITH 9"DIAMETER FLAT SLOTTED GRATE TOP AND REMOVABLE SEDIMENT BUCKET	ZURN MODEL #Z-551-Y JR SMITH #2270-B	1, 2
LSD-1	LINEAR SHOWER DRAIN 3-1/2" x 60" STAINLESS STEEL WITH LIGATURE-RESISTANT GRATE COVER (RESIDENT SHOWER AREA)	LINEAR TRENCH FLOOR DRAIN 3-1/2" x 60" - 14 GAUGE STAINLESS STEEL WITH LIGATURE - RESISTANT GRATE COVER AND 2" WASTE OUTLET (RESIDENT SHOWER AREA)	(JR SMITH, WILLOUGHBY, ZURN) WILLOUGHBY MODEL #LRTD-60	1, 2

FLOOR DRAIN FOOTNOTES:

1. REFER TO SPECIFICATIONS FOR REQUIREMENTS OF MATERIALS, COLOR, FINISHES, INSTALLATION, APPROVED EQUAL MANUFACTURERS, ETC.
2. PROVIDE COMPLETE WITH INDIVIDUAL DEEP SEAL TRAP FOR ALL FLOOR DRAINS AND FLOOR SINKS UNLESS OTHERWISE NOTED.
3. PROVIDE VANDAL RESISTANT SCREWS WITH THE SCHEDULED AND SPECIFIED DRAINS, (TYPICAL)
4. PROVIDE SUPPLY TYPE TRAP PRIMER VALVE ASSEMBLY AND WATER SUPPLY PIPING TO THE SCHEDULED AND SPECIFIED FLOOR DRAINS.

SHOWER FIXTURES					
FIXTURE IDENTIFICATION	DESCRIPTION	MOUNTING REQUIREMENTS	FIXTURE MANUFACTURER AND MODEL NUMBER (OR APPROVED EQUAL)	FIXTURE ACCESSORIES MAKE AND MODEL NUMBER (OR APPROVED EQUAL)	FOOTNOTES
SH-1	BUILT-IN PLACE SHOWER STALL RESIDENT SHOWER FACILITY LIGATURE-RESISTANT (2nd FLOOR SHOWER AREA)	STANDARD ACCESSIBLE	BUILT-IN PLACE (REFER TO ARCHITECTURAL DRAWINGS FOR DETAILS)	(ACORN, BRADLEY, WILLOUGHBY) INSTUTIONAL SHOWER HEAD ANTI-LIGATURE TYPE BOD: WILLOUGHBY MODEL #LRSH	1, 2, 3
SH-2	BUILT-IN PLACE SHOWER STALL RESIDENT SHOWER FACILITY LIGATURE-RESISTANT (2nd FLOOR SHOWER AREA)	ADA HANDICAP ACCESSIBLE	BUILT-IN PLACE (REFER TO ARCHITECTURAL DRAWINGS FOR DETAILS)	(ACORN, BRADLEY, WILLOUGHBY) INSTUTIONAL SHOWER HEAD ANTI-LIGATURE TYPE BOD: WILLOUGHBY MODEL #LRSH	1, 2, 3

SHOWER FIXTURES FOOTNOTES:

1. REFER TO SPECIFICATIONS FOR REQUIREMENTS OF MATERIALS, COLOR, FINISHES, INSTALLATION, APPROVED EQUAL MANUFACTURERS, ETC.
2. PROVIDE COMPLETE SUPPLY AND WASTE ROUGH-IN ASSEMBLIES FOR SHOWER HEADS WITH REMOTE THERMOSTATIC SHOWER CONTROL VALVE & RECESSED CABINET ASSEMBLY IN ACCORDANCE WITH DRAWINGS AND SPECIFICATIONS.
3. SHOWER HEADS SHALL BE INSTITUTIONAL ANTI-LIGATURE TYPE AS SCHEDULED AND SPECIFIED.

PLUMBING FIXTURE CONNECTION SCHEDULE		
<u>FIXTURE</u>	<u>WATER</u>	<u>WASTE, SOIL & VENT (UNO)</u>
WATER CLOSET	1" C	4"S & 2"V
URINAL	3/4" C	2"W & V
LAVATORY	1/2"H & C	1 1/2"W & V
SINK	AS NOTED	AS NOTED
ERVICE RECEPTOR BASIN / SINK	1/2"H & C	3"W - 2"V
SHOWER	1/2"H & C	2"W - 2"V
WATER COOLER	1/2" C	1 1/2"W & V
FLOOR DRAIN	AS NOTED	AS NOTED
FLOOR SINK	AS NOTED	AS NOTED
WALL HYDRANT (EXTERIOR)	3/4" C	----
HOSE BIBB (INTERIOR)	3/4" C	----

PLUMBING FIXTURE ABBREVIATIONS

W	WATER CLOSET	SS	SERVICE SINK OR SERVICE RECEPTOR
L	LAVATORY	FD	FLOOR DRAIN
S	SINK	WH	WALL HYDRANT
U	URINAL	SH	SHOWER
D	WATER COOLER	HB	HOSE BIBB

NOTES:


SUFFIXES FOR FIXTURE LETTERS AS SPECIFIED.

REFER TO PROJECT SPECIFICATIONS FOR PLUMBING
ACCESSORIES, SPECIALTIES AND EQUIPMENT.

REFERENCE NOTES:

1. ALL ITEMS TO BE CONSIDERED BB#1 UNLESS NOTED OTHERWISE.
2. REFER TO P-001 FOR PLUMBING SYMBOLS, ABBREVIATIONS, NOTES AND DETAILS . (TYPICAL)

RECORD REVISIONS



PROFESSIONAL'S SIGNATURE DATE

UpStreet ARCHITECTS, INC.

541 PHILADELPHIA ST. 911 MENOHER BLVD.
INDIANA, PA 15701 JOHNSTOWN, PA 15905

COMMONWEALTH OF PENNSYLVANIA
DEPARTMENT OF GENERAL SERVICES
HARRISBURG, PENNSYLVANIA

D.G.S. PROJECT No.

C-0588-0015 PHASE 1

THE YOUTH DEVELOPMENT CENTER

INNOVATIONS TO ZIMMERMAN-BINGAMAN (ZB) COTTAGE

NGAMAN (ZB) COTTAGE
DEPARTMENT of HUMAN SERVICES

TYRONE TOWNSHIP, PERRY COUNTY, PA

SCHEDULES - PLUMBING

CONTRACTOR SHALL FIELD VERIFY ALL DIMENSIONS VARIANCE FROM CONTRACT DOCUMENTS NOT PERMITTED WITHOUT PROFESSIONAL & BUREAU OF CONSTRUCTION APPROVAL.	DRAWN BY S. KORMANIK	DATE 27 JUNE 2023	SHEET No. <div style="font-size: 2em; font-weight: bold; text-align: center;">P-701</div>
	CHECKED BY W. MINAHAN	SCALE AS NOTED	