


1 THIRD FLOOR - NEW WORK - FIRE PROTECTION

Scale: 3/16" = 1'-0"



DRY SPRINKLER VALVE PIPING DETAIL
NOT TO SCALE

- NOTES:**
- ALL ITEMS ARE TO BE CONSIDERED B8#1 UNLESS NOTED OTHERWISE.
 - REFER TO FP-001 FOR FIRE SUPPRESSION SYMBOLS, ABBREVIATIONS, NOTES AND DETAILS. REFER TO TYPICAL SPRINKLER CONTROL AND TEST VALVE ASSEMBLY DETAIL #2 ON DRAWING FP-200. (TYPICAL)
 - THE BUILDING SHALL BE FULLY PROTECTED WITH AN AUTOMATIC FIRE SPRINKLER SYSTEM IN ACCORDANCE WITH THE APPLICABLE CONSTRUCTION CODES, NFPA STANDARDS AND THE FACILITY'S INSURANCE CARRIER REQUIREMENTS. THE FIRE SPRINKLERS ARE SHOWN FOR BID PURPOSES ONLY. (TYPICAL)
 - ATTIC (WET) SYSTEM AREA: 162 SF ± (STAIRWELL)
ATTIC (DRY) SYSTEM AREA: 2942 SF ±
 - THE FIRE SUPPRESSION SYSTEM SHALL BE HYDRAULICALLY DESIGNED, CALCULATED AND SIZED IN ACCORDANCE TO NFPA 13.

RECORD REVISIONS			
PROFESSIONAL'S SIGNATURE DATE			
UpStreet ARCHITECTS, INC. 541 PHILADELPHIA ST. 911 MENOHER BLVD. INDIANA, PA 15701 JOHNSTOWN, PA 15905			
COMMONWEALTH OF PENNSYLVANIA DEPARTMENT OF GENERAL SERVICES HARRISBURG, PENNSYLVANIA			
D.G.S. PROJECT No. C-0588-0015 PHASE 1			
LOYSVILLE YOUTH DEVELOPMENT CENTER- RENOVATIONS TO ZIMMERMAN- BINGAMAN (ZB) COTTAGE DEPARTMENT OF HUMAN SERVICES LOYSVILLE, TYRONE TOWNSHIP, PERRY COUNTY, PA			
THIRD FLOOR PLAN - NEW WORK - FIRE			
VERIFY SCALE BAR IS ONE (1) INCH LONG ON ORIGINAL DRAWING: 0 1 IF BAR IS NOT ONE (1) INCH LONG, ADJUST SCALE ACCORDINGLY	CONTRACTOR SHALL FIELD VERIFY ALL DIMENSIONS. VARIANCE FROM CONTRACT DOCUMENTS NOT PERMITTED WITHOUT PROFESSIONAL & BUREAU OF CONSTRUCTION APPROVAL.	DRAWN BY S. KORMANIK CHECKED BY W. MINAHAN	DATE 27 JUNE 2023 SCALE AS NOTED
	SHEET No. FP-203		