



- NOTES:**
- ALL ITEMS TO BE CONSIDERED B8#1 UNLESS NOTED OTHERWISE.
  - REFER TO FP-001 FOR FIRE SUPPRESSION SYMBOLS, ABBREVIATIONS, NOTES AND DETAILS. REFER TO TYPICAL SPRINKLER CONTROL AND TEST VALVE ASSEMBLY DETAIL 'A' ON DRAWING FP-200. (TYPICAL)
  - THE BUILDING SHALL BE FULLY PROTECTED WITH AN AUTOMATIC FIRE SPRINKLER SYSTEM IN ACCORDANCE WITH THE APPLICABLE CONSTRUCTION CODES, NFPA STANDARDS AND THE FACILITY'S INSURANCE CARRIER REQUIREMENTS. THE FIRE SPRINKLERS ARE SHOWN FOR BID PURPOSE ONLY. (TYPICAL)
  - FIRST FLOOR AREA: (WET) FIRE SPRINKLERS 2858 SF ±  
FIRST FLOOR AREA: (DRY) FIRE SPRINKLERS 381 SF ±
  - THE FIRE SUPPRESSION PIPING SYSTEM SHALL BE HYDRAULICALLY DESIGNED, CALCULATED AND SIZED IN ACCORDANCE TO NFPA 13.
  - APPROVED INSTITUTIONAL ANTI-LIGATURE TYPE FIRE SPRINKLER HEADS WILL BE FURNISHED AND INSTALLED IN ALL OCCUPIED AND ACCESSIBLE AREAS THROUGHOUT THE FACILITY UNLESS OTHERWISE NOTED AND SCHEDULED. REFER TO SPRINKLER SCHEDULE ON FP-001.

**1 FIRST FLOOR PLAN - NEW WORK - FIRE PROTECTION**  
Scale: 3/16" = 1'-0"



<b>VERIFY SCALE</b>			
BAR IS ONE (1) INCH LONG ON ORIGINAL DRAWING:			
0 1			
IF BAR IS NOT ONE (1) INCH LONG, ADJUST SCALE ACCORDINGLY			
CONTRACTOR SHALL FIELD VERIFY ALL DIMENSIONS. VARIANCE FROM CONTRACT DOCUMENTS NOT PERMITTED WITHOUT PROFESSIONAL & BUREAU OF CONSTRUCTION APPROVAL.	DRAWN BY S. KORMANIK	DATE 27 JUNE 2023	SHEET No. <b>FP-201</b>
	CHECKED BY W. MINAHAN	SCALE AS NOTED	

RECORD REVISIONS	
PROFESSIONAL'S SIGNATURE    DATE	
<b>UpStreet ARCHITECTS, INC.</b> 541 PHILADELPHIA ST.    911 MENOHER BLVD. INDIANA, PA 15701    JOHNSTOWN, PA 15905	
COMMONWEALTH OF PENNSYLVANIA DEPARTMENT OF GENERAL SERVICES HARRISBURG, PENNSYLVANIA	
D.G.S. PROJECT No. <b>C-0588-0015 PHASE 1</b>	
<b>LOYSVILLE YOUTH DEVELOPMENT CENTER- RENOVATIONS TO ZIMMERMAN- BINGAMAN (ZB) COTTAGE</b> DEPARTMENT OF HUMAN SERVICES LOYSVILLE, TYRONE TOWNSHIP, PERRY COUNTY, PA	
<b>FIRST FLOOR PLAN - NEW WORK - FIRE</b>	