

PACKAGED DUCTLESS MINI SPLIT SYSTEM HEAT PUMP SCHEDULE													
SYMBOL	MFG.	MODEL NO.	CFM	COOLING CAPACITY		ELECTRICAL CHARACTERISTICS						REMARKS	
				TOTAL MBH	S.E.E.R.	COMPRESSOR		O.D. FAN		POWER SUPPLY			VOLTAGE
						R.L.A.	L.R.A.	H.P.	F.L.A.	MCA	MFA		
CC-1	* MITSUBISHI	NTXCKS12A112A	335	12.0	—	—	—	—	—	0.3	—	230-1ϕ	①②④⑤
CC-2	* MITSUBISHI	NTXCKS12A112A	335	12.0	—	—	—	—	—	0.3	—	230-1ϕ	①②④⑤
HP-1	* MITSUBISHI	NTXMPH24A132CA	—	23.6	17.25	—	—	—	—	31.5	40	230V-1ϕ	①③

REMARKS


- UNIT SHALL BE PROVIDED WITH THE FOLLOWING ACCESSORIES: TIME DELAY RELAY, LOW AMBIENT CONTROLLER, WINTER START CONTROL EVAPORATOR DEFROST CONTROL KIT, HIGH LOW PRESSURE CUT-OUT SWITCH AND WALL BRACKET.
- REFRIGERANT LINE SETS SHALL BE SIZED PER MANUFACTURERS RECOMMENDATIONS AND SHALL BE INSULATED WITH 1" AP ARMAFLEX .
- WIRED AND INTERLOCKED WITH INDOOR UNITS CC-X.
- WALL MOUNTED THERMOSTAT WITH REMOTE CONTROL.
- INDOOR UNIT POWERED BY OUTDOOR UNIT. WIRED BY E.C.

* OR APPROVED EQUAL


EXHAUST FAN SCHEDULE										
SYMBOL	SERVING	TYPE *	C.F.M.	E.S.P.	R.P.M.	WATTS OR HP	VOLTAGE	REFERENCE		REMARKS
								MFG.	MODEL NO.	
CEF-1	RESTROOM/JAN. CL.	C	125	.25	975	115	115/60/1	GREENHECK	SP-B125	NOTE 1, 3, 4
CEF-2	RESTROOM/BREAK RM.	C	150	.25	1050	150W	115/60/1	GREENHECK	SP-B150	NOTE 1, 3, 4
CEF-3	TOOL STORAGE	C	450	.25	1050	108W	115/60/1	GREENHECK	SP-A290	NOTE 2, 3, 4
ILF-1	MECHANICS SHOP	IL	740 *2630	.50	VAR.	1 HP	115/60/1	GREENHECK	SQ-160-VG	NOTE 5, 6, 8
ILF-2	WASH BAY	IL	875 *4450	.50	VAR.	2 HP	230/60/1	GREENHECK	SQ-160-VG	NOTE 5, 6, 8
ILF-3	GARAGE BAY #1	IL	1600 *7450	.50	VAR.	3 HP	IN-230/60/1 OUT-230/60/3	GREENHECK	SQ-18	NOTE 5, 6, 7, 8
ILF-4	GARAGE BAY #2	IL	2120 *9880	.50	VAR.	5 HP	IN-230/60/1 OUT-230/60/3	GREENHECK	SQ-24	NOTE 5, 6, 7, 8

- * C = CEILING MOUNTED RT = ROOF TOP WM = WALL MOUNTED IL = IN-LINE
- NOTES:
- CONTROLLED BY LIGHTING CONTROL FOR TOILET ROOMS/SHOWER RM. REFER TO ELECTRICAL DRAWING FOR INFORMATION.
 - CONTROLLED BY REVERSE ACTING THERMOSTAT IN UTILITY ROOM.
 - CONTROLLED BY DEDICATED SWITCH IN BREAK ROOM, JANITORS CLOSET AND TOOL STORAGE ROOM.
 - PROVIDE WITH BACKDRAFT DAMPER, INSECT SCREEN AND WALL CAP OR BRICK VENT AS SPECIFIED BY ARCHITECT. MANUFACTURED BY GREENHECK.
 - CONTROLLED BY OCCUPANCY SENSOR, CO SENSOR, NOX SENSOR, REVERSE ACTING THERMOSTAT & DEDICATED SWITCH. PROVIDE WITH LOUVER, BACKDRAFT DAMPER, INSECT SCREEN AND WALL CAP OR BRICK VENT AS SPECIFIED BY ARCHITECT. MANUFACTURED BY GREENHECK.
 - TWO STAGE OPERATION FIRST STAGE: OCCUPIED VENTILATION, SECOND STAGE: EMERGENCY & HEAT REMOVAL VENTILATION. FAN CONTROLS REQUIRE 0-10V INPUT FOR STAGING.
 - PROVIDE WITH VFD FOR 230V-1 ϕ POWER SUPPLY TO CONVERT TO 230V-3 ϕ FOR FAN POWER.
 - FAN CONTROL BY 0-10V CONTROL INPUT FOR FIRST STAGE - OCCUPIED VOLUME AND EMERGENCY/HEAT REMOVAL - SECOND STAGE CONTROL, ONCE STAGES ARE SET, BALANCE.

* OR APPROVED EQUAL



TYPICAL THRU THE WALL CONCENTRIC VENT/FLUE KIT DETAILS
SCALE: NONE




DUCTWORK CONNECTION DETAILS
NO SCALE

All documents prepared by Brehm-Lebo Engineering, Inc., are instruments of service with respect to this project. They are not intended or represented to be suitable for reuse by owners, contractors or others on extensions of this Project or on any other project. Any reuse without written verification or adoption by Brehm-Lebo Engineering, Inc., will be at owners sole risk and without liability or legal exposure to Brehm-Lebo Engineering, Inc., and Owner shall indemnify, and hold harmless, Brehm-Lebo Engineering, Inc., from all claims, damages, losses and expenses arising out of or resulting therefrom.



PENNSYLVANIA ONE CALL SYSTEM, INC.
1-800-242-1776
PENNSYLVANIA LAW REQUIRES NOT LESS THAN THREE NOR MORE THAN TEN WORKING DAYS NOTICE BEFORE EXCAVATION
REFER TO PENNSYLVANIA ONE CALL SYSTEM, INC. UTILITY LOCATIONS SHOWN HEREON ARE APPROXIMATE



- NOTE:
- FURNISH AND INSTALL VISSMANN/RENNAI TUBE CONDENSING TYPE HIGH EFFICIENCY GAS BOILER WITH ALL APERTENANCES AS REQUIRED BY APPLICABLE CODES AND MANUFACTURE'S RECOMMENDED INSTALLATION REQUIREMENTS.
 - PROVIDE PLUMBING MECHANICAL PACKAGE AS REQUIRED BY RADIANT SYSTEM MANUFACTURER.
 - PROVIDE BALANCING VALVES ON ALL LOOPS.
 - VERIFY ALL PIPING SIZING AND MANIFOLD SUPPLY PIPING SIZE WITH SYSTEM MANUFACTURER PRIOR TO BIDDING.
 - ARCHITECT SHALL PROVIDE INSULATED SLAB AS PER MANUFACTURERS INSTALLATION INSTRUCTIONS. COORDINATE INSTALLATION REQUIREMENTS WITH ARCHITECTURAL DRAWINGS.
 - LOOP MANIFOLDS SHALL BE INSTALLED ON THE WALL OR IN THE FLOOR AS RECOMMENDED BY SYSTEM MANUFACTURER AND OWNERS DIRECTION. SEE APPROXIMATE LOCATIONS ON DRAWING H1. VERIFY INSTALLATION LOCATION WITH OWNER AND MANUFACTURERS REPRESENTATIVE PRIOR TO INSTALLATION AND CONSTRUCTION.
 - THIS DETAIL IS A SCHEMATIC OF A TYPICAL INSTALLATION AND MAY NOT INCLUDE ALL ITEMS REQUIRED FOR A COMPLETE INSTALLATION FOR EACH APPLICATION. THE CONTRACTOR SHALL VERIFY ALL REQUIREMENTS WITH THE MANUFACTURERS REPRESENTATIVE FOR A COMPLETE AND FUNCTIONAL SYSTEM TO MEET THE DESIGN INTENT FOR THIS PROJECT.
 - THE CONTRACTOR SHALL PROVIDE SHUT-OFF VALVES AT LOCATIONS REQUIRED FOR MAINTENANCE OF ALL ITEMS.
 - CONTRACTOR SHALL PROVIDE ALL CONTROLS, SENSORS, LOW VOLTAGE WIRING, VALVES, ETC. TO PROVIDE THE HYDRONIC HEATING COIL WITH REQUIRED TEMPERATURE FLUID AND RADIANT SLAB SYSTEM MIXED DOWN TO TEMPERATURE AS RECOMMENDED BY THE SYSTEM MANUFACTURER FOR SLAB HEATING AND SNOW MELTING SYSTEMS AS REQUIRED.

TYPICAL SLAB HEATING SYSTEM SCHEMATIC DETAIL
NO SCALE

HORIZONTAL UNIT HEATER SCHEDULE

SYMBOL	TYPE *	MFG.	MODEL NO.	C.F.M.	GAS CAPACITIES (MBH)		ELECTRICAL DATA			REMARKS
					INPUT	OUTPUT	FAN MOTOR		VOLTAGE	
							H.P.	AMPS		
HUH-1	H	* MODINE	HDS-45	720	45	36.9	1/15	3.75	120V-1 ϕ	MOUNT TOP OF UNIT 18" MIN. FROM CEILING. CONCENTRIC VENT ARRANGEMENT THROUGH THE WALL.
HUH-2	H	* MODINE	HDS-60	1650	60	49.2	1/12	3.3	120V-1 ϕ	MOUNT TOP OF UNIT 18" MIN. FROM CEILING. CONCENTRIC VENT ARRANGEMENT THROUGH THE WALL.
HUH-3	H	* MODINE	HDS-100	1650	100	82.0	1/6	5.05	120V-1 ϕ	MOUNT TOP OF UNIT 18" MIN. FROM CEILING. CONCENTRIC VENT ARRANGEMENT THROUGH THE WALL.

* H= HORIZONTAL C= CABINET

NOTE : PROVIDE WITH WALL MONUNTED THERMOSTAT, MOUNTED AT 42" ABOVE FINISHED FLOOR. PROVIDE WITH 2 STAGE GAS VALVE.

* OR APPROVED EQUAL

EXHAUST GRILL SCHEDULE

SYMBOL	DESCRIPTION	C.F.M. RANGE	NECK SIZE	MANUFACTURER	MODEL	MATERIAL	FINNISH	REMARKS
EG-1	EXHAUST GRILLE	1570 2400	22X22	TUTTLE & BAILEY	CRE500	ALUMINUM	WHITE	① ②
EG-1	EXHAUST GRILLE	2400 3500	24X24	TUTTLE & BAILEY	CRE500	ALUMINUM	WHITE	① ②

- NOTES:
- PROVIDE WITH FRAME TO SECURE TO DUCTWORK.
 - PROVIE ALL ALUMINUM CONSTRUCTION.
 - PROVIDE WITH INTEGRAL OPPOSED BLADE BALANCING DAMPER.

DRAWING KEY
CD- = DIFFUSER, GRILLE & REGISTER TYPE
250 = AIR QUANTITY IN CFM

* OR APPROVED EQUAL

ELECTRIC HEAT SCHEDULE

NOTE: ALL ELECTRIC HEATERS SHALL HAVE POSITIVE SHUT-OFF AND OFF POSITION.

SYMBOL	SERVING	TYPE *	KW	VOLTAGE	REFERENCE		REMARKS
					MFG.	MODEL NO.	
WIH-1	RESTROOM	W	1.5	115/60/1	* QMARK	CWH3150F	INTEGRAL THERMOSTAT POSITIVE SHUT-OFF
WIH-2	RESTROOM	W	2.0	230/60/1	* QMARK	CWH3404F	INTEGRAL THERMOSTAT POSITIVE SHUT-OFF

* C = CEILING MOUNTED R = ROOF TOP W = WALL MOUNTED F = FLOOR MOUNTED

* OR APPROVED EQUAL

GAS FIRED INFRARED RADIANT HEATING UNIT SCHEDULE

SYMBOL	MFG.	MODEL NO.	CAPACITY		UNIT AMPS	VOLTAGE	UNIT WEIGHT	REMARKS
			INPUT MBH	OUTPUT MBH				
RT-1	MODINE	IP150	75	5.5	120V-1 ϕ	—	—	30"-0" - 4" TUBE CONTROLLED BY SPACE STAT USED IN GARAGE

- REMARKS:
- COORDINATE REFLECTOR DIRECTIONS WITH ALL CONSTRUCTION AFTER INSTALLATION.
 - PROVIDE WITH 4" TYPE 'B' GAS VENT THROUGH WALL WITH VENT HOOD.
 - PROVIDE WITH REMOTE THERMOSTAT, HONEYWELL DIGITAL ROUND HEAT ONLY. MOUNT AT 42" A.F.F.
 - PROVIDE DIRECT CONNECTED COMBUSTION AIR INTAKE KIT THROUGH THE WALL.

* OR APPROVED EQUAL

SYMBOLS

- ① THERMOSTAT
- AIR FLOW DIRECTION
- MANUAL BALANCING DAMPER
- └ TURNING VANES OR RADIUS ELBOW

ABBREVIATIONS

AC	AIR CONDITIONING	HZ	HERTZ
AFF	ABOVE FINISHED FLOOR	IN	INCHES
AHU	AIR HANDLING UNIT	LRA	LOCKED ROTOR AMPS
APPROX	APPROXIMATELY	MAX	MAXIMUM
BLD'G	BUILDING	MBH	THOUSAND BTU'S PER HOUR
BTU/H	BRITISH THERMAL UNITS	MCA	MINIMUM CIRCUIT AMPS
CAP	CAPACITY	MECH	MECHANICAL
CFM	CUBIC FEET PER MINUTE	MFG	MANUFACTURER
CLG	CEILING	MIN	MINIMUM
CONT'D	CONTINUED	MTD	MOUNTED OR MOUNTING
DB	DRY BULB	NIC	NOT IN CONTRACT
DEG	DEGREE	OA	OUTSIDE AIR
DIA	DIAMETER	PC	PLUMBING CONTRACTOR
DN	DOWN	PH	PHASE
DWG	DRAWING	QTY	QUANTITY
EAT	ENTERING AIR TEMPERATURE	REQ'D	REQUIRED
EC	ELECTRICAL CONTRACTOR	RG	REGISTER
EER	ENERGY EFFICIENCY RATING	RLA	RUNNING LOAD AMPS
EF	EXHAUST FAN	RPM	REVOLUTIONS PER MINUTE
ESP	EXTERNAL STATIC PRESSURE	SA	SUPPLY AIR
EXH	EXHAUST	SEER	SEASONAL ENERGY EFFICIENCY RATING
EXIST	EXISTING	SENS	SENSIBLE
F	FAHRENHEIT	SP	STATIC PRESSURE
FD	FIRE DAMPER	STAT	THERMOSTAT
FL	FLOOR	STD	STANDARD
FLA	FULL LOAD AMPS	TEMP	TEMPERATURE
GC	GENERAL CONTRACTOR	TSP	TOTAL STATIC PRESSURE
HC	HEATING CONTRACTOR	TYP	TYPICAL
HVAC	HEATING VENTILATING AIR CONDITIONING	W	WATTS
HP	HORSE POWER	WB	WET BULB

NOTE: THE ABOVE SCHEDULE IS A STANDARD. THE ABBREVIATIONS DO NOT NECESSARILY APPEAR ON THE DRAWINGS FOR THIS PROJECT.

NOT FOR CONSTRUCTION - ISSUED FOR BID AND PERMIT 08-21-23


EQUIPMENT BUILDING
CONSTRUCTION DRAWING

FOR
PROPOSED FIRST FLOOR PLAN
CUMBERLAND COUNTY, PA

Drawn By: LEC
Designed By: LEC
Checked By: LEC
File: 2022-SH-009
Date: 08/18/2023
Scale: 3/16"=1'-0"
Drawing No.

H-2

Cox Engineering
175 Matamoras Road
Halifax, PA 17032
Phone/Fax: (717) 896-8242
Mobile: (717) 877-0102
E-Mail: Cox.Engineering@comcast.net



BREHM-LEBO ENGINEERING, INC.
CIVIL ENGINEERS
17 STATE AVENUE
CARLSBURG, PA 17013
PH: (717) 267-4141
FAX: (717) 243-3301

STRUCTURAL ENGINEERS
SURVEYORS
PLANNERS