SPECIFIC NOTES - HVAC NEW	
M1	EXISTING LOW WALL RETURN AIR GRILLE.
M3	1-1/4" CONDENSATE DOWN TO EXISTING OPEN HUB DRAIN.
M5	SPILL 1-1/4" CONDENSATE TO GRADE WITH SPLASH BLOCK.
M7	1-1/4" CONDENSATE UP, DISCHARGE ON ROOF.
M13	MECHANICAL WORK INDICATED WITHIN THIS AREA SERVING THE FIRST FLOOR OFFICES IS PART OF BASE BID NO. 1 AND BASE BID NO. 2 ONLY.
M18	EXISTING CEILING CASSETTE UNIT.
M19	EXISTING WALL HUNG UNIT.
M20	EXISTING CONDENSING UNIT.
M24	LOCATE THERMOSTAT FOR GYM AT CORRIDOR CEILING.
M27	CAP DUCTWORK AT LOCATION OF REMOVED EXHAUST AIR GRILLE.

1 FIRST FLOOR PLAN - HVAC
1/8" = 1'-0"

GRAPHIC SCALE 1/8"=1'-0"
0 20 40 60 80

This drawing is the property of Century Engineering and is prepared for the exclusive use of it's clients at the location indicated. No other use is authorized or intended.

CENTURY ENGINEERING
A Kleinfelder Company
10710 Gilroy Road
Hunt Valley, MD 21031
Phone: (443) 589-2400
www.centuryeng.com

© 2021 ALL RIGHTS RESERVED

SEAL

NO.	DESCRIPTION	DATE

REVISIONS

MILLERSVILLE UNIVERSITY

MI-1213 PUCILLO HVAC RENOVATION

125 PUCILLO DRIVE MILLERSVILLE, PA. 17551

SHEET TITLE

FIRST FLOOR PLAN - HVAC

ISSUE DATE: 11.17.2023

DRAWN	DESIGNED	CHECKED
SS	JE	JB

SCALE: AS NOTED

SHEET NO.: H-101

PROJECT NO.: 24000543.001A