SPECIFIC NOTES - HVAC DEMO	
MD1	EXISTING SUPPLY AIR DIFFUSER TO REMAIN.
MD2	EXISTING RETURN AIR GRILLE TO REMAIN.
MD3	EXISTING EXHAUST AIR GRILLE TO REMAIN.
MD4	REMOVE REGISTER/GRILLE.
MD7	EXISTING CEILING CASSETTE UNIT TO REMAIN.
MD8	EXISTING WALL HUNG UNIT TO REMAIN.
MD9	EXISTING CONDENSING UNIT TO REMAIN.
MD12	EXISTING TO REMAIN LOW WALL RETURN AIR GRILLE.
MD19	MECHANICAL WORK INDICATED WITHIN THIS AREA SERVING THE FIRST FLOOR OFFICES IS PART OF BASE BID NO. 1 AND BASE BID NO. 2 ONLY.

ETR THROUGH THE WALL VENTILATION UNIT

LOCKER RM 144 · STORAGE A 143 · STORAGE B 144 · STORAGE C 145 · TRASH RM 147 · ELEC CLST 146 · WC STORAGE 146A

ETR 16"x10" EA UP · ETR 8"x8" EA · ETR 16"x10" EA · MD3 · MD4 · MD9

RX 18"x16" RA UP · ETR 18"x6" EA UP · RX 18"x16" SA UP · RX 12"x4" SA · RX REHEAT COIL · RX 16"x6" EA · ETR 18"x6" EA UP · RX 18"x16" RA · RX 18"x16" SA · ETR 18"x12" SA · ETR 16"x10" SA · ETR 14"x8" SA

STAIR NO.1 · SHOWER RM 142 · MEN'S FACILITY RESTRM 140 · LOCKER RM 141 · STORAGE 147

ETR 14"x8" SA · ETR 14"x8" SA · ETR 14"x8" SA · RX 2" CD · RX 16"x6" EA · RX 18"x16" RA · RX 20"x12" EA · RX 44"x44" EA UP

MEN'S RESTROOM 138 · RX 30"x14" EA · ETR 30"x12" EA · ETR 20"x12" EA · ETR 20"x8" EA · RX 30"x16" EA · RX 36"x16" EA · MD12

RX 56"x14" EA · RX 24"x10" EA · RX 18"x14" SA UP · RX 18"x14" RA UP · RX 18"x14" SA · RX 18"x8" EA

WOMEN'S FACULTY RESTRM 139 · STORAGE 138 · RX 12"x10" EA · RX 20"x8" EA · RX 18"x10" SA · RX 18"x12" EA · MD7 · MD8

WHIRLPOOL 135 · TRAINING RM 125 · SHOWER RM 126 · STORAGE 137 · RX REHEAT COIL · RX 18"x8" EA · RX 18"x6" SA · RX 18"x12" EA · RX 18"x8" EA · RX 26"x26" EA UP · MD12

VARSITY LOCKER RM 144 · TOILET 127 · WOMEN'S RESTROOM 129 · RX 18"x6" SA · RX 20"x8" EA · RX 12"x6" EA · RX 12"x10" EA · RX 18"x8" EA · RX 12"x6" EA

RX 33"x33" EA UP · RX 8"x4" EA · RX 24"x10" EA · RX 40"x18" EA · RX 20"x12" EA · CORRIDOR 131 · LAUNDRY RM 132 · STORAGE 130 · ETR 18"x12" EA · ETR EUH · ETR 18"x8" EA · ETR EUH · MD3

STAIR NO.3 · FACULTY LOCKER RM 119 · FACULTY SHOWER 120 · OFFICE 117 · CONF. RM 116A · KITCH. 108 · STOR. 109 · RECEPT. 106

ETR REHEAT COIL, 3.0 KW · ETR REHEAT COIL, 2.0 KW · ETR 14"x6" SA · ETR 12"x6" SA · ETR 12"x4" SA · ETR 16"x6" SA · ETR 16"x10" SA · ETR 12"x4" SA · ETR 16"x10" SA · ETR 14"x10" SA · ETR 12"x10" SA · ETR 12"x8" SA · ETR 12"x6" SA · ETR 10"x6" SA · RX 20"x4" EA · RX 18"x6" EA · RX 14"x10" EA · ETR 20"x12" RA · ETR 20"x12" SA · RX 12"x6" EA · RX 12"x6" EA · RX 20"x12" EA · RX 14"x6" EA · RX 14"x6" EA UP · ETR 20"x12" RA UP · ETR 20"x12" SA UP · ETR HEATER · ETR HEATER · ETR REHEAT COIL, 12.5 KW · RX UNIT HEATER · MD1 · MD2 · MD10 · MD12

GYMNASIUM 101 · STORAGE 100 · MD12 · LOBBY 105 · CONCESSION 102 · MD12 · ELEVATOR 107 · EAST LOBBY 104A · STAIR NO.2 · WEST LOBBY 1006

WOMEN'S SHOWERS 145 · WOMEN'S RESTRM 143 · WOMEN'S LOCKER RM 144 · STORAGE 147 · OFFICE 142 · SWIMMING POOL 101 · OFFICE 154 · MEN'S RESTRM 153 · MEN'S LOCKER RM 152 · MEN'S SHOWERS 151

1 FIRST FLOOR PLAN - HVAC - DEMOLITION
1/8" = 1'-0"

GRAPHIC SCALE 1/8"=1'-0"
0 20 40 60 80

This drawing is the property of Century Engineering and is prepared for the exclusive use of it's clients at the location indicated. No other use is authorized or intended.

CENTURY ENGINEERING
A Kleinfelder Company
10710 Gilroy Road
Hunt Valley, MD 21031
Phone: (443) 599-2400
www.centuryeng.com

© 2021 ALL RIGHTS RESERVED

SEAL

NO.	DESCRIPTION	DATE

REVISIONS

MILLERSVILLE UNIVERSITY

MI-1213 PUCILLO HVAC RENOVATION

125 PUCILLO DRIVE MILLERSVILLE, PA. 17551

SHEET TITLE

FIRST FLOOR PLAN - HVAC - DEMOLITION

ISSUE DATE: 11.17.2023

DRAWN	DESIGNED	CHECKED
SS	JE	JB

SCALE: AS NOTED

SHEET NO.: H-002

PROJECT NO.: 24000543.001A