SPECIFIC NOTES - ELECTRICAL NEW	
E8	CONNECT TO SPARE 20A-1P BREAKER P2A-7.
E13	FURNISH A 20A-1P BREAKER AND INSTALL IN EXISTING SQUARE D NQ PANEL A1D. CONNECT WITH 2#10, 1#10 G IN 3/4" CONDUIT. ROUTE CONDUIT TO FIRST FLOOR VIA JANITOR CLOSET ON FLOOR BELOW.
E14	FURNISH A 20A-1P BREAKER AND INSTALL IN EXISTING SQUARE D NQ PANEL A1C. SPACE 41. CONNECT WITH 2#10, 1#10 G IN 3/4" CONDUIT. ROUTE CONDUIT TO FIRST FLOOR VIA WOMENS BATHROOM PLUMBING CHASE ON FLOOR BELOW.
E23	COORDINATE FINAL LIGHT LOCATIONS WITH DUCTWORK.
E24	CONNECT TO EXISTING TOGGLE SWITCH AND CIRCUIT IN SPACE.
E27	RELOCATE MECHANICAL EQUIPMENT. PROVIDE CONDUIT/WIRING TO MATCH EXISTING TO EXTEND TO NEW LOCATION.
E28	PROVIDE 3#12, 1#12 G, IN 3/4" CONDUIT FROM F-13 TO EXISTING BUCKET IN MOTOR CONTROL CENTER LABELED F-13.

E23 FAN RM NO.4
SD
E24
E13
EX WIREWAY
EX

E23 FAN RM NO.2
SD
E24
E8
EX WIREWAY
EX
UP

PRESS BOX
NO.

ELEVATOR
NO.

ACCESS RM
NO.

E14
EX
E24
EX WIREWAY
SD
FAN RM NO.3 E23
BASE BID NO. 3: EXISTING H&V UNIT 6.

E8
EX
E24
EX MCC
E27 RELOCATED F-13 BASE BID NO. 1.
SD
E23 FAN RM NO.1
BASE BIDS NO. 2 AND 3: EXISTING H&V UNIT 7.
E28 NEW F-13 BASE BIDS NO. 2 AND 3.

1 CLERESTORY FLOOR PLAN - ELECTRICAL
1/8" = 1'-0"

GRAPHIC SCALE 1/8"=1'-0"
0 20 40 60 80

This drawing is the property of Century Engineering and is prepared for the exclusive use of it's clients at the location indicated. No other use is authorized or intended.

CENTURY ENGINEERING
A Kleinfelder Company
10710 Gilroy Road
Hunt Valley, MD 21031
Phone: (443) 589-2400
www.centuryeng.com

© 2021 ALL RIGHTS RESERVED

SEAL

NO.	DESCRIPTION	DATE

REVISIONS

MILLERSVILLE UNIVERSITY

MI-1213 PUCILLO HVAC RENOVATION

125 PUCILLO DRIVE MILLERSVILLE, PA. 17551

SHEET TITLE
CLERESTORY FLOOR PLAN - ELECTRICAL

ISSUE DATE:	11.17.2023	
DRAWN	DESIGNED	CHECKED
SP	SGH	SGH
SCALE	SHEET NO.	
AS NOTED	E-104	
PROJECT NO. 24000543.001A		