SPECIFIC NOTES - ELECTRICAL DEMO	
No.	KEYNOTE TEXT
ED1	DISCONNECT DUCT HEATER TO ALLOW FOR REMOVAL BY DIVISION 20. REMOVE ASSOCIATED DISCONNECT SWITCH, AND ASSOCIATED CONDUIT/WIRING BACK TO SOURCE (ASSUMED TO BE PANEL H1BL OR H1BR. VERIFY IN FIELD).
ED11	DISCONNECT AND REMOVE LIGHT FIXTURES WITHIN OUTLINED AREA UNLESS NOTED OTHERWISE. REMOVE ASSOCIATED CONDUIT AND WIRING BETWEEN FIXTURES. RETAIN HOMERUN WIRING FOR NEW LIGHTING.
ED14	DISCONNECT VIDEO CAMERA TO ALLOW FOR CEILING REMOVAL. REINSTALL VIDEO CAMERA IN SAME LOCATION IN NEW LOWER CEILING GRID. EXTEND VIDEO CAMERA CABLING AND RECONNECT TO MATCH EXISTING.
ED15	DISCONNECT AND REMOVE LIGHTING TOGGLE SWITCH(ES). REMOVE ASSOCIATED WIRING BACK TO ABOVE CEILING. RETAIN BACKBOX AND CONDUIT STUB FOR NEW WIRING AND LIGHTING CONTROL DEVICE.
ED19	DISCONNECT SMOKE DETECTOR TO ALLOW FOR CEILING REMOVAL. RETAIN SMOKE DETECTOR AND CABLING FOR REINSTALLATION.
ED20	DISCONNECT AND REMOVE EMERGENCY LIGHT FIXTURE. IF MORE THAN ONE FIXTURE IN SPACE, REMOVE ASSOCIATED CONDUIT AND WIRING BETWEEN FIXTURES. RETAIN HOMERUN WIRING FOR NEW EMERGENCY LIGHTING.
ED22	DISCONNECT AND REMOVE LIGHTING TOGGLE SWITCH(ES). REMOVE CONDUIT AND WIRING BACK TO POINT OF ORIGIN. PROVIDE BLANK STAINLESS STEEL COVER FOR BACKBOX.
ED23	DISCONNECT AND REMOVE LIGHTING TOGGLE SWITCH AND WIREMOLD BACKBOX. REMOVE ASSOCIATED SURFACE MOUNTED RACEWAY AND WIRING TO LIGHT FIXTURE. PROVIDE PLUG IN RECEPTACLE WIREMOLD BACKBOX.
ED24	DISCONNECT AND REMOVE LIGHT FIXTURE.
ED25	DISCONNECT AND REMOVE EXIT SIGN TO ALLOW FOR CEILING REMOVAL. RETAIN CONDUIT AND WIRING. REINSTALL EXIT SIGN AFTER NEW CEILING IS INSTALLED AND RECONNECT TO MATCH.
ED29	TEMPORARILY DISCONNECT CONDUITS FROM STRUCTURAL MEMBERS INDICATED FOR REINFORCEMENT ON DRAWING S101. RESUPPORT CONDUITS AFTER REINFORCEMENT IS COMPLETE.



ED29 1 FIRST FLOOR PLAN - ELECTRICAL - DEMOLITION
1/8" = 1'-0"

GRAPHIC SCALE 1/8"=1'-0"
0 20 40 60 80

This drawing is the property of Century Engineering and is prepared for the exclusive use of it's clients at the location indicated. No other use is authorized or intended.

CENTURY ENGINEERING
A Kleinfelder Company
10710 Gilroy Road
Hunt Valley, MD 21031
Phone: (443) 589-2400
www.centuryeng.com

© 2021 ALL RIGHTS RESERVED

SEAL

NO.	DESCRIPTION	DATE

REVISIONS

MILLERSVILLE UNIVERSITY

MI-1213 PUCILLO HVAC RENOVATION

125 PUCILLO DRIVE MILLERSVILLE, PA. 17551

SHEET TITLE

FIRST FLOOR PLAN - ELECTRICAL - DEMOLITION

ISSUE DATE: 11.17.2023

DRAWN	DESIGNED	CHECKED
SP	SGH	SGH

SCALE: AS NOTED

SHEET NO.: E-003

PROJECT NO.: 24000543.001A