

SPECIFIC NOTES - ELECTRICAL DEMO	
No.	KEYNOTE TEXT
E03	<p>BASE BID NO. 1 AND 2: DISCONNECT MECHANICAL EQUIPMENT TO ALLOW FOR REMOVAL BY DIVISION 20. REMOVE ASSOCIATED DISCONNECT SWITCH AND CONDUIT/WIRING BACK TO ENCLOSED CIRCUIT BREAKER IN FAN ROOM 3 BELOW. BASE BID NO. 3: DISCONNECT EQUIPMENT TO ALLOW FOR RELOCATION BY DIVISION 20. REMOVE ASSOCIATED CONDUIT AND WIRING BACK TO DISCONNECT SWITCH IN FAN ROOM 3 BELOW. RELOCATE DISCONNECT SWITCH AT UNIT TO NEW LOCATION. REFEED AS INDICATED ON NEW WORK PLAN.</p>
E10	<p>BASE BID NO. 1: DISCONNECT MECHANICAL EQUIPMENT TO ALLOW FOR REMOVAL BY DIVISION 20. REMOVE ASSOCIATED EXTERIOR DISCONNECT SWITCH AND CONDUIT/WIRING BACK TO ENCLOSED CIRCUIT BREAKER IN FAN ROOM 1. BASE BID NO. 2 AND 3: DISCONNECT CONDUIT/WIRING FROM ENCLOSED CIRCUIT BREAKER IN FAN ROOM 1. REFEED AS INDICATED ON NEW WORK PLAN.</p>
E026	<p>DISCONNECT MECHANICAL EQUIPMENT TO ALLOW FOR REMOVAL BY DIVISION 20. REMOVE ASSOCIATED DISCONNECT SWITCH AND CONDUIT/WIRING BACK TO ENCLOSED CIRCUIT BREAKER IN FAN ROOM 1. REFEED AS INDICATED ON NEW WORK PLAN. ROUTED THROUGH GYM. ABANDON IN PLACE. PROVIDE JUNCTION BOX OUTSIDE LIMITS OF GYM. CAP WIRING AND MAKE SAFE. CAP END OF CONDUIT.</p>
E027	<p>DISCONNECT MECHANICAL EQUIPMENT TO ALLOW FOR REMOVAL BY DIVISION 20. REMOVE ASSOCIATED CONDUIT AND WIRING BACK TO JUNCTION BOX IN GYM BELOW ROOF. DISCONNECT WIRING FROM MCC BUCKET IN FAN ROOM 1 FEEDING FAN CAP WIRING ON 4TH FLOOR AND MAKE SAFE. TAP WIRING IN MCC AND JUNCTION BOX. COORDINATE WITH OWNER FOR GYM FLOOR RATING PRIOR TO LIFTING LIFT OR SCAFFOLDING.</p>

CENTURY
ENGINEERING

A Kleinfelder Company

10710 Gilroy Road
Hunt Valley, MD 21031
Phone: (443) 589-2400
www.centuryeng.com
© 2021 ALL RIGHTS RESERVED

MILLERSVILLE UNIVERSITY
MI-1213 PUCILLO HVAC RENOVATION
125 PUCILLO DRIVE MILLERSVILLE, PA. 17551

ROOF PLAN -
ELECTRICAL -
DEMOLITION

