SPECIFIC NOTES - HVAC DEMO	
MD11	REFURBISH EXISTING FIRE DAMPERS, REPLACE FUSIBLE LINKS.
MD13	BASE BID 1: RELOCATE EXISTING EXHAUST FAN. BASE BID 2 AND 3: REMOVE EXHAUST FAN AND DUCTWORK AS INDICATED ON THE PLAN.
MD14	REMOVE EXISTING CONCRETE HOUSEKEEPING PAD.
MD15	REMOVAL OF H&V UNIT 6 IS PART OF BASE BID NO. 1 AND BASE BID NO. 2 ONLY.
MD16	REMOVAL OF H&V UNIT 7 IS PART OF BASE BID NO. 1 ONLY.

RX H&V UNIT-4
RX O.A PLENUM
EX 48"x30" RA GRATING
RX R.A DAMPER
RX 18"x16" RA DN
RX 18"x16" SA DN
RX 60"x20" SA
EX 60"x20" SA
MD14
FAN RM NO.4
RX H&V UNIT-5
RX 22"x22" RA
RX R.A DAMPER
RX 18"x16" RA
RX 30"x16" SA
RX 18"x16" SA
RX 18"x14" SA
RX 18"x14" RA

MD11 RA PLENUM W/ MULTIPLE FIRE DAMPERS

RX O.A PLENUM
RX H&V UNIT - 2
MD14
FAN RM NO.2
RX 60"x20" SA
EX 60"x20" SA
UP

ELEVATOR 20
ACCESS RM 22
PRESS BOX 301

UP
DN
EX 60"x20" SA
RX 60"x20" SA
MD14
RX H&V UNIT - 3
FAN RM NO.3
RX H&V UNIT - 6 MD15
RX O.A LOUVER SCREEN & DAMPER
EX 48"X30" RA GRATING
RX O.A PLENUM
RX 20"x12" SA
EX 20"x12" SA DN
MD14
RX 12"x20" RA
EX 20"x12" RA DN

MD11 RA PLENUM W/ MULTIPLE FIRE DAMPERS
MD13 EXT F-13
24"x12" SA
RX 24"x24" RA
RX 40"x16" SA
MD14
RX H&V UNIT - 7 MD16
MD14
FAN RM NO.1
RX 60"x20" SA
EX 60"x20" SA
RX O.A PLENUM
RX H&V UNIT - 1

1 CLERESTORY FLOOR PLAN - HVAC - DEMOLITION
1/8" = 1'-0"

GRAPHIC SCALE 1/8"=1'-0"
0 20 40 60 80

This drawing is the property of Century Engineering and is prepared for the exclusive use of it's clients at the location indicated. No other use is authorized or intended.

CENTURY ENGINEERING
A Kleinfelder Company
10710 Gilroy Road
Hunt Valley, MD 21031
Phone: (443) 589-2400
www.centuryeng.com

© 2021 ALL RIGHTS RESERVED

SEAL

NO.	DESCRIPTION	DATE

REVISIONS

MILLERSVILLE UNIVERSITY

MI-1213 PUCILLO HVAC RENOVATION

125 PUCILLO DRIVE MILLERSVILLE, PA. 17551

SHEET TITLE

CLERESTORY FLOOR PLAN - HVAC - DEMOLITION

ISSUE DATE: 11.17.2023

DRAWN	DESIGNED	CHECKED
SS	JE	JB

SCALE: AS NOTED

SHEET NO.: H-004

PROJECT NO.: 24000543.001A