


REMARKS





- ① FAUCET SHALL MEET ASSE 1070, BASIS OF DESIGN: CHICAGO FAUCET MODEL NO. 420-E74ABCP, 1.0GPM.
- ② PROVIDE WITH FIELD INSTALLED TANK TYPE LOCKING KIT 4188A174.020 OR APPROVED EQUAL.
- ③ PROVIDE WITH WSG2424 STAINLESS STEEL WALL GUARD, 889-CC WOP HANGER, 832AA HOSE & BRACKET, AND 830-AA SERVICE FAUCET
- ④ PROVIDE WITH J-902 DECK MOUNT SINK FAUCET, J-ADA-35 STAINLESS STEEL DRAIN ASSEMBLY
- ⑤ INCLUDED WITH ASPEN WHITE DISPENSER, STAINLESS STEEL FILTER BOX, REMOTE FILTER CABLE, AND 3000 GALLON FAUCET EFW3000 WITH 71300C PFAS (PFOA/PFOS) REPLACEMENT FILTER.

WATER HEATER SCHEDULE												
SYMBOL	BASIS OF DESIGN		MAXIMUM INPUT (MBH)	GPM @ 70° RISE	GPM @ 50° RISE	MAXIMUM GPM	WATER CONN.	GAS CONN.	THERMAL EFF. (%)	ELECTRICAL		REMARKS
	MANUFACTURER	MODEL								VOLTS	AMPS	
WH-1	RINNAI	RL94i	199.0	4.8	6.7	9.8	3/4"	3/4"	82	120	2	①
<b>REMARKS</b> ① PROVIDE AND INSTALL WITH SERVICE VALVES AND CONCENTRIC WALL TERMINATION KIT.												



- 1 REMOVE CLEAN AGENT FIRE SUPPRESSION SYSTEM TANK, PIPING, HEAD, AND ALL PLUMBING COMPONENTS. RETAIN AND DELIVER TO FACILITY MAINTENANCE DEPARTMENT.
- 2 REMOVE AND DISPOSE OF WATER HEATER AND WATER PIPING.
- 3 REMOVE PLUMBING FIXTURES WITH ALL ASSOCIATED WATER AND SEWER PIPING, ENTIRELY BACK TO BUILDING ENTRANCE.

### PLUMBING DEMOLITION NOTES:

- |  |                        |
|--|------------------------|
| ----   | (CW) COLD WATER        |
| ----   | (HW) HOT WATER         |
| ----   | (V) VENT               |
| ----   | (SAN) SANITARY         |
|             | RPZ BACKFLOW PREVENTER |
|  <u>WHA</u> | WATER HAMMER ARRESTOR  |
|  <u>FCO</u> | FLOOR CLEAN OUT        |
|  <u>WCO</u> | WALL CLEAN OUT         |

## SYMBOL LEGEND



CONTRACTOR SHALL FIELD VERIFY  
ALL DIMENSIONS.  
VARIANCE FROM CONTRACT  
DOCUMENTS NOT PERMITTED  
WITHOUT BUREAU OF ENGINEERING  
AND ARCHITECTURE APPROVAL

[illegible]