

DATE: February 14, 2024

DEPARTMENT OF GENERAL SERVICES
BUREAU OF CAPITAL PROJECT DESIGN MANAGEMENT
1800 HERR STREET
HARRISBURG, PENNSYLVANIA

ADDENDUM NO. 2

on

PROJECT NO. DGS C-0948-0101 PHASE 001

PROJECT TITLE - East Wing - Replacement of Escalators with Elevator, HVAC Diffuser and Cafeteria Upgrades

PROFESSIONAL:

Vitetta Group, Inc.
645 North 12th Street
Lemoyne, PA, 17043

If you submitted a bid prior to this Addendum being issued, your bid has been discarded and you must re-submit your bid(s) prior to the bid opening date and time.

ADMINISTRATIVE CHANGES – ALL CONTRACTS

Item 1 - The SDB/VBE upload documents response has been added for the .1 Contract.

SPECIFICATION CHANGES – CONTRACT NO. DGS C-0948-0101 PHASE 1.1

Item 1 - Section 010100 "Summary of Work" Page 6: Revised 1.6.B to read as follows:
B. General Construction (4.1) Contract: Divisions 02 through 14 and 32.

Item 2 - Section 044203 "Stone Masonry" Page 5: Revised 2.3.C.2 as follows:
2. G-2: Canadian Red.
a. For patching and infill where new construction adjoins existing construction.
b. Wall base.
c. Stair stringers.

Item 3 - Section 044203 "Stone Masonry" Page 5: Revised 2.3.F as follows:
1. G-1A: Honed.
2. G-1B: Thermal.
3. G-2A: Polished.

Item 4 - Section 080000 "Door Schedule": Revised as follows:
- Door P2-1S: Revised hardware set to 2.
- Door P1-EM: Revised hardware set to 3.

Item 5 - Section 087111 "Door Hardware" Page 13: Revised as follows:
- At Hardware Set 4, deleted door position switch.
- At Hardware Set 5, added 2 door position switches as follows:
2 Door Position Switches SWITCH DPS-M GY Securitron

Item 6 - Section 092900 "Gypsum Board" Page 6: Added 3.6.D.4 as follows:
4. Level 5: Exterior surface of walls around AV room at Concourse Level.

SPECIFICATION CHANGES – CONTRACT NO. DGS C-0948-0101 PHASE 1.2

Item 1 - Section 233423 "HVAC Power Ventilators:" Revised to include combination motor starter by fan

manufacturer.

SPECIFICATION CHANGES – CONTRACT NO. DGS C-0948-0101 PHASE 1.4

Item 1 - Section 262816 "Enclosed Switches and Circuit Breakers": Added this Section in its entirety.

Item 2 - Section 271500 "Communications Horizontal Cabling": Added requirements for fiber cable. New specification section attached to addendum.

DRAWING CHANGES – CONTRACT NO. DGS C-0948-0101 PHASE 1.1

Item 1 - Drawing G203: Revised as follows:

- Added to remove and reinstall suspended metal ceiling below former escalator pit.
- Added location of signs.

Item 2 - Drawing A213Ar: Added location of signs.

Item 3 - Drawing A214Ar: Added location of signs.

Item 4 - Drawing A402: Revised as follows:

- Showed handrail/post locations.
- Revised stair framing consistent with revisions to stair framing on Drawing S201.

Item 5 - Drawing A403: Revised height dimension of granite stringer.

Item 6 - Drawing A404: Revised stair details consistent with revisions to stair framing on Drawing S201.

Item 7 - Drawing A405: Revised as follows:

- At Details 07, 08 and 10, revised inverted handrail bronze channel to 2" x 1" x 1/8".
- At Detail 10, revised out to out dimension between handrails to 1'-2".
- Revised granite stringer and glass rail shoe connection to stair steel framing.

Item 8 - Drawing A411: Revised elevator shafts walls to 12" CMU.

Item 9 - Drawing A416: Revised elevator shaft walls at Concourse Level and above 12" CMU.

Item 10 - Drawing S001: At Detail for attachment of CMU wall to underside of existing roof slab, revised CMU to 12".

Item 11 - Drawing S100: At Plan 03, revised elevator shaft walls.

Item 12 - Drawing S201: Revised as follows:

- Added X within stair framing.
- Deleted CFM stud bearing wall and added 4 steel tube columns.
- Added Detail 03 covering X bracing.
- Added Details 04 and 05 covering support for glass railing shoe.

Item 13 - Drawing S300: Revised as follows:

- At Detail 1, revised termination of CMU at underside of existing concrete beams to include dry pack grout.

- At Detail 2, deleted steel beams and added concrete slab in-fill.
- Added Detail 3.

DRAWING CHANGES – CONTRACT NO. DGS C-0948-0101 PHASE 1.2

Item 1 - Drawing H201C-II: Revised as follows:

- Added description for Key Notes 1, 2 and 3.
- Added location of Key Note 3 on plan.

Item 2 - Drawing H211: Plan 01 identified location of existing T-STAT at Storage P222E to be demolished.

Item 3 - Drawing H212: Plan 01 identified location of existing T-STAT at IDF P122E to be demolished.

DRAWING CHANGES – CONTRACT NO. DGS C-0948-0101 PHASE 1.4

Item 1 - Drawing E201C: Deleted General Note 3. New controls are to be connected to existing controls power junction box with +/- 50 feet.

Item 2 - Drawing E202: Revised as follows:

- Added the following to the end of Key Note E4: Existing circuit breakers are General Electric.
- Added Key Note E14 showing location of existing card access control panel.

Item 3 - Drawing E212: Revised as follows:

- Revised Key Note E7 to read: Provide 120V disconnect switch for elevator car lights from Circuit 17 in Panel 'XC' located at Electrical Room M430 on Concourse Level.
- Revised Key Note E9 to read: Provide new 90A/480V/3P disconnect switch.
- At Plan 02, added Key Note E20 to identify box at west side of Door P1-1S.
- Added REX (request to exit) at Doors P1-1S and P1-EM.

Item 4 - Drawing E212u: Revised as follows:

- At Panel XC, revised Circuit 17 to elevator cab lights.
- Added remark to Note 3 as follows: Combine existing Circuits 15 and 17 (Gift Shop receptacle). Provide investigation of quantity of circuits connected to Circuits 15 and 17 and amp reading before proceeding.

Item 5 - Drawing E215Ad: Added notes to clarify the extend of existing non-functional neon Rotunda lighting.

Item 6 - Drawing E215Ar: Added information for new Rotunda LED lighting controller as follows:

- Add 120V receptacle and circuit to power the Rotunda LED lighting controller.
- Revised note for fiber conduit/cable feeding lighting controller data jack to read as follows: 2" conduit with single mode 12 strand fiber cable (plenum rated) in inner duct to MDF M25E (refer to Key Notes E8 and E9 on Drawing E202 and Key Notes E18 and E19 on Drawing E211). Conduit is included in Base Bid 1. Fiber cable is included in Base Bid 3.

Item 7 - Drawing E215d: At note for existing spiral stair, revised referenced drawings to A213Ad and A214Ad,

Item 8 - Drawing E401: Added this drawing with single-line diagrams for card access.