GENERAL NOTES

1. KEY NOTES BELOW REFER TO PLUMBING AND FIRE PROTECTION RENOVATION WORK ON UPPER PARKING LEVEL P1.
2. REFER TO DETAIL 02/P-FP211 FOR KEY NOTE LOCATIONS AND DETAILS 01 & 01K/P-FP211 FOR PLUMBING DEMOLITION WORK.
3. REFER TO DRAWING A211 FOR ARCHITECTURAL RENOVATION WORK FOR THIS AREA.
4. COORDINATE ALL RENOVATION WORK WITH THE .1 GENERAL CONTRACTOR.

INFORMATIONAL KEY NOTES

01 FOR THE DURATION OF THE CONSTRUCTION ACTIVITIES, THE .1 GENERAL CONTRACTOR SHALL PRESERVE AND PROTECT ALL EXISTING CONDITIONS TO REMAIN AND SHALL ENSURE THE BUILDING'S OCCUPANTS MAY SAFELY USE SPACES IN THE AREAS OF THE BUILDING NOT BEING RENOVATED.

KEY NOTES FOR .3 PLUMBING CONTRACT

P1 PROVIDE AND INSTALL NEW 4" SANITARY RISER UP TO FD-1 IN ELEVATOR PIT ABOVE.

P2 PROVIDE AND INSTALL 4" SANITARY DOWN TO PARKING LEVEL.

P3 EXISTING SANITARY VENT RISER TO REMAIN.

P4 CUT AND PATCH EXISTING CMU WALL AS REQUIRED FOR THE INSTALLATION OF NEW PLUMBING WORK.

P5 AFTER NEW CMI WALL IS CONSTRUCTED BY .1 CONTRACTOR, .3 CONTRACTOR SHALL REINSTALL ELECTRIC STORAGE HOT WATER HEATER AND SHELF, RECONNECT TO EXISTING PLUMBING PIPE, AND REPLACE ALL DISTURBED PIPE INSULATION.

P6 RE-INSTALL SALVAGED ELECTRIC STORAGE HOT WATER HEATER AND SHELF AN RECONNECT PIPING AS REQUIRED.

KEY NOTES FOR .3 FIRE PROTECTION CONTRACT

FP1 EXISTING SPRINKLER SYSTEM PIPE TO REMAIN.

FP2 PROVIDE NEW PENDANT SPRINKLER HEAD WITH WIRE GUARD.

FP3 PROVIDE NEW SCHEDULE 40 BLACK STEEL SPRINKLER PIPE (SIZE AS NOTED BELOW) AND PAINT NEW PIPE 'RED'.

FP4 4" SANITARY RISER UP.

FP5 EXISTING BELOW SLAB SANITARY TO REMAIN. INVERT IS -2'-6" FROM TOP OF SLAB.

FP6 SAW CUT, REMOVE, AND REPLACE 12" THICK SLAB-ON-GRADE WITH (2) LAYERS OF #5 REBAR AT 12" O.C. EACH WAY. PROVIDE (2) LAYERS OF #5 REBAR EACH WAY AND DOWEL NEW REBAR INTO EXISTING CONCRETE SLAB FOR PATCH.

FP7 NEW FIRE PROTECTION PIPE RISER UP TO UNDERSIDE OF STRUCTURE (± 18'-0" AFF PARKING LEVEL P1).

SCALE
3/8" = 1'-0"

KEY NOTES FOR RENOVATION WORK 02K



FLOOR ELEVATION 335'-1"

SCALE
3/8" = 1'-0"

CORE 6 - UPPER PARKING LEVEL P1 - PLUMBING - RENOVATION 02

SCALE
NONE

KEY NOTES FOR DEMOLITION WORK 01K

GENERAL NOTES

1. KEY NOTES BELOW REFER TO THE PLUMBING AND FIRE PROTECTION DEMOLITION WORK ON LOWER PARKING LEVEL P2.
2. REFER TO DETAIL 01/P-FP211 FOR KEY NOTE LOCATIONS AND DETAILS 02 & 02K/P-FP211 FOR PLUMBING RENOVATION WORK.
3. REFER TO DRAWING A214Ad FOR ARCHITECTURAL DEMOLITION WORK FOR THIS AREA.
4. COORDINATE ALL DEMOLITION WORK WITH THE .1 GENERAL CONTRACTOR.

INFORMATIONAL KEY NOTES

ALL 01 NO DEMOLITION WORK FOR THE FIRE PROTECTION SYSTEM IN THIS AREA. PRESERVE AND PROTECT ALL EXISTING CONDITIONS TO REMAIN.

KEY NOTES FOR .3 PLUMBING CONTRACT

PC 01 REMOVE AND SALVAGE ELECTRIC STORAGE HOT WATER HEATER AND SHELF. TEMPORARILY CAP ALL PIPE CONNECTIONS OR SHUT VALVES AND TAG.

KEY NOTES FOR .3 FIRE PROTECTION CONTRACT

FPC 01 REMOVE EXISTING SPRINKLER HEAD, SALVAGE, AND TURN OVER TO CLIENT AGENCY.

FPC 02 REMOVE EXISTING SPRINKLER SYSTEM PIPE.

FPC 03 EXISTING SPRINKLER SYSTEM PIPE TO REMAIN.



FLOOR ELEVATION 335'-1"

SCALE
3/8" = 1'-0"

CORE 6 - UPPER PARKING LEVEL P1 - PLUMBING - DEMOLITION 01

SCALE
NONE

FIRE PROTECTION LEGEND 00

- EXISTING SCHEDULE 40 BLACK STEEL SPRINKLER PIPE TO REMAIN
- EXISTING SCHEDULE 40 BLACK STEEL SPRINKLER PIPE TO BE REMOVED
- NEW SCHEDULE 40 BLACK STEEL SPRINKLER PIPE TO BE PROVIDED
- EXISTING SPRINKLER HEAD TO REMAIN
- D EXISTING SPRINKLER HEAD TO BE REMOVED
- N NEW SPRINKLER HEAD TO BE PROVIDED
- CONNECT NEW PIPE TO EXISTING PIPE

SCALE & DIMENSIONS

BAR IS ONE (1) INCH LONG ON ORIGINAL DRAWING

0 1

IF BAR IS NOT ONE (1) INCH LONG, ADJUST SCALE ACCORDINGLY. CONTRACTOR SHALL FIELD VERIFY ALL DIMENSIONS. VARIANCE FROM CONTRACT NOT PERMITTED WITHOUT BUREAU OF ENGINEERING AND ARCHITECTURE APPROVAL.

BASE BIDS

ALL WORK SHOWN ON THIS DRAWING IS INCLUDED IN BASE BID 01, UNLESS NOTED OTHERWISE ON THIS DRAWING.

REFER TO PROJECT MANUAL FOR FULL DESCRIPTION OF ALL BASE BIDS.

VITETTA PROJECT 4645.0000 © 2024 VITETTA
ALL DIMENSIONS MUST BE VERIFIED BY THE CONTRACTOR(S) AND THE ARCHITECT NOTIFIED OF ANY DISCREPANCIES BEFORE PROCEEDING WITH THE CONSTRUCTION
DO NOT SCALE THIS DRAWING

No.	DESCRIPTION	No.	DESCRIPTION
19		20	
17		18	
15		16	
13		14	
11		12	
09		10	
07		08	
05		06	
03		04	
01		02	

AS-BUILT REVISIONS

REGISTERED ARCHITECT PENNSYLVANIA DAVID A. VODZAK, R-17134

01.04.2024

VITETTA Professional's Signature | Consultant Professional's Signature | Date

CONSULTANT
VITETTA
ARCHITECTURE | ENGINEERING | PLANNING
HISTORIC PRESERVATION
645 NORTH 12TH STREET ● SUITE 100
LEMOYNE ● PENNSYLVANIA ● 17043

COMMONWEALTH OF PENNSYLVANIA
DEPARTMENT OF GENERAL SERVICES
HARRISBURG, PENNSYLVANIA

DGS PROJECT NUMBER
C-0948-0101 PHASE 001

CAPITOL EAST WING
REPLACEMENT OF ESCALATORS WITH ELEVATOR
HVAC DIFFUSERS & CAFETERIA UPGRADES

HARRISBURG, DAUPHIN COUNTY, PENNSYLVANIA

CORE 6
UPPER LEVEL PARKING (P1)
PLUMBING DEMO & RENO

DRAWN BY	DATE	DRAWING NUMBER
J. JOLIN	01.04.2024	P/FP212
CHECKED BY: D. VODZAK	SCALE: 3/8" = 1'-0"	

FILE PATH: P:\Projects\4645_00\PLUMB-FP\4645_P-FP212_P1-Upper-Parking-Elevator_PLMB.dwg
LAST SAVED: 23.12.20 09:47 AM PLOTTED: 24.01.3 12:12 PM PLOTTED BY: JOLIN

DRAWING IS INTENDED FOR COLOR PRINTING