

SECTION 014010

QUALITY ASSURANCE TESTING AND INSPECTION SERVICES

PART 1 – GENERAL

1.1 STIPULATIONS

- A. The specifications sections “General Conditions of the Construction Contract”, “Special Conditions”, and “Division 1 - General Requirements” form a part of this Section by this reference thereto, and shall have the same force and effect as if printed herewith in full.

1.2 GENERAL

- A. All testing and inspecting specifically called for and/or described in this section of the specifications are referred to as Quality Assurance Services and are the responsibility of the Quality Assurance Agency. Except as hereinafter specified, Quality Assurance Services will be performed without expense to the Contractor. The Quality Assurance Agency is an independent testing and inspecting agency engaged by the Department through the Professional. Testing required because of changes in materials or proportions at the request of the Contractor shall be at the Contractor's expense. The Professional may engage more than one Quality Assurance Agency to perform services. Whenever the word "Contractor" is used it shall be interpreted to mean Prime Contractor or Contractors as applicable.
- B. Work Not Included: Quality Control Testing to be performed by the Contractor is specified in Section 014000.

PART 2 – PRODUCTS (Not Used)

PART 3 – EXECUTION

3.1 RESPONSIBILITIES AND DUTIES OF THE CONTRACTOR

- A. The use of Quality Assurance Services shall in no way relieve the Contractor of its responsibility to furnish materials and construction in full compliance with the plans and specifications or to perform Quality Control Testing where specified.
- B. To facilitate Quality Assurance Inspection or Testing, the Contractor shall:
 - 1. Secure and deliver to the project site, without cost, representative samples of materials it proposes to use and which are required to be tested under Paragraph 3.4, 'Tests and Inspections'.
 - 2. Furnish such casual labor as is necessary to obtain and handle samples at the project or at other sources of material.
 - 3. Provide means of safe access to work areas, provide conditions that allow testing and inspection to take place, provide materials for testing as requested, patch test sites when completed and furnish incidental labor and assistance necessary for inspectors of the Quality Assurance Agency to perform their tests and inspections.

3.2 AUTHORITY AND LIMITATIONS OF QUALITY ASSURANCE AGENCY

- A. Personnel representing the Quality Assurance Agency will not act as foremen nor perform other duties for the Contractor.
- B. Work will be checked as it progresses, but failure to detect any defective work or materials shall not in any way prevent later rejection when such defect is discovered, nor shall it obligate the Department or the Professional for final acceptance.
- C. The Quality Assurance Agency is not authorized to revoke, alter, relax, enlarge, or release any requirements of the specifications, nor to approve or accept any portion of the work.
- D. The Quality Assurance Agency shall report all test and inspection results to the Professional, the Department and the Contractor immediately after they are performed. Selection and frequency of tests shall be at the discretion of the Professional and the Department. All reports shall be uploaded to e-Builder within 24 hours of when the inspection occurs, test is conducted, test results obtained or similar service was conducted.
- E. Written reports of each inspection, test or similar service shall include but not be limited to:
 - 1. Date of issue.
 - 2. Project title and number.
 - 3. Name, address and telephone number of testing agency.
 - 4. Dates and location of samples and tests or inspections.
 - 5. Names of individuals making the inspection or test.
 - 6. Designation of the Work and test method.
 - 7. Identification of product and specification section.
 - 8. Complete inspection or test data.
 - 9. Test results and an interpretation of test results.
 - 10. Ambient conditions at the time of sample taking and testing.
 - 11. Comments or professional opinion as to whether inspected or tested work complies with Contract Document requirements.
 - 12. Name and signature of Quality Control Agency inspector.
- F. When it appears that any material furnished or work performed by the Contractor fails to fulfill contract requirements, the Quality Assurance Agency shall report such deficiency to the Professional, the Department and the Contractor.

3.3 CONTRACTOR'S FAILURE TO MEET CONTRACT REQUIREMENTS

- A. The Department and the Professional reserve the right to reject any items which do not meet the requirements of the plans and specifications and will require the contractor to replace these items and bear all expenses in connection with such replacements.
- B. The Contractor shall pay all costs incurred in providing additional testing and/or analysis (including engineering fees) required because of deficient test results or construction not in compliance with requirements of the Contract Documents.

3.4 TESTS AND INSPECTIONS

- A. Tests and inspections listed below may, at the discretion of the Professional and the Department, be performed by an independent Quality Assurance Agency engaged by the Department through the Professional, without expense to the Contractor. The Department reserves the right to change this list at any time.

<u>REQ'D BY¹</u>	<u>DESCRIPTION OF TEST OR INSPECTION</u>	<u>REFERENCED STANDARD</u>	<u>IBC REFER-ENCE²</u>
	CONCRETE		
IBC	1. Inspection of adhesive anchors installed in hardened concrete	ACI 318: 3.8.6, 8.1.3, 21.2.8	1704.4
IBC	2. Verifying use of required design mix	ACI 318: Ch. 4, 5.2-5.4	1904.22, 1913.2, 1913.3
IBC	3. At the time fresh concrete is sampled to fabricate specimens for strength tests, perform slump and air content test, determine the temperature of the concrete	ASTM C172, C31; ACI 318: 5.6, 5.8	
IBC	4. Inspection for maintenance of specified curing temperature and techniques	ACI 318; 5.11-5.13	1913.9
IBC	5. Verifying use of required design mix	ACI 318: Ch. 4, 5.2-5.4	1904.22, 1913.2, 1913.3
IBC	6. At the time fresh concrete is sampled to fabricate specimens for strength tests, perform slump and air content tests, determine the temperature of the concrete	ASTM C172, C31; ACI 318: 5.6, 5.8	
DGS	Review Contractors' design mixes, Certificates of Compliance and material test reports		
DGS	Compressive Strength of Cylindrical Concrete Specimens ²	ASTM C39	
	STEEL CONSTRUCTION		
IBC	1. Material verification of high-strength bolts, nuts, and washers: a. Identification markings to conform to ASTM standards spec in the approved CDs. b. Manufacturer's Certificate of Compliance required	AISC 360, Section A3.3 and applicable ASTM material standards	
IBC	2. Inspection of high-strength bolting: a. Snug-tight.	AISC 360, Section M2.5	1704.3.3
IBC	3. Inspection of welding: a. Structural steel 1) Multi-Pass fillet welds 2) Single-pass fillet welds > 5/16" 3) Single-pass fillet welds < 5/16"	AWS D1.1	1704.3.1
DGS	Guide for Magnetic Particle Examination	ASTM E709	
DGS	Practice for Ultrasonic Contact Examination of Weldments	ASTM E164	

Footnotes:

1. "DGS" are test required by DGS and "IBC" are tests required by Chapter 17 of the 2009 International Building Code.
2. IBC 2009.
3. Quality Assurance for soils shall be performed/provided by the Professional's Foundation Consultant/Geotechnical Engineer under a separate work order issued by the Department to the Professional.
4. Refers to reference ACI 530/ASCE 5/TMS 402.
5. Refers to reference ACI 530.1/ASCE 6/TMS 602.
6. Concrete, mortar and grout molds are to be made by QA Agent Under Special Inspection hours.

END OF SECTION 014010