



KEYED DEMOLITION NOTES

- 1

REMOVE COMBUSTION AIR SUPPLY FANS IN ENTIRETY. DISCONNECT FROM COMBUSTION AIR DUCTWORK AS SHOWN. COMBUSTION AIR DUCTWORK SHALL REMAIN FOR RECONNECTION. HOUSEKEEPING PADS SHALL BE REMOVED BY :1 CONTRACTOR.
- 2

2" HIGH PRESSURE STEAM, 2" HIGH PRESSURE RETURN, AND 3" EXHAUST PIPING DEDICATED FOR STEAM DRIVEN TURBINE FAN SHALL BE REMOVED IN ENTIRETY.
- 3

OUTSIDE AIR INTAKE AND SOOT RETURN PIPING SHALL BE REMOVED IN ENTIRETY.
- 4

BLOWDOWN TANK AND ALL ASSOCIATED PIPING SHALL BE REMOVED IN ENTIRETY.
- 5

2" PUMP DISCHARGE PIPING SHALL BE REMOVED FROM TOP OF PIT TO POINT OF DISCHARGE.

1

H-2

BASEMENT LEVEL PLAN – SEQUENCE 1 MECHANICAL DEMOLITION

SCALE: 1/4" = 1'-0"

TRUE

PROJECT

VERIFY SCALE

BAR IS ONE (1) INCH LONG ON ORIGINAL DRAWING:  
0 1  
IF BAR IS NOT ONE (1) INCH LONG, ADJUST SCALE ACCORDINGLY

CONTRACTOR SHALL FIELD VERIFY ALL DIMENSIONS. VARIANCE FROM CONTRACT DOCUMENTS NOT PERMITTED WITHOUT PROFESSIONAL & BUREAU OF CONSTRUCTION APPROVAL.

DRAWN BY

MTD

DATE

FEB 2023

CHECKED BY

RS

SCALE

AS NOTED

DRAWING No.

H-2

REBID SUBMISSION  
FEBRUARY 26, 2024

RECORD REVISIONS			
<div><div></div><div>SIGNATURE</div><div>DATE 02-26-2024</div></div>			
ARRIS ENGINEERING GROUP, LTD. 667 SOUTH RIVER STREET PLAINS, PENNSYLVANIA			
COMMONWEALTH OF PENNSYLVANIA DEPARTMENT OF GENERAL SERVICES HARRISBURG, PENNSYLVANIA			
D.G.S. PROJECT No. C-0304-0015 PHASE 2			
ELIZABETHTOWN TRAINING ACADEMY – RENOVATE BOILER PLANT AND DOMESTIC / FIRE PROTECTION PIPING DEPARTMENT of CORRECTIONS ELIZABETHTOWN, LANCASTER COUNTY, PA			
BASEMENT LEVEL PLAN – SEQUENCE 1 MECHANICAL DEMOLITION			