

1 / E-10 MEZZANINE LEVEL – SEQUENCE 2 ELECTRICAL DEMOLITION PLAN
SCALE: 1/4" = 1'-0"

TRUE PROJECT

KEYED DEMOLITION NOTES

1. DEAERATOR TANK REMOVED BY .2 CONTRACTOR. .4 CONTRACTOR TO REMOVE STARTER, DISCONNECT SWITCH AND TEMPORARY 3P CIRCUIT ENTIRELY. COORDINATE REMOVAL WITH .2 CONTRACTOR SEQUENCING.
2. COAL SILO REMOVED IN ITS ENTIRETY BY .1 CONTRACTOR. REMOVE ALL ELECTRICAL APPURTENANCES, LIGHTING FIXTURES, CONDUIT AND WIRING ASSOCIATED WITH COAL SILO.

GENERAL DEMOLITION NOTES

1. .4 CONTRACTOR SHALL COORDINATE ALL REMOVALS WITH OTHER TRADES.
2. .4 CONTRACTOR SHALL REMOVE ALL ELECTRICAL EQUIPMENT INCLUDING ALL EXPOSED CONDUIT AND WIRING FROM SOURCE PANELS AND TO EQUIPMENT LOADS.
3. ALL PATCHING OF FLOORS AND WALLS (TO MATCH EXISTING) BY .1 CONTRACTOR UNLESS NOTED OTHERWISE.
4. VERIFY ALL CONDUIT ROUTING IN FIELD.

LEGEND

HATCHING INDICATES REMOVAL BY .4 CONTRACTOR.

HATCHING INDICATES REMOVAL BY OTHERS.

REBID SUBMISSION
FEBRUARY 26, 2024

RECORD REVISIONS

COMMONWEALTH OF PENNSYLVANIA
RICHARD SZATKOWSKI
ENGINEER
No. 044545-E

02-26-2024
SIGNATURE DATE

ARRIS ENGINEERING GROUP, LTD.
667 SOUTH RIVER STREET
PLAINS, PENNSYLVANIA

COMMONWEALTH OF PENNSYLVANIA
DEPARTMENT OF GENERAL SERVICES
HARRISBURG, PENNSYLVANIA

D.G.S. PROJECT No.
C-0304-0015 PHASE 2

ELIZABETHTOWN TRAINING ACADEMY – RENOVATE BOILER PLANT AND DOMESTIC / FIRE PROTECTION PIPING
DEPARTMENT of CORRECTIONS
ELIZABETHTOWN, LANCASTER COUNTY, PA

MEZZANINE LEVEL – SEQUENCE 2 ELECTRICAL DEMOLITION PLAN

VERIFY SCALE

BAR IS ONE (1) INCH LONG ON ORIGINAL DRAWING:
0 — 1
IF BAR IS NOT ONE (1) INCH LONG, ADJUST SCALE ACCORDINGLY

CONTRACTOR SHALL FIELD VERIFY ALL DIMENSIONS. VARIANCE FROM CONTRACT DOCUMENTS NOT PERMITTED WITHOUT PROFESSIONAL & BUREAU OF CONSTRUCTION APPROVAL.

DRAWN BY	DATE	DRAWING No.
S LOVE	FEB 2023	E-10
CHECKED BY	SCALE	
R SZATKOWSKI	AS NOTED	

FILE PATH: F:\1400.01 0304-0015 P2 Elizabethtown Boiler\Drawings\Ve Base Bid Drawings\Electrical CD\E-10_ Sec.2 Mezzanine Level Electrical Demolition Plan.dwg
LAST SAVED: 2024.02.23 02:41 PM