





- ① PROVIDE 6" CURB STOP AND FIRE HYDRANT ASSEMBLY. REFER TO DETAIL 1 SHEET FP-4 FOR COMPLETE INSTALLATION REQUIREMENTS.
- ② PROVIDE TEE IN WATER MAIN, 6" CURB STOP AND FIRE HYDRANT ASSEMBLY. REFER TO DETAIL 2 SHEET FP-4 FOR COMPLETE INSTALLATION REQUIREMENTS.
- ③ CONTRACTOR SHALL SAW CUT PAVEMENT FOR INSTALLATION OF NEW 6" FIRE LINE. SEE TYPICAL TRENCH DETAIL FOR ADDITIONAL INFORMATION.
- ④ REPAIR ROADWAY PAVEMENT, CONCRETE CURBS, SIDEWALK AND LAWN AREAS PER APPLICABLE DETAILS AND SPECIFICATIONS.
- ⑤ PROVIDE THRUST BLOCKS - 2'X2'X2' 3000PSI CONCRETE.



ENLARGED PARTIAL SITE FIRE PROTECTION PLAN


SCALE: 1/16" = 1'-0"



5 ENLARGED PARTIAL SITE FIRE PROTECTION PLAN  
FP-2 SCALE: 1/16" = 1'-0"


RECORD REVISIONS



07-26-2024

QUALITY INC

## SITE FIRE PROTECTION PLAN NEW WORK

<p><b>VERIFY SCALE</b></p> <p>BAR IS ONE (1) INCH LONG ON ORIGINAL DRAWING:</p> <p>0  1</p> <p>IF BAR IS NOT ONE (1) INCH LONG, ADJUST SCALE ACCORDINGLY</p> <p>CONTRACTOR SHALL FIELD VERIFY ALL DIMENSIONS VARIANCE FROM CONTRACT DOCUMENTS NOT PERMITTED WITHOUT PROFESSIONAL &amp; BUREAU OF CONSTRUCTION APPROVAL.</p>	<p>SOILER PUMP AND 1" FIRE PROTECTION PIPING</p> <p>DEPARTMENT OF CORRECTIONS</p> <p>ELIZABETHTOWN, LANCASTER COUNTY, PA</p>		
	<p>SITE FIRE PROTECTION PLAN</p> <p>NEW WORK</p>		
<p>DRAWN BY</p> <p>D NEVEL</p> <p>CHECKED BY</p> <p>R SZATKOWSKI</p>	<p>DATE</p> <p>FEB 2023</p> <p>SCALE</p> <p>AS NOTED</p>	<p>DRAWING No.</p> <p>FP-2</p>	