

KEYED DEMOLITION NOTES

1. REMOVE COAL BOILER IN ENTIRETY. ISOLATE ALL PIPING AND REMOVE PIPING AS SHOWN.
2. REMOVE BOILER BREECHING IN ENTIRETY BETWEEN BOILERS AND CHIMNEY.
3. NOT USED.
4. TURBINE EXHAUST PIPING SHALL BE REMOVED IN ENTIRETY.
5. WATER HEATER, WATER SOFTENERS, AND ASSOCIATED EQUIPMENT SHALL BE DISASSEMBLED AND TEMPORARILY RELOCATED. COORDINATE ALL WORK WITH CLIENT AGENCY WATER TREATMENT VENDOR –PROASYS– MARTY MEYERS @ 484–824–2742.

1 / H–4 MEZZANINE LEVEL PLAN – SEQUENCE 1 MECHANICAL DEMOLITION
SCALE: 1/4" = 1'–0"

TRUE PROJECT

REBID SUBMISSION
FEBRUARY 26, 2024

RECORD REVISIONS

COMMONWEALTH OF PENNSYLVANIA
REGISTERED PROFESSIONAL
RICHARD SZATKOWSKI
ENGINEER
No. 044441-E
PENNSYLVANIA

SIGNATURE 02–26–2024 DATE

ARRIS ENGINEERING GROUP, LTD.
667 SOUTH RIVER STREET
PLAINS, PENNSYLVANIA

COMMONWEALTH OF PENNSYLVANIA
DEPARTMENT OF GENERAL SERVICES
HARRISBURG, PENNSYLVANIA

D.G.S. PROJECT No.
C–0304–0015 PHASE 2

ELIZABETHTOWN TRAINING ACADEMY – RENOVATE BOILER PLANT AND DOMESTIC / FIRE PROTECTION PIPING
DEPARTMENT of CORRECTIONS
ELIZABETHTOWN, LANCASTER COUNTY, PA

MEZZANINE LEVEL PLAN – SEQUENCE 1 MECHANICAL DEMOLITION

VERIFY SCALE

BAR IS ONE (1) INCH LONG ON ORIGINAL DRAWING:
0 1
IF BAR IS NOT ONE (1) INCH LONG, ADJUST SCALE ACCORDINGLY

CONTRACTOR SHALL FIELD VERIFY ALL DIMENSIONS. VARIANCE FROM CONTRACT DOCUMENTS NOT PERMITTED WITHOUT PROFESSIONAL & BUREAU OF CONSTRUCTION APPROVAL.

DRAWN BY	DATE	DRAWING No.
MTD	FEB 2023	H–4
CHECKED BY	SCALE	
RS	AS NOTED	

FILE PATH: F:\1400.01 0304–0015 P2 Elizabethtown Boiler\Drawings\No Base Bid Drawings\3.Mechanical CD\H–4 Mezz Floor Plan – Phase 1 Demolition.dwg
LAST SAVED: 2024.02.28 11:53 AM