



- GENERAL SHEET NOTES
- A. MAINTAIN SPACE FOR SERVICE AND MAINTENANCE OF EQUIPMENT.
  - B. PROTECT DRAINS DURING REMAINDER OF CONSTRUCTION PERIOD TO AVOID CLOGGING WITH DIRT AND DEBRIS AND TO PREVENT DAMAGE FROM TRAFFIC AND CONSTRUCTION WORK.
  - C. PLACE PLUGS IN ENDS OF UNCOMPLETED PIPING AT END OF DAY AND WHEN WORK STOPS.
  - D. INSTALL ISOLATION VALVES ON EACH BRANCH CONNECTION.
  - E. INSTALL SANITARY SLOPED AT MAXIMUM SLOPE TO THE SITE INVERT CONNECTION FROM STARTING CONNECTION. MAINTAIN A MINIMUM OF 1/4" FALL PER FOOT.
  - F. USE A MINIMUM OF 2" OR GREATER PIPING BELOW GRADE FOR SANITARY.
  - G. ROUGH-IN PIPING SERVICES FOR FIXTURES. MOUNT FIXTURES ACCORDING TO CONTRACT DOCUMENTS, LOCAL CODES AND ADA REQUIREMENTS.
  - H. FURNISH AND INSTALL CLEANOUTS AT THE BASE OF EACH STACK.
  - I. REFER TO STRUCTURAL DRAWINGS FOR SEISMIC CLASSIFICATION FOR BUILDING. FURNISH AND INSTALL SEISMIC HANGERS AND SUPPORTS AS REQUIRED.

1 ISOMETRIC - PLUMBING

SCALE:

0 1/2' 1' 1 1/2'


**GREEN BUILDING ENGINEERS**

2548 Brandywine Lane, York, PA 17404  
412-841-4901 717-554-0153

--

426 S THIRD STREET  
SUITE 101  
LEMOYNE, PA 17043  
717-920-2282  
KD3DESIGNSTUDIO.COM

**DESIGN STUDIO**

STORAGE/MAINTENANCE BUILDING  
SHIREMANSTOWN BOROUGH  
201 RR E MAIN STREET  
SHIREMANSTOWN BOROUGH, PA

PLUMBING RISER DIAGRAMS

Reproduction of the material herein or substantial use without written permission of KD3 Design Studio, Inc., violates the Copyright Laws of the United States and will be subject to legal prosecution. Copyright: 2024	
DATE :	01/08/2024
SCALE :	AS NOTED
JOB NO:	544-23
SHEET	
P-901	