

## SECTION 323113 - CHAIN LINK FENCES AND GATES

### PART 1 - GENERAL

#### 1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

#### 1.2 SUMMARY

- A. Section Includes:
  - 1. Chain-link fences.
  - 2. Swing gates.
- B. Related Requirements:

#### 1.3 ACTION SUBMITTALS

- A. Product Data: For each type of product.
  - 1. Include construction details, material descriptions, dimensions of individual components and profiles, and finishes for the following:
    - a. Fence and gate posts, rails, and fittings.
    - b. Chain-link fabric, reinforcements, and attachments.
    - c. Gates and hardware.
- B. Shop Drawings: For each type of fence and gate assembly.
  - 1. Include plans, elevations, sections, details, and attachments to other work.
  - 2. Include accessories, hardware, gate operation, and operational clearances.

#### 1.4 INFORMATIONAL SUBMITTALS

- A. Product Certificates: For each type of chain-link fence and gate.
- B. Product Test Reports: For framework strength according to ASTM F1043, for tests performed by a qualified testing agency.
- C. Sample Warranty: For special warranty.

## 1.5 FIELD CONDITIONS

- A. Field Measurements: Verify layout information for chain-link fences and gates shown on Drawings in relation to property survey and existing structures. Verify dimensions by field measurements.

## 1.6 WARRANTY

- A. Special Warranty: Installer agrees to repair or replace components of chain-link fences and gates that fail in materials or workmanship within specified warranty period.
  - 1. Failures include, but are not limited to, the following:
    - a. Failure to comply with performance requirements.
    - b. Deterioration of metals, metal finishes, and other materials beyond normal weathering.
    - c. Faulty operation of gate hardware.
  - 2. Warranty Period: Five years from date of Substantial Completion.

## PART 2 - PRODUCTS

### 2.1 PERFORMANCE REQUIREMENTS

- A. Delegated Design: Engage a qualified professional engineer to design chain-link fence and gate frameworks.
- B. Structural Performance: Chain-link fence and gate frameworks shall withstand the design wind loads and stresses for fence height(s) and under exposure conditions indicated according to ASCE/SEI 7:
  - 1. Design Wind Load
    - a. Minimum Post Size and Maximum Spacing: Determine according to CLFMI WLG 2445, based on mesh size and pattern specified.

### 2.2 CHAIN-LINK FENCE FABRIC

- A. General: Provide fabric in one-piece heights measured between top and bottom of outer edge of selvage knuckle or twist according to "CLFMI Product Manual" and requirements indicated below:
  - 1. Fabric Height: As indicated on Drawings.
  - 2. Steel Wire for Fabric: Wire diameter of 0.148 inch (3.76 mm).
    - a. Mesh Size: 1 .75 inch (44.45 mm)
    - b. Polymer-Coated Fabric: ASTM F668.
      - 1) Color: Black according to ASTM F934.

3. Selvage: Knuckled at both selvages.

## 2.3 FENCE FRAMEWORK

- A. Posts and Rails: ASTM F1043 for framework, including rails, braces, and line; terminal; and corner posts. Provide members with minimum dimensions and wall thickness according to ASTM F1043 or ASTM F1083 based on the following:
  1. Fence Height: As indicated on Drawings.
  2. Heavy-Industrial-Strength Material: Group IA, round steel pipe, Schedule 40.
    - a. Line Post: As noted.
    - b. End, Corner, and Pull Posts: As noted.
  3. Horizontal Framework Members: Intermediate, top, and bottom rails according to ASTM F1043.
  4. Brace Rails: ASTM F1043.
  5. Polymer coating over metallic coating.
    - a. Color: Black, according to ASTM F934.

## 2.4 SWING GATES

- A. General: ASTM F900 for gate posts and single and double swing gate types.
  1. Gate Leaf Width: As indicated.
  2. Framework Member Sizes and Strength: Based on gate fabric height as indicated.
- B. Pipe and Tubing:
  1. Zinc-Coated Steel: ASTM F1043 and ASTM F1083; protective coating and finish to match fence framework.
  2. Gate Posts: Round tubular steel.
  3. Gate Frames and Bracing: Round tubular steel
- C. Frame Corner Construction: Welded.
- D. Hardware:
  1. Hinges: 180-degree inward/outward swing.
  2. Latch: Permitting operation from both sides of gate with provision for padlocking accessible from both sides of gate.
  3. Padlock and Chain: By Owner.
  4. Closer: Manufacturer's standard.

## 2.5 FITTINGS

- A. Provide fittings according to ASTM F626.
- B. Post Caps: Provide for each post.

- C. Tie Wires, Clips, and Fasteners: According to ASTM F626.
  - 1. Standard Round Wire Ties: For attaching chain-link fabric to posts, rails, and frames, according to the following:
    - a. Hot-Dip Galvanized Steel: 0.148-inch- (3.76-mm-) diameter wire
- D. Finish:
  - a. Polymer coating over metallic coating.

### PART 3 - EXECUTION

#### 3.1 EXAMINATION

- A. Examine areas and conditions, with Installer present, for compliance with requirements for[ **a certified survey of property lines and legal boundaries,**] site clearing, earthwork, pavement work, and other conditions affecting performance of the Work.
  - 1. Do not begin installation before final grading is completed unless otherwise permitted by Architect.
- B. Proceed with installation only after unsatisfactory conditions have been corrected.

#### 3.2 PREPARATION

- A. Stake locations of fence lines, gates, and terminal posts. Do not exceed intervals of 500 feet (152 m) or line of sight between stakes. Indicate locations of utilities, lawn sprinkler system, underground structures, benchmarks, and property monuments.

#### 3.3 CHAIN-LINK FENCE INSTALLATION

- A. Install chain-link fencing according to ASTM F567 and more stringent requirements specified.
- B. Post Excavation: Drill or hand-excavate holes for posts to diameters and spacings indicated, in firm, undisturbed soil.
- C. Post Setting: Set posts in concrete at indicated spacing into firm, undisturbed soil.
  - 1. Verify that posts are set plumb, aligned, and at correct height and spacing, and hold in position during setting with concrete or mechanical devices.
  - 2. Concrete Fill: Place concrete around posts to dimensions indicated and vibrate or tamp for consolidation. Protect aboveground portion of posts from concrete splatter.
    - a. Concealed Concrete: Place top of concrete 2 inches (50 mm) below grade to allow covering with surface material.
    - b. Posts Set into Sleeves in Concrete: Use steel pipe sleeves preset and anchored into concrete for installing posts. After posts are inserted into sleeves, fill annular space between post and sleeve with nonshrink, nonmetallic grout, mixed and

placed according to anchoring material manufacturer's written instructions. Finish anchorage joint to slope away from post to drain water.

- D. Terminal Posts: Install terminal end, corner, and gate posts according to ASTM F567 and terminal pull posts at changes in horizontal or vertical alignment of 15 degrees or more. For runs exceeding 500 feet (152 m), space pull posts an equal distance between corner or end posts.
- E. Line Posts: Space line posts uniformly at 10 feet (3 m) o.c.
- F. Post Bracing and Intermediate Rails: Install according to ASTM F567, maintaining plumb position and alignment of fence posts. Diagonally brace terminal posts to adjacent line posts with truss rods and turnbuckles. Install braces at end and gate posts and at both sides of corner and pull posts.
  - 1. Locate horizontal braces at midheight of fabric 72 inches (1830 mm) or higher, on fences with top rail, and at two-third fabric height on fences without top rail. Install so posts are plumb when diagonal rod is under proper tension.
- G. Top Rail: Install according to ASTM F567, maintaining plumb position and alignment of fence posts. Run rail continuously through line post caps, bending to radius for curved runs and terminating into rail end attached to posts or post caps fabricated to receive rail at terminal posts. Provide expansion couplings as recommended in writing by fencing manufacturer.
- H. Intermediate and Bottom Rails: Secure to posts with fittings.
- I. Chain-Link Fabric: Apply fabric to outside of enclosing framework (to be confirmed with Architect prior to installation). Leave 2-inch (50-mm) bottom clearance between finish grade or surface and bottom selvage unless otherwise indicated. Pull fabric taut and tie to posts, rails, and tension wires. Anchor to framework so fabric remains under tension after pulling force is released.
- J. Tension or Stretcher Bars: Thread through fabric and secure to end, corner, pull, and gate posts, with tension bands spaced not more than 15 inches (380 mm) o.c.
- K. Tie Wires: Use wire of proper length to firmly secure fabric to line posts and rails. Attach wire at one end to chain-link fabric, wrap wire around post a minimum of 180 degrees, and attach other end to chain-link fabric according to ASTM F626. Bend ends of wire to minimize hazard to individuals and clothing.
  - 1. Maximum Spacing: Tie fabric to line posts at 12 inches (300 mm) o.c. and to braces at 12 inches (610 mm) o.c.
- L. Fasteners: Install nuts for tension bands and carriage bolts on the side of fence opposite the fabric side.

### 3.4 GATE INSTALLATION

- A. Install gates according to manufacturer's written instructions, level, plumb, and secure for full opening without interference. Attach fabric as for fencing. Attach hardware using tamper-resistant or concealed means. Install ground-set items in concrete for anchorage. Adjust hardware for smooth operation.

3.5 ADJUSTING

- A. Gates: Adjust gates to operate smoothly, easily, and quietly, free of binding, warp, excessive deflection, distortion, nonalignment, misplacement, disruption, or malfunction, throughout entire operational range. Confirm that latches and locks engage accurately and securely without forcing or binding.
- B. Lubricate hardware and other moving parts.

END OF SECTION 323113