

SECTION 22 05 00 - COMMON WORK RESULTS FOR PLUMBING

PART 1 - GENERAL

1.1 SUMMARY

A. Section Includes:

1. Motors.
2. Sleeves without waterstop.
3. Sleeves with waterstop.
4. Sleeve-seal systems.
5. Grout.
6. Silicone sealants.
7. Escutcheons.
8. Thermometers, bimetallic actuated, lead free.
9. Thermowells, lead free.
10. Pressure gauges, dial type, lead free.
11. Gauge attachments, lead free.

B. Related Requirements:

1. Section 22 11 19 "Domestic Water Piping Specialties" for water meters.

1.2 DEFINITIONS

- A. Existing Piping to Remain: Existing piping that is not to be removed and that is not otherwise indicated to be removed, removed and salvaged, or removed and reinstalled.

1.3 ACTION SUBMITTALS

A. Product Data:

1. For each type of product, excluding motors which are included in Part 1 of the plumbing equipment Sections.
 - a. Include construction details, material descriptions, and dimensions of individual components, and finishes.
 - b. Include operating characteristics and furnished accessories.

1.4 INFORMATIONAL SUBMITTALS

- A. Welding certificates.
- B. Field quality-control reports.

1.5 CLOSEOUT SUBMITTALS

- A. Operation and Maintenance Data: For each type of product to include in operation and maintenance manuals.

1.6 QUALITY ASSURANCE

- A. Welding Qualifications: Qualify procedures and personnel in accordance with AWS D1.1/D1.1M.

1.7 COORDINATION

- A. Coordinate features of motors, installed units, and accessory devices to be compatible with the following:
 - 1. Motor controllers.
 - 2. Torque, speed, and horsepower requirements of the load.
 - 3. Ratings and characteristics of supply circuit and required control sequence.
 - 4. Ambient and environmental conditions of installation location.

PART 2 - PRODUCTS

2.1 PERFORMANCE REQUIREMENTS

- A. Domestic water materials for plumbing piping intended to convey or dispense water for human consumption are to comply with the U.S. Safe Drinking Water Act, with requirements of authorities having jurisdiction, and with NSF 61 and NSF 372, or be certified in compliance with NSF 61 and NSF 372 by an ANSI-accredited third-party certification body, in that the weighted average lead content at wetted surfaces is less than or equal to 0.25 percent.
- B. Compatibility: Provide products suitable for piping service fluids, materials, working pressures, and temperatures.
- C. Capability: Provide products and installations to accommodate maximum axial movement as scheduled or indicated on Drawings.

2.2 MOTORS

- A. Motor Requirements, General:
 - 1. Content includes motors for use on alternating-current power systems of up to 600 V and installed at equipment manufacturer's factory or shipped separately by equipment manufacturer for field installation.
 - 2. Comply with requirements in this Section except when stricter requirements are specified in equipment schedules or Sections.
 - 3. Comply with NEMA MG 1 unless otherwise indicated.
 - 4. Comply with IEEE 841 for severe-duty motors.

B. Motor Characteristics:

1. Duty: Continuous duty at ambient temperature of 40 deg C and at altitude of 3300 ft. above sea level.
2. Capacity and Torque Characteristics: Sufficient to start, accelerate, and operate connected loads at designated speeds, at installed altitude and environment, with indicated operating sequence, and without exceeding nameplate ratings or considering service factor.

C. Single-Phase Motors:

1. Motors larger than 1/20 hp must be one of the following, to suit starting torque and requirements of specific motor application:
 - a. Permanent-split capacitor.
 - b. Split phase.
 - c. Capacitor start, inductor run.
 - d. Capacitor start, capacitor run.
2. Multispeed Motors: Variable-torque, permanent-split-capacitor type.
3. Bearings: Prelubricated, antifriction ball bearings or sleeve bearings suitable for radial and thrust loading.
4. Motors 1/20 HP and Smaller: Shaded-pole type.
5. Thermal Protection: Internal protection to automatically open power supply circuit to motor when winding temperature exceeds a safe value calibrated to temperature rating of motor insulation. Thermal-protection device will automatically reset when motor temperature returns to normal range.

2.3 SLEEVES AND SLEEVE SEALS

A. Sleeves without Waterstop:

1. Steel Pipe Sleeves: ASTM A53/A53M, Type E, Grade B, Schedule 40, hot-dip galvanized, with plain ends.

B. Sleeves with Waterstop:

1. Description: Manufactured galvanized-steel, sleeve-type, waterstop assembly made for imbedding in concrete slab or wall.

C. Sleeve-Seal Systems:

1. Description: Modular sealing-element unit, designed for field assembly, for filling annular space between piping and sleeve.
 - a. Sealing Elements: EPDM-rubber interlocking links shaped to fit surface of pipe. Include type and number required for pipe material and size of pipe.
 - b. Pressure Plates: Carbon steel.
 - c. Connecting Bolts and Nuts: Carbon steel, with zinc coating, ASTM B633 of length required to secure pressure plates to sealing elements.

D. Grout:

1. Description: Nonshrink, for interior and exterior sealing openings in non-fire-rated walls or floors.
2. Standard: ASTM C1107/C1107M, Grade B, post-hardening and volume-adjusting, dry, hydraulic-cement grout.
3. Design Mix: 5000 psi, 28-day compressive strength.
4. Packaging: Premixed and factory packaged.

E. Silicone Sealants:

1. Silicone Sealant, S, NS, 25, NT: Single-component, nonsag, plus 25 percent and minus 25 percent movement capability, nontraffic-use, neutral-curing silicone joint sealant.
 - a. Standard: ASTM C920, Type S, Grade NS, Class 25, Use NT.
2. Silicone Sealant, S, P, T, NT: Single-component, , pourable, plus 100 percent and minus 50 percent movement capability, traffic- and nontraffic-use, neutral-curing silicone joint sealant.
 - a. Standard: ASTM C920, Type S, Grade P, Class 100/50, Uses T and NT.

2.4 ESCUTCHEONS

A. Escutcheon Types:

1. One-Piece, Cast-Brass Type: With polished, chrome-plated finish and setscrew fastener.
2. One-Piece, Deep-Pattern Type: Deep-drawn, box-shaped brass with polished, chrome-plated finish and spring-clip fasteners.
3. One-Piece, Stamped-Steel Type: With polished, chrome-plated finish and spring-clip fasteners.
4. Retain one or both finish options in "Split-Plate, Stamped-Steel Type" Subparagraph below that match escutcheon types retained in Part 3. Escutcheons described in subparagraph are generally available in 5/8-inch OD, 7/8-inch OD, 1-1/4-inch OD, 1-1/2-inch (38-mm) OD, 3/8-inch IPS, 1/2-inch IPS, 3/4-inch IPS, 1-inch IPS, 1-1/4-inch IPS, 1-1/2-inch IPS, and 2-inch IPS.
5. Split-Plate, Stamped-Steel Type: With polished, chrome-plated finish; concealed hinge; and spring-clip fasteners.

B. Floor Plates:

1. Split Floor Plates: Cast brass with concealed hinge.

2.5 METERS AND GAUGES FOR PLUMBING PIPING

A. Thermometers, Bimetallic Actuated, Lead Free:

1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
 - a. Ashcroft Inc.
 - b. Terice, H. O. Co.
 - c. WATTS; A Watts Water Technologies Company.

2. Source Limitations: Provide lead-free bimetallic-actuated thermometers from a single manufacturer.
3. Standard: ASME B40.200.
4. Case: Liquid-filled sealed type(s); stainless steel with 3-inch nominal diameter.
5. Dial: Nonreflective aluminum with permanent scale markings and scales in .
6. Connector Type(s): Union joint, rigid, bottom; with ASME B1.1 or ASME B1.20.1 screw threads to fit thermowell.
7. Stem: 0.25 or 0.375 inch in diameter; lead-free brass.
8. Window: Plain glass.
9. Ring: Stainless steel.
10. Element: Bimetal coil.
11. Pointer: Dark-colored metal.
12. Accuracy: Plus or minus 1 percent of span.

B. Thermowells, Lead Free:

1. Standard: ASME B40.200.
2. Description: Pressure-tight, socket-type fitting made for insertion into piping tee fitting.
3. Material for Use with Copper Tubing: Lead-free copper.
4. Type: Stepped shank unless straight or tapered shank is indicated.
5. External Threads: NPS 1/2, NPS 3/4, or NPS 1, or as required to match threaded opening in pipe.
6. Internal Threads: Size and thread type as required to match thermometer mounting threads.
7. Bore: Diameter required to match thermometer bulb or stem.
8. Insertion Length: Length to extend one-third of pipe diameter to match thermometer stem length.
9. Lagging Extension: Include on thermowells for insulated piping and tubing. Extension is to be of sufficient length to extend beyond finished insulation surface.
10. Bushings: For converting size of thermowell's internal screw thread to size of thermometer connection.
11. Heat-Transfer Medium: Mixture of graphite and glycerin.

C. Pressure Gauges, Dial Type, Lead Free - Direct Mounted, Metal Case:

1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
 - a. Ashcroft Inc.
 - b. Trerice, H. O. Co.
 - c. WATTS; A Watts Water Technologies Company.
2. Source Limitations: Provide dial-type, lead-free, direct-mounted, metal-case pressure gauges from single manufacturer.
3. Standard: ASME B40.100.
4. Case: Liquid-filled type(s); cast aluminum or drawn steel; 4-1/2-inch nominal diameter.
5. Pressure-Element Assembly: Lead-free Bourdon tube.
6. Pressure Connection: Lead-free brass, with NPS 1/4 or NPS 1/2, ASME B1.20.1 pipe threads and bottom-outlet type unless back-outlet type is indicated.
7. Movement: Mechanical, with link to pressure element and connection to pointer.
8. Dial: Nonreflective aluminum with permanent scale markings graduated in psi.
9. Pointer: Dark-colored metal.
10. Window: Glass.
11. Ring: Metal.

12. Accuracy: Grade A, plus or minus 1 percent of middle half of span.

D. Gauge Attachments, Lead Free:

1. Snubbers: ASME B40.100, lead-free brass; with NPS 1/4 or NPS 1/2, ASME B1.20.1 pipe threads and piston-type surge-dampening device. Include extension for use on insulated piping.
2. Valves: Lead-free brass ball, with NPS 1/4 or NPS 1/2, ASME B1.20.1 pipe threads.

PART 3 - EXECUTION

3.1 INSTALLATION OF SLEEVES - GENERAL

- A. Install sleeves for piping passing through penetrations in floors, partitions, roofs, and walls.
- B. For sleeves that will have sleeve-seal system installed, select sleeves of size large enough to provide 1-inch annular clear space between piping and concrete slabs and walls.
 1. Sleeves are not required for core-drilled holes.
- C. Install sleeves in concrete floors, concrete roof slabs, and concrete walls as new slabs and walls are constructed.
 1. Permanent sleeves are not required for holes in slabs formed by molded-PE or -PP sleeves.
 2. Cut sleeves to length for mounting flush with both surfaces.
 - a. Exception: Extend sleeves installed in floors of mechanical equipment areas or other wet areas 2 inches above finished floor level.
 3. Using grout or silicone sealant, seal the space outside of sleeves in floors/slabs/walls without sleeve-seal system. Select to maintain fire resistance of floor/slab/wall.
- D. Install sleeves for pipes passing through interior partitions.
 1. Cut sleeves to length for mounting flush with both surfaces.
 2. Install sleeves that are large enough to provide 1/4-inch annular clear space between sleeve and pipe or pipe insulation.
 3. Seal annular space between sleeve and piping or piping insulation; use joint sealants that joint sealant manufacturer's literature indicates is appropriate for size, depth, and location of joint.
- E. Fire-Resistance-Rated Penetrations, Horizontal Assembly Penetrations, and Smoke Barrier Penetrations: Maintain indicated fire or smoke rating of walls, partitions, ceilings, and floors at pipe penetrations. Seal pipe penetrations with fire- and smoke-stop materials. Comply with requirements for firestopping and fill materials specified in Section 07 84 13 "Penetration Firestopping."

3.2 INSTALLATION OF SLEEVES WITH WATERSTOP

- A. Install sleeve with waterstop as new walls and slabs are constructed.

- B. Assemble fitting components of length to be flush with both surfaces of concrete slabs and walls. Position waterstop flange centered across width of concrete slab or wall.
- C. Secure nailing flanges to wooden concrete forms.
- D. Using grout or silicone sealant, seal space around outside of sleeves. Select to maintain fire resistance of floor/slab/wall.

3.3 INSTALLATION OF SLEEVE-SEAL SYSTEMS

- A. Install sleeve-seal systems in sleeves in exterior concrete walls and slabs-on-grade at service piping entries into building, and passing through exterior walls.
- B. Select type, size, and number of sealing elements required for piping material and size and for sleeve ID or hole size. Assemble sleeve-seal system components, and install in annular space between piping and sleeve. Tighten bolts against pressure plates that cause sealing elements to expand and make a watertight seal.

3.4 INSTALLATION OF ESCUTCHEONS

- A. Install escutcheons for piping penetrations of walls, ceilings, and finished floors.
- B. Install escutcheons with ID to closely fit around pipe, tube, and insulation of insulated piping and with OD that completely covers opening.

3.5 INSTALLATION OF METERS AND GAUGES

- A. Install thermometer with thermowell at each required thermometer location.
- B. Install thermowells in vertical position in piping tees.
- C. Install thermowells of sizes required to match thermometer connectors. Include bushings if required to match sizes.
- D. Install thermowells with extension on insulated piping.
- E. Fill thermowells with heat-transfer medium.
- F. Install direct-mounted thermometers in thermowells and adjust vertical and tilted positions.
- G. Install remote-mounted thermometer bulbs in thermowells and install cases on panels; connect cases with tubing and support tubing to prevent kinks.
- H. Install direct-mounted pressure gauges in piping tees with pressure gauge located on pipe at most readable position.
- I. Install remote-mounted pressure gauges on panel.
- J. Install valve and snubber in piping for each pressure gauge for fluids.

- K. Install test plugs in piping tees.
- L. Install thermometers in the following locations:
 - 1. Inlet and outlet of each water heater.
 - 2. Inlets and outlets of each domestic water heat exchanger.
 - 3. Inlet and outlet of each domestic hot-water storage tank.
 - 4. Outlet side of hot-water-balancing valve.
 - 5. Each main hot-water-recirculating line return pipe.
- M. Install pressure gauges in the following locations:
 - 1. Building water service entrance into building.
 - 2. Inlet and outlet of each pressure-reducing valve.
 - 3. Suction and discharge of each domestic water pump.
 - 4. Inlet and outlet of each central water filter

3.6 CONNECTIONS

- A. Install meters and gauges adjacent to machines and equipment to allow space for service and maintenance of meters, gauges, machines, and equipment.

3.7 ADJUSTING

- A. After installation, calibrate meters according to manufacturer's written instructions.
- B. Adjust faces of meters and gauges to proper angle for best visibility.

3.8 FIELD QUALITY CONTROL

- A. Sleeves and Sleeve Seals:
 - 1. Perform the following tests and inspections:
 - a. Leak Test: After allowing for a full cure, test sleeves and sleeve seals for leaks. Repair leaks and retest until no leaks exist.
 - b. Sleeves and sleeve seals will be considered defective if they do not pass tests and inspections.
 - 2. Prepare test and inspection reports.
- B. Escutcheons:
 - 1. Using new materials, replace broken and damaged escutcheons and floor plates.

3.9 SLEEVES APPLICATION

- A. Use sleeves and sleeve seals for the following piping-penetration applications:

1. Exterior Concrete Walls above and below Grade:
 - a. Sleeves with waterstops.
 - 1) Select sleeve size to allow for 1-inch annular clear space between piping and sleeve for installing sleeve-seal system.
2. Concrete Slabs-on-Grade:
 - a. Sleeves with waterstops.
 - 1) Select sleeve size to allow for 1-inch annular clear space between piping and sleeve for installing sleeve-seal system.
3. Concrete Slabs above Grade:
 - a. Sleeves with waterstops or stack-sleeve fittings.
4. Interior Wall and Partitions:
 - a. Sleeves without waterstops.

3.10 ESCUTCHEONS APPLICATION

- A. Escutcheons for New Piping and Relocated Existing Piping:
 1. Piping with Fitting or Sleeve Protruding from Wall: One piece, deep pattern.
 2. Chrome-Plated Piping: One piece, cast brass with polished, chrome-plated finish.
- B. Escutcheons for Existing Piping to Remain:
 1. Chrome-Plated Piping: Split casting, stamped steel with concealed hinge with polished, chrome-plated finish.
- C. Install floor plates for piping penetrations of equipment-room floors.
- D. Install floor plates with ID to closely fit around pipe, tube, and insulation of piping and with OD that completely covers opening.
 1. New Piping and Relocated Existing Piping: One piece, floor plate.
 2. Existing Piping: Split floor plate.

3.11 THERMOMETER, LEAD FREE, APPLICATION

- A. Thermometers are to be the following:
 1. Liquid-filled bimetallic-actuated type.
- B. Thermometer stems are to be of length to match thermowell insertion length.

3.12 THERMOMETER, LEAD FREE, SCALE-RANGE APPLICATION

- A. Scale Range for Domestic Cold-Water Piping:
 - 1. 0 to 100 deg F.
- B. Scale Range for Domestic Hot-Water Piping:
 - 1. 30 to 240 deg F.
- C. Scale Range for Domestic Cooled-Water Piping:
 - 1. 0 to 100 deg F.

3.13 PRESSURE-GAUGE APPLICATION

- A. Pressure gauges are to be the following:
 - 1. Liquid filled, direct mounted, metal case.

3.14 PRESSURE-GAUGE SCALE-RANGE APPLICATION

- A. Scale Range for Water Service Piping:
 - 1. 0 to 160 psi.
- B. Scale Range for Domestic Water Piping:
 - 1. 0 to 100 psi.

END OF SECTION