

ROOF PLAN - POWER

SCALE: 1" = 20'-0"

DRAWING NOTES:

1. MOUNT ROOFTOP RECEPTACLE ON OR ADJACENT TO UNIT MINIMUM 18" ABOVE ROOF. CONNECT RECEPTACLE TO NEAREST EXISTING UNSWITCHED CORRIDOR OR STORAGE ROOM 120V RECEPTACLE CIRCUIT ACCORDINGLY.
2. REFER TO KITCHEN EXHAUST HOOD WIRING DIAGRAM ON DRAWING E-9 FOR CIRCUITING REQUIREMENTS.
3. INTEGRAL CONVENIENCE RECEPTACLE PROVIDED BY EQUIPMENT MANUFACTURER.
4. RUN (2)-2" CONDUITS, WITH 3 #4/0 & #2G IN EACH, TO EXISTING SWITCHBOARD 'LMDP' AND CONNECT TO SPARE 500A/3P CIRCUIT BREAKER. BREAKER MADE SPARE BY REMOVAL OF EXISTING AUDITORIUM DIMMER RACK.
5. PROVIDE 120V WIRING CONNECTION TO UNIT FOR UV LIGHTS, BI-POLAR IONIZATION, ETC.
6. CONNECT TO MANUAL SWITCH BELOW IN ROOM FAN SERVES. SEE APPLICABLE DRAWINGS.



KEY PLAN

SCALE: N.T.S.

CONSOLIDATED ENGINEERS
1022 James Drive
Leesport, PA 19533
Tel: 610-916-1600 Fax: 610-916-1610
Internet: www.consolidatedengineers.com

COMMONWEALTH OF PENNSYLVANIA
PROFESSIONAL
CHRISTOPHER R. WINKLHOFER
ENGINEER

AEM ARCHITECTS INC.
3700 PERKIOMEN AVENUE, READING, PA 19606-2795
Phone: 610.779.3220 Fax: 610.779.9022
www.aem-arch.com

ROOF PLAN - POWER

RENOVATIONS TO THE COCALICO MIDDLE SCHOOL
COCALICO SCHOOL DISTRICT
SOUTH 4TH STREET, DENVER BOROUGH, LANCASTER COUNTY PA

ALL DIMENSIONS and EXISTING CONDITIONS shall be CHECKED and VERIFIED by the CONTRACTOR at the SITE.

JOB NO.: 23001.00
DRAWN BY: DS
DATE: 04.12.24

E-R1