

STANDARD NOTES

- NOTE: ALL SOLID SURFACE DETAILS AND DRAWINGS ARE FOR
CONCEPTUAL PURPOSES---NOT FOR PREFABRICATION

NOTE:




- NOTE:

-SOLID SURFACE TOPS PROVIDED BY DELFIELD
AND SHIPPED LOOSE FROM DELFIELD



-SOLID SURFACE TOPS PROVIDED BY DELFIELD
AND SHIPPED LOOSE FROM DELFIELD

SKU NO. 000-40013UBCA	
MODEL NO. SES-30	ITEM NO. 11
-CASHIER COUNTER	
-3 IN DIAMETER HOLE WITH GROMMET	
-2" S	
-TOP AND LOCKING DRAWER	
-(1) 120V-15A DUPLEX (GFCI)	
RECEPTACLE, NEMA #5-15R WITH	
100A BREAKER	
-(1) LOCATED ON BASE TO ACCOMMODATE	
100 AMP SYSTEM OTHERS	
-(1) RECESSED ON END TO ACCOMMODATE	
TRAILER LENSE MODEL RMC584 SUPPLIED	
AND INSTALLED BY OTHERS	
-120V	
-NEMA NO. 5-30 PLUG WITH 9FT CORD	
120V-50T-1PH-172A	
-(2) SOLID SURFACE TRANSLATE WITH	
PUSH BUTTON	
MOUNTED ON FIXED BRACKETS	



APPROVED FOR FABRICATION





- ☐ APPROVED
☐ APPROVED AS NOTED
☐ RESUBMIT
 COMPANY: _____
 BY _____ DA _____

If you are placing equipment into an area which has certain standards or codes other than those normally accepted in the food - service industry (NSF, UL, etc.) Delfield must be advised of those specifications in detail before fabrication of the equipment in order that we may quote additional costs if any. Failure to notify The Delfield Company before fabrication releases us from any obligation to modify our standards without any additional charges.

- NOTES:

- * TOPS ARE TO BE 14 GAUGE S/S
- * PROVIDE INTERLOCKS AS REQUIRED
- * ALL STANDARD LOCKING POLYURETHANE CASTERS
- * CORDS STANDARD WITH 90° PLUGS
- * UNITS SPECIFIED WITH DRAINS TO HAVE GATE VALVE AND GARDEN HOSE HOOK UP
- * WHEN TRAY SLIDE/WORK SHELF BRACKETS ARE USED: FOLD DOWN BRACKETS ARE STANDARD UNLESS OTHERWISE REQUESTED
- * ALL 120 VOLT RECEPTACLES (15 AND 20 AMP) WILL

- ENVIRONMENTALLY FRIENDLY INSULATION**
- * KYOTO PROTOCOL COMPLIANT
 - * NON G.D.P. (OZONE DEPLETION POTENTIAL)
 - * NON G.W.P. (GLOBAL WARMING POTENTIAL)
 - * POLYURETHANE INSULATION
- SHELLYSTEEL (LAMINATED): PROVIDE ANGULAR FRAME BASES**
- * WITH LAMINATE SIDE PANELS
 - * MANUFACTURER: *VERIFY*
 - * MODEL: *VERIFY*
 - * FINISH: *VERIFY*
 - * DESCRIPTION: *VERIFY*
 - * GRAIN DIRECTION: *VERIFY*



SKU NO. 000-40013UBC9	
MODEL NO SFW-5-NU	ITEM NO. 12
-INDIVIDUALLY CONTROLLED COMBO HOT/COLD/FREEZE PAN SERVING COUNTER	
DRY OPERATION ONLY	
208/240V-60C-1PH-10.0A-(5) @ 1/5HP	
-SOLID SURFACE TRAYS/SLIDE WITH RUNNERS	
-MOUNTED ON FIXED BRACKETS	
-NEMA NO. 14-50 PLUG W/ 3FT CORD	
120-208/240V-60C-1PH-10.0A	
-TEL RIGG/RVCO INTL 17	

SKU NO. 000-CCA13UBCB	
MODEL NO. DCF5FS	ITEM NO. FS-12
-SINGLE TIER, SINGLE SERVICE FLEXIBLE FOOD SHIELD -CONVERTS TO THREE POSITIONS -SUPPORTS WITH S/S FINISH AND CHROME MOUNTING HARDWARE -0.38 TEMPERED GLASS TOP -0.25 TEMPERED GLASS FRONT AND ENDS -(1) 6000 LED LIGHT (120V-0.00A)	

SKU NO. 000-40013/BCC		
MODEL NO. SCSG-60-BP	ITEM NO. 13	
-COLD PAN SERVING COUNTER		
-52.00 BY 21.62 BY 7.00 MECH.		
-COOLED COLD PAN WITH DRAIN		
115V-60C-1PH-32A-1/4HP		
-4" DEEP PANS BY OTHERS		
-SOLID SURFACE TRAYS/SLIDE WITH RUNNERS		
-MOUNTED ON FIXED BRACKETS		
-NEMA 14-20 SINGLE RECEPTACLE		
120/208-240V-60C-1PH-10/2A		
-PIGGYBACK FROM UNIT 12		
-NEMA NO. 14-20 PLUG W/ 3FT CORD		
120-208/240V-60C-1PH-13.5A		

SKU NO. 000-CCA13UBCC	
MODEL NO. DCF5KS	ITEM NO. FS-12
-SINGLE TIER, SINGLE SERVICE FIXED SNEEZE GUARD FRONTS -SUPPORTS WITH S/S FINISH AND CHROME MOUNTING HARDWARE -0.38 TEMPERED GLASS TOP -0.25 TEMPERED GLASS FRONT AND ENDS -(1) 36.00 LED LIGHT (120V-0.12A)	

SKU NO. 000-40013UBCD
MODEL NO. SCTF-30-NUP | ITEM NO. 14
-FROST TOP SERVING COUNTER
-37-13 LONG BY 19-69 WIDE MECH.
COOLED FROST TOP
-113V-60C-1PH-2-3A-1/5HP
-SOLID SURFACE TRAYSIDE WITH
RUNNERS
-MOUNTED ON FIXED BRACKETS
-NEMA 14-20 SINGLE RECEPTACLE
120-208-240V-60C-1PH-13.52A
-PIGGYBACK FROM UNIT 13
-NEMA NO. 14-20 PLUG W/ 3FT CORD
120-208/240V-60C-1PH-13.52A
-TO PIGGYBACK INTO 15

SKU NO. 000-CCA3UBCD	
MODEL NO. DCFSS	ITEM NO. FS-14
-SINGLE TIER, SINGLE SERVICE FIXED SNEEZE GUARD FRONTS -SUPPORTS WITH S/S FINISH AND CHROME MOUNTING HARDWARE -0.38 TEMPERED GLASS TOP -0.25 TEMPERED GLASS FRONT AND ENDS -(1) 36.00 LED LIGHT (120V-0.12A)	

SKU NO. 000-40013UBCE
MODEL NO. SC-36-NU ITEM NO. 15
-ALL PURPOSE COUNTER
-SOLID SURFACE TRAYS/SLIDE WITH RUNNERS
-MOUNTED ON FIXED BRACKETS
-NEMA 14-20 SINGLE RECEPTACLE 120/208-240V-60C-1PH-13.52A
-PIGGYBACK FROM UNIT 14
-NEMA NO. 14-20 PLUG W/ 9FT CORD 120/208-240V-60C-1PH-13.56A

SKU NO. 000-CCA13UBCE	
MODEL NO. DCF5K5	ITEM NO. FS-15
-SINGLE TIER, SINGLE SERVICE FIXED SNEEZE GUARD FRONT -SUPPORTS WITH S/S FINISH AND CHROME MOUNTING HARDWARE -0.38 TEMPERED GLASS TOP -0.25 TEMPERED GLASS FRONT AND ENDS -C1> 1200 LED LIGHT (120V-0.04A)	

SKU NO 000-40012B/CF	
MODEL NO SCCS-30	ITEM NO 16
-CASHIER COUNTER	
-3 IN DIAMETER HOLE WITH GROMMET IN TOP	
-SCS SHELF AND LOCKING DRAWER	
-120V-15A DUPLEX GFCID RECEPTACLE, NEMA 5-15R WITH 10/0A BREAKER	
-(1) LOCATED ON BASE TO ACCOMMODATE	
-(1) LOCATED BY OTHERS	
-(1) RECESSED IN END TO ACCOMMODATE TRALESEN MODEL 49C495A SUPPLIED AND INSTALLED BY OTHERS	
-120V-7.2A NEMA 5-15P	
-NEMA 10-30 1-PH 3-PH WITH 9FT CORD	
120V-60C-15P-17.2A	
-SOLID SURFACE TRAYSIDE WITH RUNNERS	
-MOUNTED ON FIXED BRACKETS	

AEM ARCHITECTS INC.
7700 PERKIOMEN AVENUE, READING, PA 19606-2795

SOUTH 4TH STREET DENVER BOROUGH | LANCASTER COUNTY PA

ALL DIMENSIONS and EXISTING CONDITIONS
shall be CHECKED and VERIFIED
by the CONTRACTOR at the SITE.

JOB NO.: 23001.00
DRAWN BY: CL
DATE: 04.12.24

FS-7