



1. REFER TO DRAWING H-4 FOR HVAC GENERAL PROJECT NOTES.
2. PROVIDE REQUIRED SERVICE CLEARANCE FOR ALL HVAC UNITS AS RECOMMENDED BY THE EQUIPMENT MANUFACTURER.
3. THE HVAC CONTRACTOR IS RESPONSIBLE FOR ALL CUTTING AND PATCHING REQUIRED TO COMPLETE ALL INDICATED WORK.
4. THE HVAC CONTRACTOR IS RESPONSIBLE FOR ALL EXCAVATION AND BACKFILLING NOT INDICATED OR PROVIDED BY THE GENERAL CONTRACTOR ELSEWHERE IN THE DOCUMENTS THAT IS REQUIRED TO COMPLETE ALL INDICATED HVAC WORK.
5. REFER TO ARCHITECTURAL REFLECTED CEILING PLANS FOR EXACT LOCATIONS OF HVAC CEILING OUTLETS AND OTHER CEILING MOUNTED EQUIPMENT. CEILING REPAIRS AND PATCHING FOR WORK TO BE COMPLETED UNDER THIS CONTRACT, THAT IS NOT INDICATED ON THE ARCHITECTURAL PLANS, SHALL BE THE RESPONSIBILITY OF THIS CONTRACTOR. CEILING REPAIRS AND PATCHING SHALL BE REPLACE AND/OR REPAIRED BY HIM, AS PER SPECIFICATIONS.

- ① PROVIDE 1" x 1" STAINLESS STEEL SCREEN OVER END OF DUCT OPENING AND SECURE IN PLACE ON ALL SIDES.
- ② RISE DUCTWORK UP ABOVE EXISTING ELECTRICAL CONDUIT AND ROUTE UP IN BETWEEN EXISTING BAR JOIST AS REQUIRED, EXTEND AND CONNECT TO INDICATED AIR TERMINAL OUTLET DEVICE.

SECOND FLOOR

FIRST FLOOR

DENVER
ELEMENTARY
SCHOOL

KEY PLAN

SCALE N.T.S.