NEW U/G DOMESTIC PIPING SEE P-03 FOR ROUTING.

NAT GAS METER BY UGI

U/G FUEL OIL TANK REMOVED BY HC

CONNECT 6" UG FP TO EXISTING 6" COMBINED DCW SUPPLY AND ROUTE TO NEW FP PUMP HOUSE

ELECTRONIC GONG PROVIDED BY F.P.C.

4" TO 5" STORZ F.D.C. VERIFY THREAD TYPE WITH LOCAL AUTHORITY, BY F.P.C.

STUB AND CAP 6" UG FP FOR FUTURE EXTENSION TO DENVER ELEMENTARY

PRE-INSULATED PACKAGED FIRE PUMP BUILDING BY FPC – SEE DETAILS DRAWING SHT FP-4.

FUTURE 6" DIP UNDERGROUND FP

MEDIUM VOLTAGE SWITCHGEAR BY EC SEE DETAIL ON DWG. E-2.

HANDHOLE BY EC. SEE DETAIL ON DWG. E-2.

NEW COMBINED METER PIT BY OTHERS

EMERGENCY GENERATOR

6" DIP UNDERGROUND FP

2024 SURVEY
2014 SURVEY

S. 4TH STREET

SITE PLAN - PLUMBING AND FIRE PROTECTION

SCALE: 1" = 40'-0"

DRAWING NOTES:

1. REFER TO 21510, 22510 FOR UNDERGROUND PIPE BEDDING MATERIALS.

CONSOLIDATED ENGINEERS
1022 James Drive
Leesport, PA 19533
Tel: 610-916-1600 Fax: 610-916-1610
Internet: www.consolidatedengineers.com

COMMONWEALTH OF PENNSYLVANIA
REGISTERED PROFESSIONAL
ADAM NICHOLAS MOSER
ENGINEER

AEM ARCHITECTS INC.
3700 PERKIOMEN AVENUE, READING, PA 19606-2795
Phone: 610.779.3220 Fax: 610.779.9022
www.aem-arch.com

SITE PLAN - PLUMBING AND FIRE PROTECTION

RENOVATIONS TO THE COCALICO MIDDLE SCHOOL

COCALICO SCHOOL DISTRICT

SOUTH 4TH STREET, DENVER BOROUGH, LANCASTER COUNTY PA

ALL DIMENSIONS and EXISTING CONDITIONS shall be CHECKED and VERIFIED by the CONTRACTOR at the SITE.

JOB NO.: 23001.00
DRAWN BY: RLC
DATE: 04.12.24

PFP-1