

SECTION 05 31 00 - STEEL DECKING

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General Conditions and Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. Section Includes:

- 1. Roof deck.

- B. Related Requirements:

- 1. Division 01 Section "Coordination Drawings" for requirements to coordinate the work of this Section with the construction elements indicated as "Coordination Drawing Content" and as required by the other Prime Contractors for the Project Coordination Drawings.
- 2. Division 03 Section "Cast-in-Place Concrete" for normal-weight and lightweight structural concrete fill over steel deck.
- 3. Division 05 Section "Structural Steel Framing" for shop- and field-welded shear connectors.
- 4. Division 05 Section "Steel Joists."
- 5. Division 05 Section "Metal Fabrications" for framing deck openings with miscellaneous steel shapes.
- 6. Division 09 Section "Painting and Finishing" for repair painting of primed deck and finish painting of deck.

1.3 ACTION SUBMITTALS

- A. Product Data: For each type of deck, accessory, and product indicated.

- B. Shop Drawings:

- 1. Include layout and types of deck panels, anchorage details, reinforcing channels, pans, cut deck openings, special jointing, accessories, and attachments to other construction.
- 2. For steel deck indicated to comply with certain design loadings, include structural analysis data sealed and signed by the qualified professional engineer who was responsible for its preparation.

1.4 INFORMATIONAL SUBMITTALS

- A. Manufacturer's Data:

- 1. Manufacturer's specifications and installation instructions for each product specified. Include manufacturer's certification as may be required to show compliance with these specifications. Indicate by transmittal form that a copy of each instruction has been distributed to the Installer.

- B. Welding certificates.

- C. Product Certificates: For each type of steel deck signed by steel deck manufacturer certifying compliance with requirements.
- D. Field quality-control reports from testing agency.
- E. Code Compliance: Provide documentation demonstrating compliance with the version of the International Building Code in effect for the Project and as acceptable to the authorities having jurisdiction.

1.5 QUALITY ASSURANCE

- A. Installer Qualifications: An experienced installer who has completed steel deck similar in material, design, and extent to that indicated for this Project and whose work has resulted in construction with a record of successful in-service performance.
- B. Engineer Qualifications: A professional engineer legally authorized to practice in the jurisdiction where project is located and experienced in providing engineering services of the kind indicated that have resulted in the installation of steel deck similar to this project in material, design, and extent and that have a record of successful in-service performance.
- C. Testing Agency Qualifications: Qualified according to ASTM E 329 for testing indicated.
- D. Welding Qualifications: Qualify procedures and personnel according to AWS D1.3, "Structural Welding Code - Sheet Steel."

1.6 DELIVERY, STORAGE, AND HANDLING

- A. Protect steel deck from corrosion, deformation, and other damage during delivery, storage, and handling.
- B. Stack steel deck on platforms or pallets and slope to provide drainage. Protect with a waterproof covering and ventilate to avoid condensation.

PART 2 - PRODUCTS

2.1 PERFORMANCE REQUIREMENTS

- A. AISI Specifications: Comply with calculated structural characteristics of steel deck according to AISI's "North American Specification for the Design of Cold-Formed Steel Structural Members."
- B. Fire-Resistance Ratings: Comply with ASTM E 119; testing by a qualified testing agency. Identify products with appropriate markings of applicable testing agency.
 - 1. Indicate design designations from UL's "Fire Resistance Directory" or from the listings of another qualified testing agency.

2.2 ROOF DECK

- A. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
 - 1. Canam Buildings US, Inc.; Canam Group Inc.

2. New Millennium Building Systems, LLC.
 3. Epic Metals Corporation.
 4. Marlyn Steel Decks, Inc.
 5. Vulcraft Group; Division of Nucor Group.
 6. Roof Deck, Inc.
 7. Wheeling Corrugating Company; Div. of Wheeling-Pittsburgh Steel Corporation.
- B. Roof Deck: Fabricate panels, without top-flange stiffening grooves, to comply with "SDI Specifications and Commentary for Steel Roof Deck," in SDI Publication No. 31, and with the following:
1. Galvanized-Steel Sheet: ASTM A 653/A 653M, Structural Steel (SS), Grade 33 zinc coating.
 2. Deck Profile: Type WR, wide rib.
 3. Profile Depth: 1-1/2 inches
 4. Design Uncoated-Steel Thickness: 0.0358 inch.
 5. Span Condition: As indicated.
 6. Side Laps: Overlapped.

2.3 ACCESSORIES

- A. General: Provide manufacturer's standard accessory materials for deck that comply with requirements indicated.
- B. Mechanical Fasteners: Corrosion-resistant, low-velocity, power-actuated or pneumatically driven carbon-steel fasteners; or self-drilling, self-threading screws.
- C. Side-Lap Fasteners: Corrosion-resistant, hexagonal washer head; self-drilling, carbon-steel screws, No. 10 minimum diameter.
- D. Flexible Closure Strips: Vulcanized, closed-cell, synthetic rubber.
- E. Miscellaneous Sheet Metal Deck Accessories: Steel sheet, minimum yield strength of 33,000 psi, not less than 0.0359-inch design uncoated thickness, of same material and finish as deck; of profile indicated or required for application.
- F. Pour Stops and Girder Fillers: Steel sheet, minimum yield strength of 33,000 psi, of same material and finish as deck, and of thickness and profile indicated.
- G. Weld Washers: Uncoated steel sheet, shaped to fit deck rib, 0.0598 inch thick, with factory-punched hole of 3/8-inch minimum diameter.
- H. Galvanizing Repair Paint: ASTM A 780 or SSPC-Paint 20 or MIL-P-21035B, with dry film containing a minimum of 94 percent zinc dust by weight.
- I. Repair Paint: Manufacturer's standard rust-inhibitive primer of same color as primer.

PART 3 - EXECUTION

3.1 EXAMINATION

- A. Examine supporting frame and field conditions for compliance with requirements for installation tolerances and other conditions affecting performance. Notify Contractor in writing on unsatisfactory conditions.

- B. Proceed with installation only after unsatisfactory conditions have been corrected.

3.2 INSTALLATION, GENERAL

- A. Install deck panels and accessories according to applicable specifications and commentary in SDI Publication No. 31, manufacturer's written instructions, and requirements in this Section.
- B. Install temporary shoring before placing deck panels if required to meet deflection limitations.
- C. Locate deck bundles to prevent overloading of supporting members.
- D. Do not place deck panels on concrete until concrete has cured.
- E. Place deck panels on supporting frame and adjust to final position with ends accurately aligned and bearing on supporting frame before being permanently fastened. Do not stretch or contract side-lap interlocks.
- F. Place deck panels flat and square and fasten to supporting frame without warp or deflection.
 - 1. Deck panels shall be installed to span a minimum of three supports.
- G. Cut and neatly fit deck panels and accessories around openings and other work projecting through or adjacent to deck.
- H. Provide additional reinforcement and closure pieces at openings as required for strength, continuity of deck, and support of other work.
 - 1. Deck around openings 6" to 12" in size, reinforce by means of flat galvanized steel sheet placed over opening on top of floor decking and fusion welded to surface of deck. Provide 0.0478-inch-thick steel sheet of same quality as deck units at least 12" wider and longer than opening. Space welds at each corner and not more than 12" o.c. along each side.
 - 2. Deck openings from 15" wide to 30" wide, and are not supported by structural members reinforced by welding a 1"x1-1/4" steel angle to underside of deck at right angles to deck ribs. Extend angle 3 ribs beyond each side of opening and weld to bottom surface of each rib. Reinforce opening side parallel to deck ribs with a 12" wide, 0.0359-inch-thick steel sheet placed on top surface of decking, welded at each corner and at 12" o.c. along each side. Side reinforcing may be omitted when a roof sump pan is to be installed over the opening 12" wider and longer than the opening. Provide welds at each corner and spaced not more than 12" o.c. along each side.
- I. Comply with AWS requirements and procedures for manual shielded metal arc welding, appearance and quality of welds, and methods used for correcting welding work.
- J. Exposed Steel Deck: Paint shop-primed steel deck in the field in accordance with Division 09 Section "Painting and Finishing" requirements.

3.3 ROOF-DECK INSTALLATION

- A. Fasten roof-deck panels to steel supporting members by arc spot (puddle) welds of the surface diameter indicated or arc seam welds with an equal perimeter that is not less than 1-1/2 inches long, and as follows:
 - 1. Weld Diameter: 5/8 inch, nominal.

2. Weld Spacing: Weld edge and interior ribs of deck units with a minimum of two welds per deck unit at each support. Space welds 12 inches apart in the field of roof and 6 inches apart in roof corners and perimeter, based on roof-area definitions in FMG Loss Prevention Data Sheet 1-28.
 3. Weld Washers: Install weld washers at each weld location.
- B. Side-Lap and Perimeter Edge Fastening: Fasten side laps and perimeter edges of panels between supports, at intervals not exceeding the lesser of 1/2 of the span or 36 inches, and as follows:
1. Fasten with a minimum of 1-1/2-inch- long welds.
- C. End Bearing: Install deck ends over supporting frame with a minimum end bearing of 1-1/2 inches, with end joints as follows:
1. End Joints: Lapped 2 inches minimum.
- D. Miscellaneous Roof-Deck Accessories: Install ridge and valley plates, finish strips, end closures, and reinforcing channels according to deck manufacturer's written instructions. Weld to substrate to provide a complete deck installation.
1. Weld cover plates at changes in direction of roof-deck panels unless otherwise indicated.
- E. Flexible Closure Strips: Install flexible closure strips over partitions, walls, and where indicated. Install with adhesive according to manufacturer's written instructions to ensure complete closure.

3.4 FIELD QUALITY CONTROL

- A. Testing Agency: Contractor shall engage a qualified testing agency to perform tests and inspections.
- B. Field welds will be subject to inspection.
- C. Testing agency will report inspection results promptly and in writing to Contractor and Architect.
- D. Remove and replace work that does not comply with specified requirements.
- E. Additional inspecting, at Contractor's expense, will be performed to determine compliance of corrected work with specified requirements.

3.5 PROTECTION

- A. Galvanizing Repairs: Prepare and repair damaged galvanized coatings on both surfaces of deck with galvanized repair paint according to ASTM A 780 and manufacturer's written instructions.
- B. Repair Painting: Wire brush and clean rust spots, welds, and abraded areas on both surfaces of prime-painted deck immediately after installation, and apply repair paint.
 1. Apply repair paint, of same color as adjacent shop-primed deck, to bottom surfaces of deck exposed to view.
 2. Wire brushing, cleaning, and repair painting of bottom deck surfaces are included in Division 09 Section "Painting and Finishing."
- C. Repair Painting: Wire brushing, cleaning, and repair painting of rust spots, welds, and abraded areas of both deck surfaces are included in Division 09 Section "Painting and Finishing".

- D. Provide final protection and maintain conditions to ensure that steel deck is without damage or deterioration at time of Substantial Completion.

END OF SECTION 05 31 00