

SECTION 08 56 53 - SECURITY WINDOWS

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General Conditions and Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. Section Includes:
 - 1. Fixed, transaction security windows.

1.3 COORDINATION

- A. Coordinate installation of anchorages for security windows. Furnish setting drawings, templates, and directions for installing anchorages, including sleeves, concrete inserts, anchor bolts, and items with integral anchors, that are to be embedded in adjacent construction. Deliver such items to Project site in time for installation.

1.4 ACTION SUBMITTALS

- A. Product Data: For each type of product.
 - 1. Include construction details, material descriptions, dimensions of individual components and profiles, and finishes for window units.
- B. Shop Drawings: For security windows.
 - 1. Include plans, elevations, sections, and attachments to other work.
 - 2. Glazing details.
 - 3. Details of deal tray transaction counter and speaking aperture.

1.5 DELIVERY, STORAGE, AND HANDLING

- A. Pack security windows in wood crates for shipment. Crate glazing separate from frames unless factory glazed.
- B. Label security window packaging with drawing designation.
- C. Store crated security windows on raised blocks to prevent moisture damage.

1.6 FIELD CONDITIONS

- A. Field Measurements: Verify actual dimensions of openings by field measurements before fabrication.

PART 2 - PRODUCTS

2.1 FIXED, TRANSACTION SECURITY WINDOWS

- A. Provide fixed, framed transaction windows with speaking aperture and deal tray that allows the transfer of currency and documents.
 - 1. Basis of Design: Subject to compliance with requirements, fixed, transaction security windows incorporated into the project shall be based on systems as follows:
 - a. Insulgard Security Products; "AVT Bullet Resisting Transaction Window" with "Round Stainless Steel Bullet Resistant Speak Thru".
 - 2. Acceptable Manufacturers: Subject to compliance with requirements, in lieu of the Basis of Design manufacturer, Contractor may provide products from the following manufacturers that meet or exceed the published data of the specified Basis of Design product.
 - a. Armortex.
 - b. Chicago Bullet Proof Systems.
 - c. National Bullet Proof, Inc.
 - d. Overly Door Company.
- B. Ballistic Resistance: Level 3 for complete system in accordance with UL 752.
- C. Framing: Perimeter framing, mullions, and glazing stops shall be bullet-resistant extruded aluminum.
 - 1. Finish: Clear anodic finish.
- D. Size: 30" x 48".
- E. Sill: Formed from stainless steel and designed for glazing.
 - 1. Transaction Counter: Stainless steel, with integral deal tray centered in opening.
- F. Glazing: Bullet-resistant, glass-clad polycarbonate glazing in accordance with ballistic threat level indicated.

2.2 FABRICATION

- A. General: Fabricate security windows to provide a complete system for assembly of components and anchorage of window units.
 - 1. Provide units that are reglazable from the secure side without dismantling the nonsecure side of framing.
 - 2. Prepare security windows for glazing unless preglazing at the factory is indicated.
- B. Framing: Miter or cope corners the full depth of framing; weld and dress smooth.
 - 1. Fabricate framing with manufacturer's standard, internal opaque armoring in thicknesses required for security windows to comply with ballistics-resistance performance indicated.
- C. Glazing Stops: Finish glazing stops to match security window framing.

1. Secure-Side (Exterior) Glazing Stops: Welded or integral to framing.
 2. Nonsecure-Side (Interior) Glazing Stops: Removable, coordinated with glazing indicated.
- D. Welding: Weld components to comply with referenced AWS standard. To greatest extent possible, weld before finishing and in concealed locations to minimize distortion or discoloration of finish. Remove weld spatter and welding oxides from exposed surfaces by descaling or grinding.
- E. Metal Protection: Separate dissimilar metals to protect against galvanic action by painting contact surfaces with primer or by applying sealant or tape recommended by manufacturer for this purpose.
- F. Factory-cut openings in glazing for speaking apertures.

2.3 GENERAL FINISH REQUIREMENTS

- A. Protect mechanical finishes on exposed surfaces from damage by applying a strippable, temporary protective covering before shipping.
- B. Appearance of Finished Work: Noticeable variations in same piece are not acceptable. Variations in appearance of adjoining components are acceptable if they are within the range of approved Samples and are assembled or installed to minimize contrast.

2.4 ALUMINUM FINISHES

- A. Clear Anodic Finish: AAMA 611, AA-M10C22A41, Class I.

2.5 STAINLESS-STEEL FINISHES

- A. Surface Preparation: Remove tool and die marks and stretch lines, or blend into finish.
- B. Polished Finishes: Grind and polish surfaces to produce uniform finish, free of cross scratches.
1. Run grain of directional finishes with long dimension of each piece.
 2. When polishing is completed, passivate and rinse surfaces. Remove embedded foreign matter and leave surfaces chemically clean.
 3. Directional Satin Finish: No. 4.

PART 3 - EXECUTION

3.1 EXAMINATION

- A. Examine substrates, areas, and conditions, with Installer present, for compliance with requirements for installation tolerances and other conditions affecting performance of security windows.
- B. Examine roughing-in for embedded and built-in anchors to verify actual locations of security window connections before security window installation.
- C. For the record, prepare written report, endorsed by Installer, listing conditions detrimental to performance of security windows.

- D. Inspect built-in and cast-in anchor installations, before installing security windows, to verify that anchor installations comply with requirements. Prepare inspection reports.
 - 1. Remove and replace anchors where inspections indicate that they do not comply with specified requirements. Reinspect after repairs or replacements are made.
 - 2. Perform additional inspections to determine compliance of replaced or additional work. Prepare anchor inspection reports.
- E. For glazing materials whose orientation is critical for performance, verify installation orientation.
- F. Proceed with installation only after unsatisfactory conditions have been corrected.

3.2 PREPARATION

- A. Coordination: Furnish layouts for cast-in-place anchors, clips, and other security window anchors whose installation is specified in other Sections.
 - 1. Furnish cast-in-place anchors and similar devices to other trades for installation well in advance of time needed for coordinating other work.

3.3 INSTALLATION

- A. Fastening to In-Place Construction: Provide anchorage devices and fasteners where necessary for securing security windows to in-place construction. Include threaded fasteners for inserts, security fasteners, and other connectors.
- B. Fasteners: Install security windows using fasteners recommended by manufacturer with head style appropriate for installation requirements, strength, and finish of adjacent materials. Provide stainless-steel fasteners in stainless-steel materials.
- C. Sealants: Comply with requirements in Division 07 Section "Joint Sealants" for installing sealants, fillers, and gaskets.
 - 1. Set continuous sill members and flashing in a full sealant bed to provide weathertight construction unless otherwise indicated.
 - 2. Seal frame perimeter with sealant to provide weathertight construction unless otherwise indicated.
- D. Metal Protection: Where dissimilar metals will contact each other, protect against galvanic action by painting contact surfaces with primer or by applying sealant or tape recommended in writing by manufacturer for this purpose. Where aluminum will contact concrete or masonry, protect against corrosion by painting contact surfaces with bituminous paint.

3.4 FIELD QUALITY CONTROL

- A. Inspect installed products to verify compliance with requirements. Prepare inspection reports and indicate compliance with and deviations from the Contract Documents.

3.5 CLEANING AND PROTECTION

- A. Clean surfaces promptly after installation of security windows. Take care to avoid damaging the finish. Remove excess glazing and sealant compounds, dirt, and other substances.

- B. Clean glass of preglazed security windows promptly after installation.
- C. Provide temporary protection to ensure that security windows are without damage at time of Substantial Completion.

END OF SECTION 08 56 53