

## SECTION 23 82 50 – HYDRONIC UNIT HEATERS

### PART 1 - GENERAL

#### 1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and other Division 1 Specification Sections, apply to this Section.

#### 1.2 SUMMARY

- A. This Section includes propeller unit heaters with hot-water coils. Obtain all unit heaters through one source and from a single manufacturer.

#### 1.3 QUALITY ASSURANCE

- A. Obtain all unit heaters through one source from a single manufacturer, regularly engaged in production of the units.

#### 1.4 SUBMITTALS

- A. Product Data: Include rated capacities, operating characteristics, furnished specialties, and accessories for each unit type and configuration.
- B. Operation and Maintenance Data: For unit heaters.

### PART 2 - PRODUCTS

#### 2.1 MANUFACTURERS

- A. Manufacturers: Subject to compliance with requirements, provide unit heaters manufactured by one of the following:
  - 1. Trane.
  - 2. Sigma
  - 3. Sterling.
  - 4. Zehnder Rittling

#### 2.2 UNIT HEATERS

- A. Description: An assembly including casing, coil, fan, and motor with adjustable discharge louvers. Comply with UL 2021 and UL 823.

HYDRONIC UNIT HEATERS

2.3 CABINETS

- A. Cabinets are constructed from heavy duty cold rolled corrosion resistant steel. Provide a baked finish in the manufacturer's standard color.
- B. Fronts have integral double-folded discharge frame for additional cabinet rigidity. Back panels have integral inlet collars for superior stiffness.
- C. Horizontal units to be furnished with louvres and individually adjustable blades.

2.4 COILS

- A. Standard coils are constructed from heavy wall 5/8" outside diameter copper tube with mechanically bonded aluminum fins. Coils are pressure tested at 350 psig.

2.5 FAN

- A. Fans to be statically and dynamically balanced for quiet, low vibration operation.

2.6 FAN MOTORS

- A. Motors to be totally enclosed with automatic thermal overload protection. Motors to be resilient mounted onto fan guards for quiet, low-vibration operation.
- B. Motor Type: Permanently lubricated.

PART 3 - EXECUTION

3.1 EXAMINATION

- A. Examine areas to receive propeller unit heaters for compliance with requirements for installation tolerances and other conditions affecting performance.
- B. Examine roughing-in for piping and electrical connections to verify actual locations before propeller unit-heater installation. Proceed with installation only after unsatisfactory conditions have been corrected.

3.2 INSTALLATION

- A. Install propeller unit heaters level and plumb.
- B. Install propeller unit heaters to comply with NFPA 90A.
- C. Suspend propeller unit heaters from structure with all-thread hanger rods with vibration isolators.

3.3 CONNECTIONS

- A. Piping installation requirements are specified in other Division 23 Sections. Drawings indicate general arrangement of piping, fittings, and specialties.

- B. Install piping adjacent to unit to allow service and maintenance.
- C. Unless otherwise indicated, install union, control valve, strainer and ball valve on supply-water connection and union, calibrated balancing valve and ball valve on return-water connection of unit heater.

#### 3.4 FIELD QUALITY CONTROL

- A. Perform field tests and inspections as required by the manufacturer. Provide test reports.
- B. Remove and replace malfunctioning units and retest as specified above.

END OF SECTION 23 82 50