


NUMBERED NOTES: (THIS SHEET ONLY)

1. PROVIDE 4" EMPTY CONDUIT FOR COMMUNICATIONS. PROVIDE 4" EMPTY CONDUIT FOR ELECTRIC. CONFIRM CONDUIT ROUTING WITH OWNER. CONFIRM STUB-UP LOCATION AT PROPOSED TICKET BUILDING WITH OWNER. PROVIDE PULL STRING IN BOTH CONDUITS.
2. PROVIDE 4" EMPTY COMMUNICATIONS CONDUIT FROM STORAGE ROOM 117. CONFIRM WITH OWNER LOCATION OF EXISTING CONDUIT TO UNDER BLEACHERS QUAZITE BOX FOR THE PRESS BOX. EC TO MAKE ALLOWANCE TO PROVIDE TRENCHING AND CONDUIT TO MAKE CONNECTION WITH EXISTING CONDUIT IN THE EXISTING 18"X24" QUAZITE BOX.
3. PROVIDE 4" EMPTY COMMUNICATION CONDUIT FROM EXISTING COMMUNICATION BOX TO STORAGE ROOM 117. STUB-UP AT BACKBOARD. CONFIRM CONDUIT ROUTING AND STUB-UP LOCATION WITH OWNER. PROVIDE PULL STRING.
4. EXTEND EXISTING 4" CONDUIT FROM APX ELECTRICAL ENCLOSURE TO PANEL H1 IN STORAGE RM 117. PROVIDE NEW CONDUCTORS FROM APX PANEL TO PANEL H1 AS INDICATED ON ONE-LINE.
5. 4" SPARE FOR FIELDHOUSE ELECTRIC. TERMINATES NEAR WATER AND SEWER PIPES WHICH ARE STUBBED UP ABOVE GRADE.

1 OVERALL ROOF PLAN - POWER
E-1 SCALE: 1/8" = 1'-0"



DRAWING NO.
E-4


SITE PLAN

PROJECT NO. 1757-24-001
SCALE: AS NOTED
DATE: 04/09/24

REVISIONS

NO.	DATE	DESCRIPTION
1	4-9-24	ISSUED FOR BIDDING

NEW FIELDHOUSE FOR THE
MIDD-WEST SCHOOL DISTRICT
MIDDLEBURG, PA



J.P.D. ARCHITECTS, LLC.
ARCHITECTURE • DESIGN • CONSULTING SERVICES
Cell: 717-475-6044 • Email: jpdkey@gmail.com

DRAWN BY: CHECKED BY: APPROVED BY: